

Specification No.: 21-350020  
Advertisement Date: 1/22/2021

**BID SOLICITATION FOR WATER TREATMENT PRODUCTS AND SERVICES  
FOR THE  
BOARD OF EDUCATION OF THE CITY OF CHICAGO**

Required for use by the Department of Facilities

Contract Period: Two (2) years from Contract commencement  
with the Board having up to three (3) options to renew for additional one (1) year periods

**BIDS ARE TO BE SUBMITTED ELECTRONICALLY ACCORDING TO THE INSTRUCTIONS  
CONTAINED IN THE SUBMITTAL REQUIREMENTS SECTION OF THIS BID. IF BIDDER  
DESIGNATES ANY PORTION OF ITS SUBMITTAL AS EXEMPT UNDER THE ILLINOIS FREEDOM OF  
INFORMATION ACT ("FOIA"), BIDDER SHALL ALSO PROVIDE ONE (1) ELECTRONIC VERSION OF  
THE REDACTED BID.**

**BIDS MUST BE RECEIVED NO LATER THAN FEBRUARY 22, 2021 AT 2 P.M. CENTRAL TIME  
THROUGH THE FOLLOWING LINK:**

<https://cps.bonfirehub.com/opportunities/private/a0bc635ca8946bd681c8232f99998d39>

A Virtual Bid reading will be held at the following link:

Meeting ID

[meet.google.com/bxt-kphf-svz](https://meet.google.com/bxt-kphf-svz)

Phone Numbers

**(US)+1 347-450-1910**

**PIN: 696 624 219#**

A Virtual Pre-Submittal Conference will be held on February 11, 2021, at 1pm Central Time, at the following link:

Meeting ID

[meet.google.com/aak-djpf-uhu](https://meet.google.com/aak-djpf-uhu)

Phone Numbers

**(US)+1 774-419-5200**

**PIN: 661 743 446#**

Attendance is not mandatory, but encouraged. A MBE/WBE Networking Session will follow immediately after the Pre-Submittal Conference.

**ISSUED BY THE DEPARTMENT OF PROCUREMENT**

**LORI E. LIGHTFOOT  
MAYOR**

**JANICE K. JACKSON, EdD  
CHIEF EXECUTIVE OFFICER**

**MIGUEL DEL VALLE  
PRESIDENT**

**JONATHAN MAPLES  
CHIEF PROCUREMENT OFFICER**

For current Bid/RFP/RFQ information, Log in at:

<http://cps.edu/procurement/Pages/currentcontracts.aspx>

- I. General Invitation
- II. General Terms and Conditions
- III. Specific Terms and Conditions
- IV. Scope of Products and Services
- V. Submittal Requirements
- VI. Evaluation Criteria and Basis of Award
- VII. Bid Tabulation Worksheet
- VIII. Bid Execution Page

Attachments:

Attachment A: Contractor's Disclosure Form

Attachment B: W-9 Tax Form

Attachment C: MBE/WBE Compliance Plan

Attachment D: Bid Tabulation Page Water Treatment Products and Services\_Boiler

## I. GENERAL INVITATION

### REQUEST FOR BID FOR WATER TREATMENT PRODUCTS AND SERVICES BID

The Board of Education of the City of Chicago (the “**Board**”) invites the submission of bids from firms (“**Bidder(s)**”) that wish to provide Water Treatment Products and Services (“**Products**” and “**Services**”) to the Board. The Board reserves the right to (i) select one or more Bidders to provide the Products and Services outlined herein; (ii) accept portions of the bid from one or more Bidders; or, (iii) reject any and all bids.

Bidder may only bid in one capacity: either individually, as a joint venture, a partnership, or other type of legal entity. A “Person”, “Partnership”, “Joint Venture” or “Sole Proprietorship” operating under an Assumed Name must be registered with the Illinois county in which located, as provided in 805 ILCS 405.

Bids must be submitted electronically according to the instructions contained in the Submittal Requirements Section of this bid.

Bidder shall be responsible for successful delivery of its bid to the Chief Procurement Officer before the advertised date and hour for the receipt of the bids. Bids submitted or partially submitted past the advertised date and hour for the bid receipt will not be considered and will be rejected, except in the case of error by CPS.

**Bidder shall bear all costs of responding to this Bid.**

#### **Downloading Bid Solicitations/Addenda:**

This bid and all attachments are available for download from the Board’s website at:

<https://cps.edu/procurement/Pages/currentcontracts.aspx>

#### **Questions:**

Firms seeking assistance shall only contact Keisha Saintil at [ksaintil@cps.edu](mailto:ksaintil@cps.edu). If a firm is in doubt as to the true meaning of a part of this solicitation the firm may submit a written request of clarification to the aforesaid individual with a reference to the Specification Number provided on the cover page of this solicitation. No telephone calls will be accepted.

**Firms, including all agents or subcontractors, who contact any other CPS personnel, either verbally or in writing, concerning this solicitation, are in violation of procurement procedures and any submitted bids from or including such individuals or entities may be disqualified.**

**NOTE: ALL QUESTIONS REGARDING THIS BID SOLICITATION MUST BE SUBMITTED IN WRITING VIA E-MAIL TO KEISHA SAINTIL ([ksaintil@cps.edu](mailto:ksaintil@cps.edu)) NO LATER THAN FEBRUARY 11, 2021 AT NOON (CENTRAL TIME).**

**All written questions received by the deadline will be answered via e-mail and any written clarification or response will also be posted on the Board’s website at: <http://cps.edu/procurement/Pages/currentcontracts.aspx>. Oral clarifications offered by any Board employee will not be binding to the Board. Late questions will not be answered.**

#### **Addenda:**

Any revisions of this solicitation deemed necessary by the Chief Procurement Officer will be made only by an addendum issued by the Department of Procurement not less than seventy-two (72) hours prior to the

## **I. GENERAL INVITATION**

submission deadline. A copy of any such addendum will be posted on the Office of Procurement website at: <http://cps.edu/procurement/Pages/currentcontracts.aspx> and may be e-mailed or mailed to Bidders.

Failure on the part of Bidder to receive any written addenda will not be grounds for withdrawal of a bid. Bidder must acknowledge receipt of each addendum issued in Section VIII: Bid Execution Page.

### **Errors, Omissions, and Withdrawal of Bids:**

Bidder is expected to comply with the true intent of this solicitation taken as a whole and shall not avail itself of any error or omission to the detriment of the Board. Should Bidder suspect an error, omission, or discrepancy in the specifications or instructions, Bidder shall immediately notify the Board in writing, and the Board will issue written corrections or clarifications in an addendum if necessary in the Board's sole discretion. Bidder shall not be allowed to benefit from errors in the document that could have been reasonably discovered by Bidder in the process of putting the bid together. Bidder is responsible for the contents of its bid and for satisfying the requirements set forth in this solicitation. Bids may be withdrawn at any time prior to the scheduled opening time. All requests to withdraw must be in writing; oral requests will not be honored. The request should be labeled and addressed in the same way as the original bid and should be clearly marked to indicate that it is a withdrawal of the bid. Resubmission of a withdrawn bid will be considered a new bid and must be submitted prior to the due date.

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**

## II. GENERAL TERMS AND CONDITIONS

1. **Contract:** If selected to provide the Products and Services described herein, Bidder shall adhere to the terms and conditions contained in this bid solicitation. The term “Contract” hereinafter refers collectively to this bid solicitation, all exhibits attached hereto and/or incorporated herein by reference, all addenda, Bidder’s response to this bid solicitation, and acceptance by the Board of such bid. In case of any conflict between the terms and conditions of this bid solicitation and the Bidder’s response, the following terms and conditions of the bid solicitation shall govern and control for all purposes.
  
2. **Term of Contract:** The term of this Contract shall commence on the date stated on the Section VII: Bid Execution Page and end two (2) years thereafter (“**Term**”), unless terminated sooner as provided herein. The Board shall have the right to renew this Contract for up to three (3) additional one (1) year periods as determined by the Board, upon the same terms, conditions and pricing (a “**Renewal Term**”). The Renewal Term shall be documented by a renewal agreement signed by the authorized representatives of the Board, approved by the Board’s General Counsel, and signed by the authorized representative of the successful Bidder.
  
3. **Scope of Products and Services:** Bidder agrees to deliver the Products and Services set forth in Section IV: Scope of Products and Services, in accordance with the terms and conditions of this Contract. “Products and Services” means, collectively, the products, deliverables, duties and responsibilities described in this Contract and any and all work necessary to complete them or carry them out fully and to the standard of performance required in this Contract. The Board retains final authority with respect to all Product and Services related decisions. Any changes in the Products and Services, including any increase or decrease in the amount paid by the Board for such Products and Services shall be documented in a written amendment signed by the authorized representatives of each party and approved by the Board’s General Counsel before the change can take effect.
  
4. **Purchase Orders, Billing and Payment Procedures; Electronic Payments:**
  - A. **Purchase Orders:** Orders must be on the Board’s Standard Purchase Order Form (“**PO**”). The pre-printed terms and conditions found on the Board’s Purchase Order shall apply to the extent that such terms supplement and are not inconsistent with the terms and conditions contained in this Contract. Under no circumstances shall Bidder deliver any Products or perform any Services without an approved Purchase Order.
  
  - B. **Billing and Payment Procedures:** All invoices must be submitted electronically via email in PDF format to [cpsinvoice@cps.edu](mailto:cpsinvoice@cps.edu). Each email may only contain one invoice and must include your vendor name and the CPS Purchase Order number. All invoices must include:
    - Bidder name and payment address
    - Unique invoice number (determined by bidder)
    - Valid purchase order number (only one PO number may be referenced on each invoice)
    - Invoice date
    - Itemized description of the Products and Services provided
    - Date the Products were delivered or Services performed
    - Detailed pricing information such as quantities, unit prices, discount, and final net amount due

Invoices shall be submitted in a timely manner. The final invoice shall be submitted no later than ninety (90) days after the expiration or termination of this Contract. If Bidder has more than one contract with the Board, separate invoices must be submitted for each contract. The Board shall process payments in accordance with the Local Government Prompt

## **II. GENERAL TERMS AND CONDITIONS**

Payment Act [50 ILCS 505/1 *et seq.*]. The Board reserves the right to request additional information and supporting documentation necessary for the Board to verify the Products delivered or Services performed under this Contract.

- C. **Electronic Payments:** Bidder agrees that, at the Board's sole discretion, the Board may make payment electronically to Bidder for any and all amounts due to Bidder pursuant to this Contract by means of the Board's procurement charge card account. Bidder recognizes that any charge to the Board's procurement charge card that is in excess of the open remaining amount as stipulated in the applicable Purchase Order, or any charge unaccompanied by the requisite documentation and data as required by the Board, shall be deemed invalid and disputed by the Board. Bidder further recognizes that, in the absence of any supporting documentation as may be required by the Board, payments associated with disputed charges shall be rescinded by the Board and deemed not owed by the Board. Bidder agrees to comply with the rules, procedures and documentation required for electronic payment via the Board's procurement charge card as established by the Board's Department of Procurement.
5. **Standards of Performance:** Bidder shall devote, and shall cause all of its employees, agents and subcontractors to devote, such of their time, attention, best skill and judgment, knowledge and professional ability as is necessary to deliver all Products and perform all Services effectively and efficiently and to the satisfaction of the Chief Procurement Officer ("**CPO**"). Bidder shall retain and utilize, as required by law or by contract, professionals licensed to practice in the State of Illinois in the applicable profession. Bidder shall use efficient business administration methods and deliver the Products and Services in a workmanlike manner in accordance with generally recognized industry standards for similar products and in an expeditious and economical manner consistent with the best interests of the Board, so as to assure, among other things, that the Products and Services are supplied at a reasonable cost to the Board and that Products and Services delivered by other entities or persons in connection with this Contract are efficiently and cost-effectively delivered. Bidder acknowledges that, if in the course of providing Products and Services hereunder, it is entrusted with or has access to valuable and confidential information and records of the Board, that with respect to that information, Bidder agrees to be held to the standard of care of a fiduciary. Any review, approval, acceptance of Products and Services or payment for same by the Board does not relieve Bidder of its responsibility for any nonconformity with the Specifications or any defects in the Products and Services. Bidder shall remain responsible for all Products and Services furnished hereunder, whether furnished by Bidder or its subcontractors or others on its behalf.
6. **Personnel/Adequate Staffing:** Bidder must assign and maintain during the Term of the Contract and any renewal of it, an adequate staff of competent personnel that is fully trained, equipped, licensed as appropriate, available as needed, qualified and assigned to deliver the Products and Services. If the Board determines, in its sole discretion, which any employee, subcontractor, or other person providing Products hereunder for Bidder is not performing in accordance with the performance standards or other requirements in this Contract, the Board shall have the right to direct the Bidder to remove that person from delivering Products and Services under the Contract.
7. **Compensation and Pricing:**
- A. **Compensation:** The total maximum compensation amount payable to Bidder pursuant to this Contract shall not exceed the amount specified in Section VIII: Bid Execution Page, with no reimbursement for expenses except as specifically set out in this Contract, and shall be firm for the duration of the Term of this Contract. Bidder is not entitled to any payment nor is the Board obligated to pay Bidder any amount solely by virtue of entering into this Contract. Compensation shall be based on actual Products and Services delivered during the Term of this Contract, and the Board shall not be obligated to pay for any Products and Services not in compliance with this Contract. In the event of early termination of this Contract, the Board

## II. GENERAL TERMS AND CONDITIONS

shall only be obligated to pay for Products and Services delivered up to the date of termination. Unless the Board has requested that Products and Services ordered before the effective termination or expiration date be delivered after the effective date of termination or expiration, the Board shall not have any liability for any Products and Services delivered after the effective expiration or termination date.

- B. **Prices:** The prices indicated on Bid Tabulation Worksheet shall be firm for the Term of this Contract, and any increases that are permitted by the Board for the Renewal Term shall not exceed the maximum percentage indicated in the Bid Tabulation Worksheet for that Renewal Term. The maximum payment amount for any Renewal Term shall be established by the Board in a separate written renewal agreement, if the option(s) is exercised.
8. **Non-appropriation:** Expenditures not appropriated by the Board in its current fiscal year budget are deemed to be contingent liabilities only and are subject to appropriation in subsequent fiscal year budgets. In the event sufficient funds are not appropriated in a subsequent fiscal year by the Board for performance under this Contract, the Board shall notify Bidder and this Contract shall terminate on the earlier of the last day of the fiscal period for which sufficient funds were appropriated or whenever the funds appropriated for payment under this Contract are exhausted. In no event shall the Board be liable to the Bidder for any amount in excess of the current amount appropriated and budgeted by the Board to fund payments under this Contract.
9. **Audit and Document Retention:** Bidder shall permit and cooperate in good faith in any audits by the Board, including its Department of Procurement or its agents for compliance by the Bidder with this Contract. Bidder shall promptly rectify errors and resolve disputes that may be reported as a part of any such audit. Bidder shall furnish the Board with such information, supporting documentation and reports as may be requested relative to costs of the delivery of Products and Services, and compliance with applicable MBE/WBE requirements. Failure of the Bidder to comply in full and cooperate with the requests of the Board or its agents shall give the Board, in addition to all other rights and remedies hereunder, the right to charge the Bidder for the cost of such audit. Bidder shall maintain all records relating to Bidder's delivery of Products and Services under this Contract. As used in this Section, "Records" shall include all correspondence, receipts, vouchers, memoranda, and other data, regardless of type or medium (including emails or other electronically stored data) relating to this Contract and Bidder's delivery of Products and Services. All records referenced above shall be retained for five (5) years after the termination or expiration of this Contract and shall be subject to inspection and audit by the Board. If any audit, litigation or other action involving the records is being conducted or has not been resolved, all applicable records must be retained until the proceeding is closed. Bidder shall require all of its subcontractors to maintain the above described records and allow the Board the same right to inspect and audit said records as set forth herein.
10. **Termination, Events of Default, and Remedies:**
- A. **Early Termination:** The Board may terminate this Contract in whole or in part without cause, at any time by a notice in writing from the Board to Bidder in accordance with the notice provisions herein. The effective date of termination shall be thirty (30) calendar days from the date the notice is received or the date stated in the notice, whichever is later.

After notice is received, Bidder must restrict its activities, and those of its subcontractors, to winding down all activities previously begun under this Contract. No costs incurred after the effective date of the termination are allowed. Unless the Board has requested that Products and Services ordered before the effective termination or expiration date be delivered after the effective termination or expiration date, the Board shall not have any liability for any Products and Services delivered after the expiration/termination date.

## II. GENERAL TERMS AND CONDITIONS

Bidder must include in its contracts with subcontractors an early termination provision in form and substance equivalent to this early termination provision to prevent claims against the Board arising from termination of subcontracts after the early termination of this Contract.

Bidder shall not be entitled to make any early termination claims against the Board resulting from any subcontractor's claims against Bidder or the Board to the extent inconsistent with this provision.

- B. Suspension of Product and Service Delivery: The Board may, upon thirty (30) calendar days written notice, direct Bidder to suspend the delivery of Products and Services. Bidder shall promptly resume delivering Products and Services upon written notice from the Board and upon such equitable extension of time as may be mutually agreed upon in writing by the Board and Bidder. Responsibility for any additional costs or expenses actually incurred by Bidder as a result of remobilization shall be determined by mutual agreement of the parties.
- C. Bidder's Events of Default: Events of default ("**Events of Default**") include, but are not limited to, the following:
- 1) Any action or failure to act by Bidder which affects the safety and/or welfare of students or Board staff;
  - 2) Any material misrepresentation by Bidder in the inducement or the performance of this Contract;
  - 3) Breach of any term, condition, representation or warranty made by Bidder in this Contract;
  - 4) Failure of Bidder to perform any of its obligations under this Contract, including but not limited to, the following:
    - i) Failure to timely deliver any portion of the Products and Services in the manner specified herein;
    - ii) Failure to maintain sufficient personnel, material, or equipment to ensure the timely delivery of the Products and Services;
    - iii) Failure to deliver the Products and Services in a manner reasonably satisfactory to the CPO;
    - iv) Failure to promptly re-deliver, within a reasonable time and at no cost to the Board, Products and Services that were determined by the Board to be incomplete or unsatisfactory;
    - v) Discontinuance of the delivery of Products and Services for reasons within Bidder's reasonable control;
    - vi) Failure to comply with any term of this Contract, including but not limited to, the provisions concerning insurance and nondiscrimination, and any other acts specifically and expressly stated in this Contract constituting an Event of Default; or
    - vii) Failure to meet the MBE/WBE program participation goals;
  - 5) Default by Bidder under any other agreement Bidder may presently have or may enter into with the Board;
  - 6) Where Products and Services include contact with CPS students, any failure to comply with the Background Check Section, in whole or in part; and



## **II. GENERAL TERMS AND CONDITIONS**

- 7) Assignment by Bidder for the benefit of creditors or consent by Bidder to the appointment of a trustee or receiver or the filing by or against Bidder of any petition or proceeding under any bankruptcy, insolvency or similar law that is not dismissed within sixty (60) days of the date of its filing.

D. **Remedies:** The Board in its sole discretion may declare Bidder in default, in whole or in part, if Bidder commits an Event of Default. The Chief Procurement Officer may, in his/her sole discretion, give Bidder an opportunity to cure the default within a certain period of time (the “**Cure Period**”) or s/he may determine that an opportunity to cure is not warranted or necessary. The Chief Procurement Officer shall give Bidder written notice of the default, either in the form of a cure notice (“**Cure Notice**”), or if no opportunity to cure is granted, a default notice (“**Default Notice**”).

The Chief Procurement Officer may give a Default Notice after a Cure Notice has been provided if: (i) Bidder fails to effect a cure within the Cure Period given in the applicable Cure Notice, or (ii), if the Event of Default cannot be reasonably cured within said Cure Period, Bidder fails to commence and continue diligent efforts to cure in the sole opinion of the Board.

A written Default Notice shall be final and effective termination of the Contract, in whole or in part, upon Bidder’s receipt of the notice or on the date as set forth in the notice, whichever is later. Upon receipt of a Default Notice, Bidder must discontinue all Products and Services unless specifically directed otherwise in the notice, and Bidder must deliver to the Board all materials prepared or created in performance of this Contract, whether completed or in-process.

Upon the occurrence of an Event of Default, the Board may invoke any or all of the following remedies:

- 1) The right to take over and complete the delivery of Products and Services or any part thereof, by contract or otherwise as agent for and at the cost of Bidder either directly or through others. Bidder shall be liable to the Board for any excess costs incurred by the Board. Any amount due Bidder under this Contract or any other agreement Bidder may have with the Board may be offset against amounts claimed due by the Board in exercising this remedy;
- 2) The right to terminate this Contract, in whole or in part, as to any or all of the Products and Services yet to be delivered effective at a time specified by the Board;
- 3) The right to suspend the delivery of Products and Services during the Cure Period if the default results from Bidder's action or failure to act which affects the safety or welfare of students or Board staff. In the event that the delivery of Products and Services is resumed, Bidder shall not be entitled to seek reimbursement from the Board for any additional costs and expenses incurred as a result of the remobilization;
- 4) The right to specific performance, an injunction or any other appropriate equitable remedy;
- 5) The right to receive from Bidder any and all damages incurred as a result or in consequence of an Event of Default;
- 6) The right to money damages;

## **II. GENERAL TERMS AND CONDITIONS**

- 7) The right to withhold all or part of Bidder's compensation that are due or that may become due under the Contract; and
- 8) The right to use an Event of Default as a basis to deem Bidder non-responsible in future contracts to be awarded by the Board and/or seek debarment of Bidder pursuant to the Board's Debarment Policy (08-1217-PO1), as may be amended from any time.

The Board may elect not to declare Bidder in default or to terminate this Contract. The parties acknowledge that this provision is solely for the benefit of the Board and that if the Board permits Bidder to continue to deliver the Products and Services despite one or more Events of Default, Bidder shall in no way be relieved of any responsibilities, duties or obligations under this Contract nor shall the Board waive or relinquish any of its rights under this Contract, at law, equity or statute, nor shall the Board be deemed to have waived or relinquished any of the rights it has to declare an Event of Default in the future. If the Chief Procurement Officer decides not to terminate, then s/he may decide at any time thereafter to terminate the Contract, in whole or in part, in a subsequent Default Notice.

The remedies under the terms of this Contract are not intended to be exclusive of any other remedies provided, but each and every such remedy shall be cumulative and shall be in addition to any other remedies, existing now or hereafter, at law, in equity or by statute. No delay or omission to exercise any right or power accruing upon the occurrence of any Event of Default shall be construed as a waiver of any Event of Default or acquiescence thereto, and every such right and power may be exercised from time to time and as often as may be deemed expedient.

If the Board's election to terminate this Contract for default is determined by a court of competent jurisdiction to have been wrongful, then in that case the termination is to be considered an early termination pursuant to the Early Termination Section above.

- E. **Turnover of Documents and Records:** Upon demand of the Board after termination of this Contract for any reason or the expiration of this Contract by its terms, Bidder shall turn over to the Board or its designee within five (5) days of demand, all materials, supplies, equipment owned or purchased by the Board, completed or partially completed work product or analyses, data, computer disks, documents and any other information relating in any way to this Contract, the delivery of Products and Services, except that Bidder may keep a copy of such information for its own records.

### **11. Confidential Information, Dissemination of Information, Ownership, Survival:**

- A. **Confidential Information:** In the performance of this Contract, Bidder may have access to or receive certain information that is not generally known to others including but not limited to, proprietary information, copyrighted material, business plans, financial information, educational records, student data, employee data, information relating to health records, and other information of a personal nature (collectively "**Confidential Information**"). Confidential Information may include confidential or proprietary information of third parties provided by Board to Bidder in the course of performance of the Contract. Confidential Information shall not include information that is: (i) or becomes part of the public domain through no fault of Bidder; (ii) made available to Bidder by an independent third party having the legal right to make such disclosure; and (iii) information that can be established and documented by Bidder to have been independently developed or obtained by Bidder without violating the confidentiality obligations of this Contract and any other agreements with the Board.

## II. GENERAL TERMS AND CONDITIONS

- B. Use of Confidential Information: Bidder shall use or disclose any Confidential Information or any finished or unfinished documents, screens, reports, writings, procedural manuals, forms, source code, object code, work flow charts, methods, processes, data, data studies, drawings, maps, files, records, computer printouts, designs, equipment descriptions, or other materials prepared or generated as a result of this Contract (collectively "**Work Product**") for the sole purpose of rendering Products and Services to the Board pursuant to the terms of this Contract. Bidder shall not disclose Confidential Information except to those of its officers, agents, employees, and subcontractors who have a need to access the Confidential Information to perform the obligations of this Contract. Bidder shall use at least a commercially reasonable standard of care in the protection of the Confidential Information of the Board, which shall be, at a minimum, with no less protection than Bidder uses to protect its own Confidential Information. Bidder understands that Confidential Information may be subject to the special requirements set forth in the Family Educational Rights and Privacy Act ("**FERPA**") and the Illinois School Student Records Act ("**ISSRA**").
- C. Dissemination of Information: Bidder shall not disseminate any Confidential Information to a third party without the prior written consent of the Board. In the event that Bidder is presented with a request for documents by any administrative agency or with a *subpoena duces tecum* regarding any Confidential Information or Work Product which may be in Bidder's possession, Bidder shall immediately give notice to the Board and its General Counsel with the understanding that the Board shall have the opportunity to contest such process by any means available to it prior to submission of any documents to a court or other third party. Bidder shall not be obligated to withhold delivery of documents beyond the time ordered by a court of law or administrative agency, unless the request for production or *subpoena* is quashed or withdrawn, or the time to produce is otherwise extended.
- D. Press Release: Publicity: Bidder shall not issue publicity news releases, grant press interviews, or use any Confidential Information or Board intellectual property, including but not limited to the CPS logos or the logos of any CPS schools, during or after the delivery of Products and Services without the prior written consent of the authorized representative of the Board. Furthermore, Bidder may not photograph or film or cause others to photograph or film within any CPS school or facility without the prior express written consent of the Chief Communications Officer or his/her designee.
- E. Ownership: The Board owns and retains ownership of all Confidential Information as between Bidder and the Board. Bidder agrees that, to the extent permitted by law, any and all Work Product shall exclusively be deemed "works for hire" within the meaning and purview of the United States Copyright Act, 17 U.S.C. § 101 *et seq.* To the extent any Work Product does not qualify as a "work for hire," Bidder irrevocably grants, assigns, and transfers to the Board all right, title, and interest in and to the Work Product in all media throughout the world in perpetuity and all intellectual property rights therein, free and clear of any liens, claims, or other encumbrances, to the fullest extent permitted by law. All intellectual property developed by, created for, or incorporating information, including Confidential Information, gained from or in the course of the performance of the Contract shall at all times be and remain the property of the Board. Bidder shall execute all documents and perform all acts that the Board may request in order to assist the Board in perfecting or protecting its rights in and to the Work Product and all intellectual property rights consistent with the terms set forth herein. All of the foregoing items shall be delivered to the Board upon demand at any time and in any event, shall be promptly delivered to the Board upon expiration or termination of this Contract within five (5) business days of demand. In addition, Bidder shall return the Board's data in the format requested by the Board. If any of the above items are lost or damaged while in Bidder's possession, such items shall be restored or replaced at Bidder's expense.

## II. GENERAL TERMS AND CONDITIONS

- F. Unauthorized Access, Use or Disclosure: If Bidder has knowledge of any unauthorized access, use and/or disclosure of Confidential Information, it shall: (i) notify the Board immediately, which in no event shall be longer than twenty-four (24) hours from Bidder receiving notice of the unauthorized access, use, or disclosure; (ii) take prompt and appropriate action to prevent further unauthorized access, use, or disclosure; (iii) cooperate with the Board and any government authorities with respect to the investigation and mitigation of any such unauthorized access, use, or disclosure, including if required under any federal or state law, providing notification to the affected persons. Bidder shall bear the losses and expenses (including attorneys' fees) associated with the breach of Confidential Information, including without limitation any costs: (1) of providing notices of a data breach, including without limitation, establishing call centers and providing credit monitoring or credit restoration services, as requested by the Board. Bidder shall include this provision in any and all agreements it executes with subcontractors providing Products and Services under this Contract.
- G. Return and/or Destruction of Confidential Information: Upon the expiration or termination of this Contract, Bidder shall promptly cease using and shall return or destroy (and certify in writing destruction of) all Confidential Information furnished by the Board along with all copies thereof in its possession including copies stored in any computer memory or storage medium.
- H. Employees, Agents, and Subcontractors: Bidder agrees to cause its employees, agents and subcontractors, if any, to undertake the same obligations of confidentiality and ownership agreed to herein by Bidder.
- I. Injunctive Relief: In the event of a breach or threatened breach of this Section, Bidder acknowledges and agrees that the Board would suffer irreparable injury not compensable by money damages and would not have an adequate remedy at law. Accordingly, Bidder agrees that the Board shall be entitled to immediate injunctive relief to prevent or curtail any such breach, threatened or actual. The foregoing shall be in addition to and without prejudice to such rights that the Board may have in equity, at law, or by statute.
- J. Survival: The provisions of this Section shall survive the termination or expiration of this Contract.
12. Representations and Warranties of Bidder: Bidder represents and warrants that the following shall be true and correct as of the effective date of this Contract and shall continue to be true and correct during the Term of this Contract and any Renewal Terms:
- A. Contractor's Disclosure Form: The disclosures in the Contractor's Disclosure Form submitted by Bidder to the Department of Procurement are true and correct. Bidder shall promptly notify the Board of any material change in information set forth therein, including but not limited to, change in ownership or control, and any such change shall be subject to Board approval which shall not be unreasonably withheld.
- B. Financially Solvent: Bidder warrants that it is financially solvent, is able to pay all debts as they mature and is possessed of sufficient working capital to deliver all Products and Services and perform all other obligations under this Contract.
- C. Compliance with Laws: Bidder is and shall remain in compliance with all applicable federal, state, county, and municipal statutes, laws, ordinances, and regulations relating to this Contract, the delivery of Products and Services in effect now or later and as amended from time to time, including but not limited to the Prevailing Wage Act, 820 ILCS 130/1 *et seq.*, the DrugFree Workplace Act, the Illinois School Student Records Act, the Family Educational

## **II. GENERAL TERMS AND CONDITIONS**

Rights and Privacy Act, the Protection of Pupil Rights Amendment and any others relating to nondiscrimination. Further, Bidder is and shall remain in compliance with all applicable Board policies and rules. Board policies and rules are available at <http://www.cps.edu/>.

- D. **Gratuities:** No payment, gratuity or offer of employment was made by Bidder, any of its members if a joint venture or, to the best of Bidder's knowledge after due inquiry, by any subcontractors, in relation to this Contract or as an inducement for award of this Contract. Bidder is and shall remain in compliance with all applicable anti-kickback laws and regulations throughout the Term of this Contract.
- E. **Ethics:** No officer, agent or employee of the Board is or shall be employed by Bidder or has or shall have a financial interest, directly or indirectly, in this Contract or the compensation to be paid hereunder except as may be permitted in writing by the Board's Code of Ethics adopted May 25, 2011 (11-0525-PO2), as may be amended at any time, which policy is hereby incorporated by reference into and made a part of this Contract as if fully set forth herein.
- F. **Good Standing:** Bidder, each of its joint venture members if a joint venture, and each of its subcontractors, if any, are not in default or have not been deemed by the Board's Chief Procurement Officer to be in default under any other contract with the Board during the five (5) year period immediately preceding the effective date of this Contract.
- G. **Authorization:** Bidder has taken all action necessary for the approval and execution of this Contract, and execution by the person signing on behalf of Bidder is duly authorized by Bidder and has been made with complete and full authority to commit Bidder to all terms and conditions of this Contract which shall constitute valid, binding obligations of Bidder.
- H. **Research Activities and Data Requests:** Bidder shall not conduct research in the Chicago Public Schools or use Confidential Information for research purposes. In the event that the Board seeks to conduct research in Chicago Public Schools or use Confidential Information for research purposes, Bidder shall comply with the Board's External Research Study and Data Policy adopted on December 11, 2019 as may be amended from time to time. Bidder may not begin any research activities or obtain data for research purposes without the prior written consent of the Chief Education Officer.
- I. **Intellectual Property:** In delivering Products and Services under this Contract, Bidder shall not violate or infringe upon any patent, copyright, trademark, trade secret, or other proprietary or intellectual property right of any third party and will not improperly use any third party's confidential or proprietary information. Bidder shall have, without encumbrance, all ownership, licenses, marketing, or other rights required to furnish all Products and Services that it provides to the Board under this Contract and can grant or assign all rights granted or assigned to the Board under this Contract.
- J. **Free of Computer Viruses:** Bidder shall use commercially reasonable best efforts to ensure that its Products and Services and any software, hardware, or other technology used in Bidder's delivery of its Products and Services is free of malicious code, malware, Trojan horses, ransomware, worms, and other computer viruses, particularly to the extent that it may interact with the Board's systems and network.
- K. **Prohibited Acts:** Within the three (3) years prior to the effective date of this Contract, Bidder or any of its members if a joint venture or a limited liability company, or any of its or their respective officers, directors, shareholders, members, managers, other officials, agents or employees: (i) have not been convicted of bribery or attempting to bribe a public officer or

## II. GENERAL TERMS AND CONDITIONS

employee of any public entity; and (ii) have not been convicted of agreeing or colluding among contractors or prospective contractors in restraint of trade, including bid-rigging or bid-rotating, as those terms are defined under the Illinois Criminal Code.

L. Debarment and Suspension: Bidder certifies to the best of its knowledge and belief, after due inquiry that:

- 1) Bidder, its principals, and its subcontractors providing Products and Services under this Contract are not barred from contracting with any unit of state or local government as a result of violation of either Section 33E-3 (bid-rigging) or 33E-4 (bid rotating) [720 ILCS 5/33E];
- 2) Bidder, its principals, and each of its subcontractors providing Products and Services under this Contract are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from participation in this transaction by any federal department or agency or any unit of state or local government; and
- 3) Bidder, its principals, and each of its subcontractors providing Products and Services under this Contract have not violated the rules, regulations, or laws of any federal, state, or local government unit or agency.

“Principals” for the purpose of this certification means officers, directors, owners, partners, persons having primary management or supervisory responsibilities within a business entity; and if a joint venture is involved, each joint venture member and the principals of each such member.

In performing any obligations of this Contract, Bidder shall not utilize any firms that have been debarred from doing business with the Board under the Board’s Debarment Policy (08-1217PO1), as amended.

M. Continued Disclosure Requirement: If at any time during the Term of the Contract or during any Renewal Terms, Bidder becomes aware of any change in the circumstances that makes the representations and warranties stated in this Contract no longer true, Bidder must immediately disclose such change to the Board in accordance with the Notice provisions of this Contract.

N. Survival: All warranties in this Section shall survive inspection, acceptance, payment, expiration or termination of this Contract. Nothing in the foregoing warranties shall be construed to limit any other rights or remedies available to the Board under the laws and this Contract.

13. Background Check. Bidder shall comply with the following requirements and such other procedures as may be determined necessary by the Board from time to time for each employee, agent, volunteer or subcontractor who may have contact with a CPS student as a result of this Contract (individually and collectively “**Staff**”) (“**Background Check**”). For purposes of this Section, contact via text messages, live chats, emails, any other digital or online media, telephone, in person, or through any other means shall be considered “contact”. Bidder shall not allow any Staff to have contact with students until Bidder has confirmed with the Board that each respective Staff has successfully completed the Background Check in accordance with the following requirements:

A. Do Not Hire List. The Board will perform a check of eligibility of each Staff who may have contact with a CPS student pursuant to this Contract by checking the Board’s “Do Not Hire” (“DNH”) records (“DNH Check”). The Board will utilize the same DNH Check process that the Board uses for its own prospective staff. Staff with a DNH designation shall not provide Products and Services hereunder.

## II. GENERAL TERMS AND CONDITIONS

- B. Criminal History Records Check. Bidder shall, at its own cost and expense, have a complete fingerprint-based criminal history records check conducted on each Staff who may have contact with a CPS student pursuant to this Contract through the process established by the Board, including using the Board's contracted vendor for conducting such checks, and otherwise in accordance with the Illinois School Code (105 ILCS 5/34-18.5), which refers to and incorporates the Sex Offender and Child Murderer Community Notification Law (730 ILCS 152/101 et seq.), and the Murderer and Violent Offender Against Youth Registration Act (730 ILCS 154/1 et seq.) (collectively "**Criminal History Records Check**"). A complete Criminal History Records Check includes the following:

- 1) Fingerprint-based checks through the Illinois State Police and the Federal Bureau of Investigation;
- 2) A check of the Illinois Sex Offender Registry and the Nationwide Sex Offender Registry; and
- 3) A check of the Illinois State Police Murderer and Violent Offender Against Youth Registry.

The results of each Criminal History Records Check shall be adjudicated by the Board. Staff shall not have contact with CPS students prior to successfully completing the Criminal History Records Check. When the Board determines that any Staff has not passed a Criminal History Records Check, such Staff shall not access any Board facility and shall not have contact with any CPS student hereunder.

- C. Department of Children and Family Services Check. At Bidder's cost and expense, the Board shall have the right to check Staff who may have contact with a CPS student pursuant to this Contract for indicated reports of child abuse and/or neglect with the Illinois Department of Children and Family Services ("**DCFS**") State Automated Child Welfare Information System (or a comparable determination of child abuse or neglect by a government agency in another jurisdiction) for each Staff ("**DCFS Check**"). Bidder shall follow the directives and processes of the Board for initiating any DCFS Check, and the results of each DCFS Check shall be adjudicated by the Board. Staff determined by the Board not to have passed a DCFS Check shall not access any Board facility and shall not have contact with any CPS student hereunder.

- D. Background Check Representations and Warranties: With respect to each Background Check, Bidder further represents and warrants that Bidder shall:

- 1) Utilize the process established by the Board for completing each Background Check and immediately initiate all action, as directed by the Board, to have such Background Check performed;
- 2) Obtain from each of its prospective and current Staff and provide to the Board a Signed; copy of any release and consent required to conduct the Background Check in the form determined by, and as directed by the Board
- 3) Confirm with the Board's Chief of Safety and Security that each respective Staff has successfully completed the Background Check through the process established by the Board and complied with the Board's directives regarding the results of each Background Check before any contact with a CPS student may occur;
- 4) When contact with a CPS student may occur, not allow any Staff to provide Products and Services until a DNH Check, Criminal History Records Check, and DCFS Check have been completed by the Board and the results of the Background Check satisfy for the Board, at a minimum, the requirements of 105 ILCS 5/34-18.5 and the requirements of all other Acts and Laws referenced in this Section, as may be amended;

## II. GENERAL TERMS AND CONDITIONS

- 5) Comply with and require compliance of all Staff with directives from the Board relating to any updates to any Background Check (which updates shall be received and adjudicated by the Board) and provide any other information requested by the Board necessary for the performance of the Background Check and its update process; and
- 6) Immediately remove from any contact with any CPS student pursuant to this Contract and otherwise terminate access for any Staff determined by the Board not to have passed a Background Check or update for any matters arising after an initial Background Check.

- E. Allocation of Costs and Liquidated Damages. Bidder is obligated to cause the Background Check to be performed for all Staff who may have contact with any CPS student pursuant to this Contract, and Bidder shall be responsible for the costs of such Background Check. Whether or not Bidder allocates the costs to its subcontractors shall not affect Bidder's obligations in this Section.

If Bidder fails to comply with this Section, in whole or in part, then, in addition to the Remedies set forth in this Contract, the Board may exercise additional remedies, including but not limited to: (i) withholding payments due under this Contract, and any other agreement Bidder may have or enter into with the Board until Bidder remedies such non-compliance to the Board's reasonable satisfaction; (ii) immediately terminating this Contract without any further obligation by the Board of any kind (other than payment for Products and Services previously rendered pursuant to the terms herein); (iii) seeking liquidated damages; (iv) or taking any other action or remedy available under this Contract or by law.

Liquidated damages shall be calculated as \$5,000.00 per breach of this Section, which, for purposes of clarity, for the aggregate calculation of liquidated damages, will include each instance of contact with CPS students by Staff as a separate breach. It is understood and agreed that Bidder's non-compliance with this Section shall constitute a material breach of this Contract.

14. **Independent Contractor:** It is understood and agreed that the relationship of Bidder to the Board is and shall continue to be that of an independent contractor and neither Bidder nor any of Bidder's staff, agents, employees or subcontractors shall be entitled to receive Board employee benefits. Bidder is the common law employer of the individuals who deliver Products and Services to the Board pursuant to this Contract. It is further understood and agreed that the Board shall not be responsible for, nor incur any liability for, any State or Federal withholding or other taxes or for FICA or State unemployment insurance for Bidder, its agents, employees or subcontractors, and the payment of any such taxes incurred or due by Bidder shall be the sole responsibility of Bidder. To the extent that Bidder is subject to taxes under Section 4980H of the Internal Revenue Code, Bidder shall be solely responsible for paying such taxes. Bidder agrees that neither Bidder nor its staff or subcontractors shall represent themselves as employees or agents of the Board. Bidder shall provide the Board with a valid taxpayer identification number as defined by the United States Internal Revenue Code, including, but not limited to, a social security number or a federal employer identification number.
15. **Indemnification:** Bidder agrees to defend, indemnify and hold harmless the Board, its members, employees, agents, officers and officials from and against liabilities, losses, penalties, damages and expenses, including costs and attorney fees, arising out of all claims, liens, damages, obligations, actions, suits, judgments or settlements, or causes of action, of every kind, nature and character (collectively "**Claims**") arising or alleged to arise out of the acts or omissions of Bidder, its officers, agents, employees and subcontractors in the performance of this Contract. The foregoing obligation extends to and is intended to encompass any and all Claims that the Products



## II. GENERAL TERMS AND CONDITIONS

and Services infringe, misappropriate or otherwise violate any confidentiality, proprietary or intellectual property rights of a third party.

Furthermore, in the event that the Board is determined to be liable for taxes under Section 4980H of the Internal Revenue Code as a result of its use of Bidder's employees under this Contract, Bidder shall indemnify the Board for any such liability. And, in the event of unauthorized access, use or disclosure of the Board's Confidential Information arising or alleged to arise from the acts or omissions of Bidder, its employees, agents, and subcontractors, in addition to the obligations provided in this Section, Bidder shall cover any costs or fees associated with: (i) providing notices of a data breach to effected persons and to regulatory bodies; and (ii) remedying and otherwise mitigating any potential damages or harm from the data breach, including but not limited to call centers and providing credit monitoring and credit restoration services as may be requested by the Board.

Bidder shall, at its own cost and expense, appear, defend and pay all attorney fees and, other costs and expenses arising hereunder. In addition, if any judgment shall be rendered against the Board in any such action, Bidder shall, at its own expense, satisfy and discharge such obligation of the Board. The Board shall have the right, at its own expense, to participate in the defense of any suit, without relieving Bidder of any of its obligations hereunder. The Board retains final approval of any and all settlements or legal strategies which involve the interest of the Board.

However, if Bidder, after receiving notice of any such proceeding, fails to immediately begin the defense of such claim or action, the Board may (without further notice to Bidder) retain counsel and undertake the defense, compromise, or settlement of such claim or action at the expense of Bidder, subject to the right of Bidder to assume the defense of such claim or action at any time prior to settlement, compromise or final determination thereof. The cost and expense of counsel retained by the Board in these circumstances shall be borne by Bidder and Bidder shall be bound by, and shall pay the amount of, any settlement, compromise, final determination or judgment reached while the Board was represented by counsel retained by the Board pursuant to this paragraph, or while Bidder was conducting the defense.

To the extent permissible by law, Bidder waives any limits to the amount of its obligations to defend, indemnify, hold harmless, or contribute to any sums due under any losses, including any claim by any employee of Bidder that may be subject to the Workers Compensation Act, 820 ILCS 305/1 *et seq.* or any other related law or judicial decision (such as *Kotecki v. Cyclops Welding Corporation*, 146 Ill. 2d 155 (1991)). The Board, however, does not waive any limitations it may have on its liability under the Illinois Workers Compensation Act, the Illinois Pension Code, any other statute or judicial decision.

The indemnities set forth herein shall survive the expiration or termination of this Contract.

16. **Non-Liability of Board Officials:** Bidder agrees that no Board member, employee, agent, officer and/or official shall be personally charged and/or held personally liable by Bidder, its members if a joint venture, and/or any subcontractors with any liability or expense under this Contract.
17. **Insurance:** Bidder, at its own expense, shall procure and maintain insurance covering all operations under this Contract, whether performed by Bidder or by subcontractors. All insurers shall be licensed by the State of Illinois and rated A-VII or better by A.M. Best or a comparable rating service. Bidder shall submit to the Board satisfactory evidence of insurance coverage **prior** to commencement of Product delivery under this Contract. Minimum insurance requirements include the coverage set forth below:

## II. GENERAL TERMS AND CONDITIONS

- A. Workers' Compensation and Employers' Liability Insurance: Workers' Compensation Insurance affording workers' compensation benefits for all employees as required by law and Employers' Liability Insurance covering all employees who are to provide Products and Services under the Contract with limits of not less than One Million Dollars (\$1,000,000.00) per occurrence. The workers' compensation policy must contain a waiver of subrogation clause.
- B. Commercial General Liability Insurance: Commercial General Liability Insurance or equivalent with limits of not less than One Million Dollars (\$1,000,000.00) per occurrence, and Two Million Dollars (\$2,000,000.00) in the aggregate for bodily injury, personal injury and property damage liability. Coverage shall be including but not be limited to, all operations, contractual liability, independent contractors, products/completed operations (for a minimum of two (2) years following completion), and defense. General liability insurance may not exclude coverage for sexual abuse and/or molestation.
- C. Automobile Liability Insurance: Automobile Liability Insurance when any motor vehicle (whether owned, non-owned or hired) is used in connection with this Contract, with limits of not less than One Million Dollars (\$1,000,000.00) per occurrence for bodily injury and property damage.
- D. Umbrella/Excess Liability Insurance: Umbrella or Excess Liability Insurance with limits of not less than Four Million Dollars (\$4,000,000.00) per occurrence, which will provide additional limits for general liability and auto insurance subject to that of the primary coverage stated above. Subcontractors performing work for the Bidder are not required to provide this coverage.
- E. Professional Liability/Errors and Omissions: When any architects, engineers, construction managers or other professional consultants perform work in connection with this Contract, Professional Liability Insurance covering acts, errors, or omissions must be maintained with limits of not less than One Million Dollars (\$1,000,000.00) each claim and Two Million Dollars (\$2,000,000.00) in the aggregate. Coverage must include contractual liability. When policies are renewed or replaced, the policy retroactive date must coincide with, or precede, start of work under this Contract. If coverage is on a "claims made" basis, a two (2) year extended reporting provision must be included.
- F. Sexual Abuse & Molestation: Sexual Abuse & Molestation Insurance with limits of not less than One Million and 00/100 Dollars (\$1,000,000.00) per occurrence and Two Million and 00/100 Dollars (\$2,000,000.00) in the aggregate, or as otherwise determined by the Board's Risk Management Department. If coverage is claims-made, the policy shall have a retroactive date effective upon the Effective Date of the Contract and have an extended reporting period of not less than two (2) years following completion of the Contract. Any retroactive date or prior acts exclusion must predate both the Effective Date of this Contract and any earlier commencement of Services. Notwithstanding the provisions of this Subparagraph 1.e. hereinabove, if the Commercial General Liability coverage and the Umbrella coverage both include coverage for Sexual Abuse and Molestation (and do not exclude or limit such coverage), then the requirements of this Subparagraph 1.e. may not apply, as determined by the Board's Risk Management Department.
- G. Contractors Pollution Liability: When any Work is performed which may cause a pollution exposure, Contractors Pollution Liability must be provided covering bodily injury, property damage and other losses caused by pollution conditions that arise from the Work with limits of not less than Two Million Dollars (\$2,000,000.00) per occurrence. When policies are renewed or replaced, the policy retroactive date must coincide with or precede, start of

## **II. GENERAL TERMS AND CONDITIONS**

Work under this Agreement. A claims-made policy, which is not renewed or replaced, must have an extended reporting period of two (2) years. The Board of Education of the City of Chicago is to be named as additional insured on a primary, non-contributory basis.

- H. Additional Insured: Bidder shall have its General and Automobile Liability Insurance policies endorsed to provide that “the Board of Education of the City of Chicago, a body politic and corporate, and its members, employees and agents, and any other entity as may be designated by the Board are named as additional insured on a primary basis without recourse or right of contribution from the Board”.

The insurance company, or its representative, shall submit an insurance certificate evidencing all coverage as required hereunder and indicating the Additional Insured status as required above. The Board reserves the right to withhold payment under this Contract pending receipt of satisfactory proof of insurance meeting the requirements set forth herein. The Certificate must provide thirty (30) days prior written notice of material change, cancellation, or non-renewal be given to:

Risk Management  
Board of Education of the City of Chicago  
42 West Madison Ave., 2<sup>nd</sup> Floor  
Chicago, Illinois 60602  
[riskmanagement@cps.edu](mailto:riskmanagement@cps.edu)

Copy to:  
Board of Education of the City of Chicago  
Department of Procurement  
42 West Madison Ave., 9<sup>th</sup> Floor  
Chicago, Illinois 60602  
ATTN: Keisha Saintil– [ksaintil@cps.edu](mailto:ksaintil@cps.edu)

Any failure of the Board to demand or receive proof of insurance coverage shall not constitute a waiver of Bidder's obligation to obtain the required insurance. The receipt of any certificate does not constitute agreement by the Board that the insurance requirements in this Contract have been fully met or that the insurance policies indicated on the certificate are in compliance with all contract requirements. Bidder's failure to carry or document required insurance shall constitute a breach of Bidder's Contract with the Board. In the event Bidder fails to fulfill the insurance requirements of this Contract, the Board reserves the right to stop all work until proper evidence of insurance is provided, or this Contract may be terminated.

Any deductibles or self-insured retentions on referenced insurance coverage must be borne by Bidder. Any insurance or self-insurance programs maintained by the Board of Education do not contribute with insurance provided by Bidder and subcontractors under this Contract. All Bidder and subcontractor insurance are considered by the parties to this Contract to be primary and collectible above all other coverage, including but not limited to, the Board's insurance and self-insurance.

All subcontractors are subject to the same insurance requirements of Bidder unless otherwise specified in this Contract. Bidder shall require any subcontractors under this Contract to maintain comparable insurance naming Bidder, the Board inclusive of its members, employees and agents, and any other entity designated by the Board, as Additional Insureds. Bidder will maintain a file of subcontractor's insurance certificates evidencing compliance with these requirements.

The coverages and limits furnished by Bidder in no way limit Bidder's liabilities and responsibilities specified within this Contract or by law. The required insurance is not limited by any limitations expressed in the indemnification language in this Contract, if any, or any limitation that might be placed on the indemnity in

## **II. GENERAL TERMS AND CONDITIONS**

this Contract given as a matter of law. Bidder agrees that insurers waive their rights of subrogation against the Board.

Winning Bidder(s) must register with the insurance certificate monitoring company designated by the Board (see below), and must maintain a current insurance certificate on file during the entire Term of the Contract. Winning Bidder(s) must register and pay the initial annual monitoring fee to the insurance certificate monitoring company prior to delivering Products and Services for the Board. The initial annual monitoring fee is currently Twelve Dollars (\$12.00) per year, but the fee may be subject to change.

**Each year, Board-approved, registered vendors will be notified 30 to 45 days prior to the expiration date of their required insurance coverage (highlighted on their latest submitted insurance certificate on file) in order to submit an updated insurance certificate with the insurance certificate monitoring company. Insurance certificate submissions and related annual fees are required to be made online at the dedicated website established by the certificate monitoring company (see URL below). Should you have any questions on submissions and payment options, you can contact the certificate monitoring company.**

**Certificate Monitoring Company:**

Topiary Communications Inc.

211 W. Wacker Drive, Suite 220

Chicago, IL 60606

Phone: (312) 494-5709

Email: [dans@topiarycomm.net](mailto:dans@topiarycomm.net)

URL: <http://www.cpsvendorcert.com>

**(designated website for online registration,  
insurance certificate submissions and annual fee payments)**

18. **Non-Discrimination:** It shall be an unlawful employment practice for Bidder or any of its subcontractors to fail or refuse to hire or to discharge any individual, or otherwise to discriminate against any individual with respect to compensation, or other terms, conditions, or privileges of employment, because of such individual's race, color, national origin, religion, sex, gender identity/expression, sexual orientation, age or disability; or to limit, segregate, or classify employees or applicants for employment in any way that would deprive or tend to deprive any individual from equal employment opportunities or otherwise adversely affect an individual's status as an employee because of such individual's race, color, national origin, religion, sex, gender identity/expression, sexual orientation, age or disability. Bidder shall particularly remain in compliance at all times with: the Civil Rights Act of 1964, 42 U.S.C.A. § 2000a, *et seq.*; the Age Discrimination in Employment Act, 29 U.S.C.A. § 621, *et seq.*; Section 504 of the Rehabilitation Act of 1973, 29 U.S.C.A. § 701, *et seq.*; the Americans with Disabilities Act, 42 U.S.C.A. § 12101, *et seq.*; the Illinois Human Rights Act, 775 ILCS 5/1-101, *et seq.*; the Illinois School Code, 105 ILCS 5/1-1 *et seq.*; the Illinois Public Works Employment Discrimination Act, 775 ILCS 10/0.01 *et seq.*; the Individuals with Disabilities Education Act (IDEA) 20 U.S.C.A. § 1400 *et seq.*; and the Chicago Human Rights Ordinance, Ch. 2-160 of the Municipal Code of Chicago, all as amended, and all other applicable federal, state, and municipal statutes, regulations, ordinances and other laws. Nothing in this paragraph is intended nor shall be construed to create a private right of action against the Board or any of its employees. Furthermore, no part of this paragraph shall be construed to create contractual or other rights or expectations for Bidder's employees or Bidder's subcontractors' employees.
19. **Assignment:** This Contract shall be binding on the parties and their respective successors and assigns; provided, however, Bidder may not assign this Contract or any obligations imposed hereunder without the prior written consent of the Board.

## **II. GENERAL TERMS AND CONDITIONS**

20. **Entirety of Contract and Amendments:** This Contract, including all attachments and addenda, constitutes the entire agreement of the parties with respect to the matters contained herein. No modification of or amendment to this Contract shall be effective unless such modification or amendment is in writing and signed by the authorized representatives of both parties. Any prior agreements or representations, either written or oral, relating to the subject matter of this Contract is of no force or effect. The Board shall not be bound by any terms and conditions in any packaging, service catalogue, brochure, technical data sheet or other document which attempts to impose any conditions that waive, abridge, or abrogate the terms and conditions contained in this bid solicitation or Contract, or the Board's contractual rights as provided under state or federal law. In the event of a conflict between the terms of this Contract and any other document, the terms of this Contract shall supersede and prevail.
21. **Continuing Obligation To Perform:** In the event of any dispute between Bidder and the Board, Bidder shall expeditiously and diligently proceed with the performance of all of its obligations under this Contract with a reservation of all rights and remedies it may have under or pursuant to this Contract at law or in equity.
22. **Survival/Severability:** All express representations or indemnifications made or given in this Contract shall survive the expiration or termination of this Contract for any reason. If any provision or part of this Contract is held to be unenforceable, this Contract shall be considered divisible and such provision shall be deemed inoperative to the extent it is deemed unenforceable, and in all other respects this Contract shall remain in full force and effect; provided, however, that if any such provision may be made enforceable by limitation thereof, then such provision shall be deemed to be so limited and shall be enforceable to the maximum extent permitted by applicable law.
23. **Governing Law:** This Contract shall be governed by and construed in accordance with the laws of the State of Illinois without regard to any conflict of law or choice of law principles. Bidder irrevocably submits itself to the original jurisdiction of those courts located in the County of Cook, State of Illinois, with regard to any controversy arising out, or relating to, or in any way concerning the execution or performance of this Contract. Bidder agrees that service of process on Bidder may be made, at the option of the Board, by either registered or certified mail to the address specified on Section VIII: Bid Execution Page, by registered or certified mail addressed to the office actually maintained by Bidder, or by personal delivery on any officer, director, or managing or general agent of Bidder. If any action is brought by Bidder against the Board concerning this Contract, the action shall only be brought in those courts located within the County of Cook, State of Illinois.
24. **Freedom of Information Act:** Bidder acknowledges that this Contract and all documents submitted to the Board related to this contract award are a matter of public record and are subject to the Illinois Freedom of Information Act (5 ILCS 140/1) and any other comparable state and federal laws and that this Contract is subject to reporting requirements under 105 ILCS 5/10-20.44. Bidder further acknowledges that this Contract shall be posted on the Board's Internet website.
25. **Waiver:** No delay or omission, or series of delays or omissions, by the Board to exercise any right hereunder shall be construed as any type of waiver of any such right, and the Board reserves the right to exercise any such right from time to time as often as may be deemed expedient.
26. **Conflict of Interest:** This Contract is not legally binding on the Board if entered into in violation of the provisions of 105 ILCS 5/34-21.3 which restricts the employment of, or the letting of contracts to, former Board members during the one (1) year period following expiration or other termination of their terms of office.

## II. GENERAL TERMS AND CONDITIONS

27. **Indebtedness:** Bidder agrees to comply with the Board's Indebtedness Policy adopted June 26, 1996 (96-0626-PO3), as may be amended from time to time, which policy is hereby incorporated by reference as if fully set forth herein.
28. **Inspector General:** Each party to this Contract hereby acknowledges that in accordance with 105 ILCS 5/34-13.1, the Inspector General of the Chicago Board of Education has the authority to conduct certain investigations and that the Inspector General shall have access to all information and personnel necessary to conduct those investigations.
29. **Right of Entry:** Bidder and any of its employees, agents, or subcontractors delivering Products and Services shall be permitted to enter upon a school site or other Board property in connection with the delivery of Products and Services hereunder, subject to the terms and conditions contained herein and those rules established by the Board. Bidder shall provide advance notice to the Board whenever applicable, of any such intended entry. Consent to enter upon a school site or other Board property given by the Board shall not create, nor be deemed to imply, the creation of any additional responsibilities on the part of the Board. Bidder shall use, and shall cause each of its employees, agents, and subcontractors to use, the highest degree of care when entering upon any property owned by the Board in connection with the delivery of Products and Services. In the case of any property owned by the Board or leased from the Board, Bidder shall comply and shall cause each of its employees, agents, and subcontractors, to comply with any and all instructions and requirements of Board or authorized Board representative for the use of such property. Any and all claims, suits or judgments, costs, or expenses, including but not limited to, reasonable attorney's fees, arising from, by reason of, or in connection with any such entries shall be treated in accordance with the applicable terms and conditions of this bid including without limitation the indemnification provisions contained in this Contract.
30. **Joint and Several Liability:** In the event that Bidder, or its successors or assigns, if any, is comprised of more than one legal entity then, and in that event, each and every obligation or undertaking herein stated to be fulfilled or performed by Bidder shall be the joint and several obligation or undertaking of each such legal entity.
31. **Board Not Subject to Taxes:** The federal excise tax does not apply to the Board, and the State of Illinois sales tax does not apply to the Board by virtue of Exemption No. E9997-7109-06. The compensation set in the Bid Tabulation Page is inclusive of all other taxes that may be levied or based on this Contract, including but not limited to sales, use, nonresident, value-added, excise, and similar taxes levied or imposed on the Products and Services to be provided under this Contract, but excluding taxes levied or imposed on the income or business privileges of Bidder. Bidder shall be responsible for any taxes levied or imposed upon the income or business privileges of Bidder.
32. **MBE/WBE Program:** Bidder acknowledges that it is familiar with the requirements of the Board's "*Remedial Program for Minority and Women-Owned Business Enterprise Participation in Goods and Services Contracts*" ("**Remedial Plan**"), which is available on the Board's website at <http://www.csc.cps.k12.il.us/purchasing/mwbe.html> and is incorporated as if fully set forth herein. Bidder agrees to adhere to the minimum participation goals and to all other applicable MBE/WBE requirements as set forth in the program. Bidder agrees to submit such documentation in connection with the program as may be requested by the Board.

Bidder and its subcontractors shall provide all required compliance data with respect to the Remedial Plan via the Board's electronic system available at <http://cps.diversitycompliance.com>. Bidder and its subcontractors shall be responsible for responding to any requests for data or information by the noted response due dates, and shall check the electronic system on a regular basis to manage contact information and contract records. Bidder shall also be responsible for

## II. GENERAL TERMS AND CONDITIONS

ensuring that all subcontractors have completed all requested items with complete and accurate information and that their contact information is current.

33. **Minimum Wage** Bidder must comply with the City of Chicago Minimum Wage Ordinance (01-24), as may be amended, and the Board's Minimum Wage Resolution (14-1217-RS2) and any applicable regulations issued by the Board's CPO. The Board's resolution adopts Chicago Mayoral Executive Order 2014-1. A copy of the Mayoral Order may be downloaded from the Chicago City Clerk's website at: <https://www.chicityclerk.com/legislation-records/journals-and-reports/executive-orders>; the Board's Resolution may be downloaded from the Chicago Public School's website at: [http://www.cpsboe.org/content/actions/2014\\_12/14-1217-RS2.pdf](http://www.cpsboe.org/content/actions/2014_12/14-1217-RS2.pdf). In the event of any discrepancy between the summary below and the Resolution and Order, the Resolution and Order shall control.

Bidder must: (i) pay its employees no less than the minimum wage in accordance with the Resolution and Order ("Minimum Wage") for work performed under the Contract; and (ii) require any subcontractors, sublicensees, or subtenants, to pay their employees no less than the Minimum Wage for work performed under the Contract.

The Minimum Wage must be paid to: (i) All employees regularly performing work on property owned or controlled by the Board or at a Board jobsite; and (ii) All employees whose regular work entails performing a service for the Board under a Board contract.

Beginning on July 1, 2015, and every July 1 thereafter, the Minimum Wage shall increase in proportion to the increase, if any, in the Consumer Price Index for All Urban Consumers most recently published by the Bureau of Labor Statistics of the United States Department of Labor, and shall remain in effect until any subsequent adjustment is made. On or before June 1, 2015, and on or before every June 1 thereafter, the City of Chicago may issue bulletins announcing adjustments to the Minimum Wage for the upcoming year.

The Minimum Wage is not required to be paid to employees whose work is performed in general support of Bidder's operations, does not directly relate to the Services provided to the Board under the Contract, and is included in the contract price as overhead, unless that employee's regularly assigned work location is on property owned or controlled by the Board. It is also not required to be paid by employers that are 501(c) (3) not-for-profits.

The term 'employee' as used herein does not include persons subject to subsection 4(a)(2), subsection 4(a)(3), subsection 4(d), subsection 4(e), or Section 6 of the Illinois Minimum Wage Law, 820 ILCS 105/1 et seq., in force as of the date of the Contract or as amended. Nevertheless, the Minimum Wage is required to be paid to those workers described in subsections 4(a) (2) (A) and 4(a)(2)(B) of the Illinois Minimum Wage Law.

The Minimum Wage is not required to be paid to employees subject to a collective bargaining agreement that provides for different wages than those required by the Board's Resolution, if that collective bargaining agreement was in force prior to December 17, 2014 or if that collective bargaining agreement clearly and specifically waives the requirements of the Resolution.

If the payment of a prevailing wage is required and the prevailing wage is higher than the Minimum Wage, then Bidder must pay the prevailing wage.

34. **Notices:** All notices required under this Contract shall be in writing and sent to: (i) Bidder at the address and to the person set forth on the Bid Execution Page or to such other addresses or person as may be designated by Bidder in writing; and (ii) to the Board at the addresses set forth below. Any notice involving non-performance or termination shall be sent by hand delivery or recognized

**II. GENERAL TERMS AND CONDITIONS**

overnight courier. All notices shall be deemed to have been given when received, if hand delivered; upon confirmation of delivery, if sent by recognized overnight courier; and after three (3) business days if mailed. Refusal to accept delivery has the same effect as receipt.

**IF TO THE BOARD:**

Chief Procurement Officer  
Board of Education of the City of Chicago  
Department of Procurement 42  
W. Madison Ave., 9<sup>th</sup> Floor  
Chicago, Illinois 60602

Copy to:

General Counsel  
Board of Education of the City of Chicago - Law Department  
One North Dearborn Street, Suite 900  
Chicago, Illinois 60602

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**



### **III. SPECIFIC TERMS AND CONDITIONS**

1. **Authority:** Bidder understands and agrees that Bidder is not an authorized representative of the Board or the Chicago Public Schools. All agreements and approvals (written or verbal) of the Board or the Chicago Public Schools must be made by authorized Board employee(s).
2. **Review of Acceptance:** Bidder shall not commence the delivery of Products and Services and the Board shall not be liable for any costs incurred by Bidder, without a Contract executed by the Board.
3. **Account Management:** Bidder must provide a single point-of-contact (Account Manager) who is assigned to oversee and manage the day-to-day activities of this relationship with the Board as well as overall management of the customer service issues and reporting. The awarded Bidder shall also be required to have periodic meetings with the Department of Procurement personnel for regular contract review meetings as well as an annual business review at a time determined by the Department of Procurement. Bidder must also provide management reporting related to the Board's spending with the Bidder including, but not limited to, summary reports on spending trends and on expenditures of Products and Services from the Bidder by category on a quarterly basis.
4. **Principals and Authorized Personnel Right to Direct:** The principals and authorized personnel of the Board ("**Users**") shall have the authority, to the maximum extent possible, to direct Bidder and its subcontractors when delivering Products and Services on Board property.
5. **Warranties of Products and Services:** Bidder hereby represents and warrants that its Products and Services will be delivered in a manner consistent with the standards of the applicable industry or profession. Bidder warrants that its Products and Services will be delivered in a manner that does not damage the property of the Board. Bidder also warrants that the deliverables submitted to the Board for acceptance will conform to the Scope of Products and Services and will be free of errors or defects in design, material and workmanship. Bidder shall be required to re-perform, at no additional cost to the Board, any Products and Services that are deemed inadequate or otherwise unacceptable. Bidder's warranty for any Products and Services delivered shall be for a minimum of sixty (60) days from the date of CPS's acceptance.
6. **Program Monitoring and Evaluation:** In order for the Board to monitor and evaluate Bidder's performance throughout the Term of the Contract, all awarded Bidders must work closely with the Board to create project-specific measurements and reports. Bidder shall provide reports in intervals and in formats determined by the Department of Procurement, which shall include, but not be limited to, the Products and Services being provided under the Contract. This report must include: the date of Product delivery, Purchase Order ("**P.O.**") number, total P.O. amount, school/department name and an itemized list of Products and Services purchased. Bidder will submit reports to the Department Facilities and the Department of Procurement.
7. **Participation by Other Local Government Agencies:** Other local government agencies ("**Local Government Agencies**") may be eligible to purchase Products and Services pursuant to the terms and conditions of this Contract if such agencies are authorized, by law or their governing bodies, to execute such purchases, and if such authorization is allowed by the Board of Education's Chief Procurement Officer, and if such purchases have no significant net adverse effect on the Board and result in no observed diminished ability on Bidder to deliver the Products and Services to the Board or Board's user departments pursuant to such purchases. Local Government Agencies shall include without limitation: City of Chicago, Chicago Park District, City Colleges of Chicago, Chicago Transit Authority, Chicago Housing Authority, Chicago Board of Elections, Metropolitan Pier & Exposition Authority (McCormick Place, Navy Pier), and the Municipal Courts. All purchases and payment transactions shall be made directly between Bidder and the requesting Local Government Agency; the Board shall not be responsible for payment of any amounts owed by any Local

### III. SPECIFIC TERMS AND CONDITIONS

Government Agency to Bidder. The Board assumes no authority, liability or obligation on behalf of any Local Government Agency.

8. **Charter School Participation:** Charter schools which receive funding from the Board shall be eligible to purchase Products and Services pursuant to the terms and conditions of this Contract and, if such charter schools are authorized by their governing bodies to execute such purchases, by issuing their own purchase order(s) to Bidder. The Board shall not be responsible for payment of any amounts owed by charter schools. The Board assumes no authority, liability or obligation on behalf of any charter school.
  
9. **Additional Copies of Invoices:** In addition to the requirements in Section II, Section 4, Bidder shall submit a duplicate copy of invoices electronically via email to the Department Facilities at [fombilling@cps.edu](mailto:fombilling@cps.edu) to apply against the Contract.
  
10. **Prevailing Wages:** If in performance of the Contract, there is any underpayment of wages or salaries by Bidder, the Board may withhold from Bidder, out of payments due it, an amount sufficient to pay employees underpaid the difference between salaries required to be paid and salaries actually paid for the total number of hours worked. The amounts withheld from Bidder shall be disbursed by the Board to the respective employees to whom they are due. In the event the Board is required to withhold and disburse said amounts of underpaid salaries to employees of Bidder, the Board shall also withhold a sum equal to the Board's cost to administer the payment of said balances of salaries due.
  
11. **Recycling Waste and Energy Conservation:** Bidder shall give preference to the use of recycled products in the delivery of any Products and Services in accordance with applicable Environmental Protection Agency guidelines as promulgated in 40 CFR Parts 247-254. Bidder shall, to the extent feasible, mulch and compost all landscaping waste and shall comply with any applicable requirements of City ordinances. In addition, Bidder shall comply with any applicable mandatory standards and policies relating to energy efficiency under the State of Illinois Energy Conservation Plan issued in compliance with the Energy Policy and Conservation Act, 42 U.S.C. Section 6321 et seq. In particular, Bidder shall give preference to energy efficient and low-emission equipment, vehicles and fuel.
  
12. **Multi-Project Labor Agreement:** The Board has entered into a Multi-Project Labor Agreement ("MPLA") with various trade unions regarding construction projects. A copy of the MPLA is available on the Board's website at: [http://www.csc.cps.k12.il.us/purchasing/documents/MultiProject\\_Labor\\_Agreement.pdf](http://www.csc.cps.k12.il.us/purchasing/documents/MultiProject_Labor_Agreement.pdf) and [http://cps.edu/SiteCollectionDocuments/Multi\\_ProjectLaborSupplementalAgreement2015\\_2025.pdf](http://cps.edu/SiteCollectionDocuments/Multi_ProjectLaborSupplementalAgreement2015_2025.pdf). If applicable, Bidder acknowledges familiarity with the requirements of the MPLA, its applicability to certain Products and Services delivered by Bidder, and shall comply in all respects.
  
13. **Work Order Response Time:** Unless otherwise specified in the Scope of Services, Bidder shall comply with the following dispatch and resolution schedule for work order repairs:
  1. Vital Emergency Repair
    - a. "Vital Emergency Repair" is an emergency repair to remediate an imminent life threatening situation for students, staff or the public at a Board facility.
    - b. Dispatch Time: Within two (2) hours.
    - c. Issue Resolved: Within eight (8) hours.

### **III. SPECIFIC TERMS AND CONDITIONS**

2. Urgent Repair
  - a. "**Urgent Repair**" is a repair necessary to remediate a situation that threatens the functionality, security, safety or health of students, staff or public at the Board Facility.
  - b. Dispatch Time: Within eight (8) hours.
  - c. Issue Resolved: Within Twenty-four (24) hours.
  
3. Routine Repairs
  - a. "**Routine Repair**" is a repair necessary to maintain the school in a secure, safe, functional and aesthetically adequate manner. A Routine Repair does not present an immediate danger to students, staff or public at the Board Facility and can be performed during normal school hours.
  - b. Dispatch Time: Within Twenty-four (24) hours.
  - c. Issue Resolved: Within 5 business days, or as agreed with the Board's Facilities Operations Chief or designee.
  
4. Scheduled Repairs
  - a. "**Scheduled Repair**" is a repair that needs to be postponed due to the disruptive nature of the repair. A Scheduled Repair may be performed during scheduled school break periods.
  - b. Dispatch Time: As scheduled.
  - c. Issue Resolved: As agreed upon by the Board's Facilities Operations Chief or designee.

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**

## **IV. SCOPE OF PRODUCTS AND SERVICES**

### **Introduction**

The CPS Department of Facilities is seeking proposals from qualified organizations for water treatment Services to maintain a high quality chemical treatment and service program to meet our goals to sustain peak operating efficiencies and optimum corrosion prevention in the heating and cooling systems safely using environmentally friendly products. The area of responsibility covers approximately six hundred (600) properties. Contract will be a three (3) year contract with the option to extend for up to two (2) one (1) year terms.

### **Details:**

- Provide a comprehensive implementation plan
- Operate and Maintain at peak operating efficiencies of all equipment
- Incorporate a service program that will assure maximum results
- Quarterly Legionella testing on all cooling system tower cells during months of operation
- Handle and apply the chemicals when necessary in a safe and efficient manner in compliance with the requirements of CPS, State and Federal regulatory requirements
- Plan, develop, schedule, conduct and document training to all designated CPS Facilities representatives of all aspects on safety and application of the chemicals
- Supply, store, preserve, and dispose all required chemicals that are environmentally acceptable to all regulatory agencies
- All appropriate chemicals used in treatment of water must follow original manufacturer's posted guidelines for appropriate storage, handling, preservation, disposal and shelf-life instructions
- Provide the highest in corrosion prevention in all water systems
- Maintain the above program at the lowest possible overall cost

### **Qualifications**

The selected Bidder's personnel shall have a minimum of five (5) year water treatment experience and in the implementation of heating and cooling systems. Bidder's representative must hold a Certified Water Technologist ("CWT") certification from the Association of Water Technologies ("AWT") and have experience in the training of operating personnel. Bidder must have adequate staff to perform consistent service across all locations.

### **Materials and Supplies**

All supplies shall be new, unused, unadulterated and come with the original manufacturer's guarantee and standard product warranty (where applicable). Additionally, supplies purchased under this Contract shall conform to the best practices known to the industry regarding strength, quality of material and workmanship.

### **Training**

Training for all and appropriate CPS designated Facilities staff or representative on water treatment implementation, chemical safety, handling of chemicals, and control monitoring will be held on-site twice per year. All training should include workbooks/manuals and videos to aid in the training of CPS Facilities personnel. Additionally, testing support Services will be provided as required by the Building Engineer or designated Facilities personnel to assure consistent "chemistry" in the treatment solution. The selected bidder must provide a copy of the annual training program which will include a program that will allow CPS to track and validate all employees trained throughout the life of the contract.

### **Service Visits**

Bidder will provide:

- A comprehensive implementation and management plan outlining the chemical treatment and service plan.
- Monthly testing to control and limit scale, corrosion, suspended solids, and oxygen to recommended ranges for boilers and chillers.
- Bidder shall provide an annual schedule to the Department of Facilities two weeks prior to the start of site visits. The schedule shall include the school and designated time and date of scheduled

## **IV. SCOPE OF PRODUCTS AND SERVICES**

visit. Bidder shall notify the Building Engineer forty-eight (48) hours prior to scheduled visit to confirm the appointment.

- The Site Visit schedule must be incorporated into the annual overall Master schedule. This Master schedule must be maintained and available for presentation to CPS in accordance with frequency needs.
- All boilers involved in water treatment should be tested before adding chemicals, to determine the quality of the water coming into the boilers.
- Bidder must provide documents, data, analytics, results and records associated with service performance as an evidence and conformance of service for each site visits and interpretation and chemical analysis levels.
- Bidders shall meet all city, state, and federal codes and regulatory guidelines.
- Bidder shall add chemicals if needed at the time of the monthly site visit.

### **Reporting**

Service visits will be made **monthly** to all designated CPS facilities for testing of the heating and cooling systems when in service. A written report with original source and supporting documents/records and operating instructions of the testing results will be left onsite with the designated Facilities Representative in order to operate the equipment at the proper levels. Any issues shall be noted and recommended for corrective action. If chemicals are needed, Bidder would make a recommendation to the Facility Manager to add the necessary chemicals.

Bidder must have a client web interface system. This system must allow designated Facilities staff the ability to remotely view testing and mitigation results of all systems in the portfolio.

### **Pre/Post Service Analysis Visits**

A pre- and post- heating and cooling service visits shall be performed to check the condition of all pretreated equipment. The visits should include oxygen studies on the d-aerator, elution studies and resin analysis of the softeners and analysis of operating efficiency on the iron filters and condensation polisher.

### **Emergency Response Time**

Emergency response time for the selected Bidder must be within four (4) hours. Bidder must include a contact telephone number for around the clock, twenty-four (24) hour, seven (7) day per week, three hundred sixty-five (365) days emergency contact.

### **Handling/Delivery of Chemicals**

Delivery of chemicals shall be in the original manufacturer bulk container. The winning bidder will be able to deliver a range of mini-bulk chemicals. The mini bulk delivery systems will consist of stainless or plastic tanks with containment. The tank must be labeled and follow City/State/Federal codes. The Bidder's staff will make delivery of the chemical directly into the original mini-bulk tanks and remove all empty drums from the Site at the time of transfer of chemical. Additionally, Materials Safety Data Sheets ("**MSDS**") shall be submitted at the time of delivery to the Facilities Building Engineer and/or Building Manager.

Bidder(s) will deliver the chemicals and supplies to Chicago Public Schools – Monday through Friday, between 8:00 a.m. and 2:30 p.m., unless CPS approves a different delivery schedule. Any deviations from these aforementioned delivery rules must be documented and approved in writing by CPS and/or CPS designated FMO Managers.

### **Test Methods**

Bidders shall attach a proposed testing program complete with the recommended frequency and description of test methods and work instructions. All Bidders shall attach a summary and information on the chemical handling, storage, preservation and appropriate disposal systems performed.

#### **IV. SCOPE OF PRODUCTS AND SERVICES**

##### **Storage of Chemicals**

Bidder must provide written guidance for appropriate handling, storage of chemicals to Building Engineers and FMO Designee.

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**

## **V. SUBMITTAL REQUIREMENTS**

### **FAILURE TO SUBMIT ANY OF THE SUBMITTAL REQUIREMENTS WILL DEEM BIDDER AS NONRESPONSIVE AND THE BID WILL NOT BE FURTHER CONSIDERED.**

1. **Format of Bid Response:** All bids shall contain sufficient detail to enable the Board to evaluate it according to the criteria outlined in Section VI: Evaluation Criteria and Basis of Award. All the bid submissions should be uploaded to the link below. The Board may, but is not required to, request additional information or oral presentations from Bidders. Therefore, the bid submitted should represent the best terms by which Bidder would be able to provide the Products and Services.

**Upload your submission at:**

<https://cps.bonfirehub.com/opportunities/private/a0bc635ca8946bd681c8232f99998d39>

2. **Contents of Response:**
  - A. **Bid Tabulation Page (Attachment D):** The Excel file containing the completed Bid Tabulation Pages must be submitted. The Bid Tabulation Spreadsheet must be completed by Bidder in compliance with Section VII.
  - B. **Bid Execution Page:** The Bid Execution Page must be appropriately completed and original signed versions must be submitted.
  - C. **Contractor Disclosure Form (Attachment A):** The Contractor's Disclosure Form must be filled out in its entirety, signed and notarized and submitted with bid response.
  - D. **W-9 Tax Form (Attachment B):** W-9 Form Request for Taxpayer Identification Number and Certification Affidavit must be properly completed.
  - E. **MBE/WBE Compliance Plan (Attachment C):** All sections of the *Remedial Program for Minority and Women-Owned Business Enterprise Participation in Goods and Services Contracts* that apply to your business entity must be filled out in their entirety. Any sections that do not apply must be clearly marked **N/A**. These completed documents must be submitted with the required copies of your Bid. Please note that all MBE/WBE documents in reference to your business that require a notarized signature must also be included in the submittal package. For the term of this Contract, Bidder shall adhere to the minimum goals set at 30% for MBE and 7% for WBE participation and shall adhere to all other applicable MBE/WBE requirements as set forth in the Remedial Program, as may be amended from time to time.
  - F. **References:** A minimum of three (3) references from entities for which Bidder is currently providing, or has in the past provided Products and Services of similar scope and magnitude. Bidder shall provide the name and telephone number of all contact persons, along with testimonials of individuals at each of the references must be provided. The Board reserves the right to contact these references.
  - G. **Financial Statements:** Electronic copies of audited financial statements or tax returns signed by the preparer (only if audited financial statements are not available) for the three (3) previous fiscal years must be provided. Financial Statements must include auditor's letter of opinion, auditor's notes, balance sheet, and statement of income/loss. Each prime or joint venture partner must submit this information. The Board reserves the right to accept alternative information and/or documentation submitted by

## **V. SUBMITTAL REQUIREMENTS**

Bidder(s). The financial statements shall only be included with the electronic submission.

- H. **Insurance Requirements:** Evidence of current insurance coverage must be submitted. If awarded this Contract, and Bidder's current coverage does not meet the requirements stated in this Bid, Bidder shall acquire the required insurance coverage, prior to supplying any Products or performing the Services.
  - I. **Licenses:** Submit copies of your entities' applicable City of Chicago, State of Illinois licenses, and all other licenses relevant to the performance of this Contract.
  - J. **Longevity of Business Organization:** List, and briefly describe how long your organization has been in business including any documentation that will support this information.
  - K. **Joint Ventures:** A copy of the executed joint venture agreement, if applicable, must be submitted. Indicate **N/A** if Bidder will not be part of a joint venture agreement.
  - L. **Legal Actions:** List, and briefly describe, any and all legal actions for the past three (3) years in which Bidder has been a debtor in bankruptcy, a defendant in a lawsuit for deficient performance under a contract or agreement; a respondent in an administrative action for deficient performance, or a defendant in a criminal action. Indicate **N/A** if Bidder does not have any legal actions as described above.
  - M. **Work History with Board:** List, and briefly describe, any past work history with the Board, including the specific project worked on or the specific products delivered to the Board.
  - N. **Work History Outside CPS:** List, and briefly describe, any past work history outside of CPS with similar size and/or scope.
  - O. **Implementation and Management Plan:** Bidder must detail the methodology and approach for managing and providing the Products and Services (both implementation and ongoing Services described in this bid). Methodology should include Bidder's approach to project management, scheduling, budget management and quality management.
3. **Responsibility for Costs or Expenses:** Bidder shall bear all costs incurred in the preparation and submission of its bid. Bidder shall not seek any reimbursement from the Board for any costs or expenses. Issuance of this solicitation does not commit the Board to pay any costs or expenses that may be incurred by Bidder during the bidding process.

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**



## **VI. EVALUATION CRITERIA AND BASIS OF AWARD**

### **1. SELECTION PROCESS**

- a) **Evaluation Committee:** An Evaluation Committee, which will include representatives from the Department of Facilities, the Department of Procurement, and may include representatives from other Board Departments, will review and evaluate the bids, in accordance with the evaluation criteria set forth below. The Evaluation Committee will submit its recommendation to the Chief Procurement Officer for review and concurrence, and request that the Chief Procurement Officer recommend to the Board that those Bidder(s) meeting the Board's criteria be awarded this Contract.
- b) **Competency of Bidder:** No award will be made to any person, firm or corporation that is in arrears or is in default with the Board, the City of Chicago, the State of Illinois and/or the County of Cook upon any debt or contract, or that is a defaulter upon any obligation to the Board, or has failed to perform faithfully on any previous contract with the Board.
- c) **Consideration of Bids:** The Chief Procurement Officer shall represent the Board in all matters pertaining to this bid. The Chief Procurement Officer reserves the right to reject any bid and to disregard any informality in the Bids when, in his opinion, the best interest of the Board will be served by such action.

### **2. EVALUATION CRITERIA**

Bidder shall be evaluated on the following criteria:

- a) Lowest responsive, responsible Bidder for each Bid Group;
- b) Longevity of business organization;
- c) Experience with other contracts of a similar type;
- d) The financial stability of Bidder;
- e) The past performance of Bidder on other contracts with the Board and any other entity in terms of quality of work and compliance with performance schedules. The Evaluation Committee may solicit from previous clients, including the Board, other government agencies, or any other available sources, relevant information concerning the Bidder's record of past performance;
- f) The quality of the responses received from the three (3) references;
- g) Capacity of Bidder to deliver the Products and Services on a timely basis;
- h) Submission of all submittal requirements;
- i) Demonstration of MBE/WBE compliance that shows how all applicable goals will be fulfilled. Proposed MBE's and WBE's must be identified through the submission of Forms 100, 101, 102 (if applicable), 103A and 103B (if applicable), 104 and 106 (if applicable). See Attachment C. The evaluation of the MBE/WBE plan will be based on the quality of the proposed MBE/WBE participation as demonstrated by the level, relevance and quality of participation by Minority/Women Business Enterprises. It should be noted failure to submit a complete and comprehensive MBE/WBE Program demonstrating compliance may cause Bidder to be deemed non-responsive and may be disqualified;

**VI. EVALUATION CRITERIA AND BASIS OF AWARD**

- j) Legal actions which may affect qualifications of Bidder or performance under this Contract;
- k) Compliance with the Insurance Requirements cited herein;
- l) Licenses to do business in the City of Chicago and/or the State of Illinois, as applicable, and all other licenses and certifications as may be necessary to deliver the Products and Services; and
- m) Quality of Implementation and Management Plan.

3. **BASIS OF AWARD**

This Contract will be awarded to the lowest, responsive, responsible Bidder who meets the Board's Evaluation Criteria set forth herein. The Board reserves the right to award a Contract to one or more than one Bidder or to reject any or all bids, when, in the Board's opinion the best interest of the Board will be served.

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**

## VII. BID TABULATION PAGE

**NOTE: ALL BID SUBMISSIONS ARE SUBJECT TO REVIEW FOR COMPLETENESS, ACCURACY AND COMPLIANCE WITH ALL TERMS AND CONDITIONS PROVIDED IN THE BID SPECIFICATION. PRICING MUST BE SUBMITTED ON THE BID TABULATION PAGES WITHOUT CONDITIONS. ANY CHANGES, MODIFICATIONS, ADDITIONAL TERMS AND CONDITIONS, EXCEPTIONS OR OTHER REVISIONS TO THIS BID, INCLUDING THE TABULATION PAGES, OR FAILURE TO COMPLETE ALL REQUIRED INFORMATION, MAY CAUSE THE BID TO BE DEEMED NON-RESPONSIVE.**

**Bid Tabulation Pages are required for completion in a Microsoft Excel Spreadsheet only. The spreadsheet(s) must be downloaded from the Department of Procurement. The Bid Tabulation spreadsheets completed by Bidder must be inserted into Section VII of this Contract. No ink or pencil submissions will be accepted.**

### **Instructions for Completing the Bid Tabulation Spreadsheets:**

Bidder is responsible for electronically entering information into the open cells in the Bid Tabulation Page in the Excel spreadsheet. Bidder **must complete all open cells in the following fields** on the Excel spreadsheet. **Any alterations to the locked cells of the Excel Spreadsheet may cause the Bid to be deemed as non-responsive.**

- **COLUMN C** - Annual Cost PER UNIT (Service, Chemicals & Training)
- **COLUMN F** - Year 3 Renewal – Annual Cost Per Unit (Service, Chemicals & Training)
- **COLUMN H** - Year 4 Renewal – Annual Cost Per Unit (Service, Chemicals & Training)
- **COLUMN J** - Year 5 Renewal – Annual Cost Per Unit (Service, Chemicals & Training)

The following fields are locked and will be filled in automatically within the Excel spreadsheet:

- Estimated Quantities
- Original Term of 2 Years- Annual System Cost
- Year 3 Annual Renewal Cost\*
- Year 4 Annual Renewal Cost\*
- Year 5 Annual Renewal Cost\*

**For this Bid, the Bidder must bid on all Boilers and all Chillers.**

### **Explanation of Columns on Boiler & Chiller Tabs**

- **Column A (Biddable Group)** – The biddable group the school is located in
- **Column B (Quality Region)** – The quality region the school is located in
- **Column C (FCID)**- Unique School Identifier
- **Column D (Property Use)** – Identifies if a school is active, closed, leased etc
- **Column E (Campus Name)** – Name of main campus for which Services are being requested
- **Column F (School Name)** – Name of school for which Services are being requested
- **Column G (Address)** - The address of the school listed

## **VII. BID TABULATION PAGE**

- **Column H (Assess Year)** – Year the unit was assessed
- **Column I (Building Name)** – Indicates if building is Main, Addition, Annex etc.
- **Column J (Building Square Footage)** – The approximate square footage for each school listed
- **Column K (Location)** – The location of the unit
- **Column L (Item Name)** - Description of the unit

**The Board will award to the lowest, responsive, responsible Bidder by Bid Group for the annual price for preventative maintenance and repair. The Board has the right to award multiple Bid Groups to one Bidder based on capacity. Bidders should only bid on Bid Groups they have the capacity to handle.**

### **Summary Page**

The Total Contract will automatically populate the cells on the Summary Page. The Summary Page must include a printed name, signature, title, telephone number and name of company by an authorized Bidder representative.


### **Signature and Contact Information**

The Bid Tabulation Page must include Bidder's name and vendor number from CPS as well as a printed name, signature, title, telephone number and name of an authorized representative of Bidder.

**[REMAINDER OF THIS PAGE HAS BEEN LEFT BLANK INTENTIONALLY]**

### Water Treatment Product and Services - Summary Page

Boiler Type	Total Contract Cost (2 year initial contract term, plus 3 one year renewals)
<b>Total Boiler Costs</b>	\$ 4,305,643
<b>Total Chiller Costs</b>	\$ 681,893
<b>Total Boiler &amp; Chiller Costs</b>	\$ 4,987,535

<b>Bidder Name: Global Water Technology, Inc.</b>	
<b>Vendor Number: 35426</b>	
<b>Bidder must provide printed name, signature, title, telephone number and name of authorized representative of the Bidder</b>	
<b>Name of Authorized Representative of the Bidder: Michael A. Byerley   Phone: 708-349-9991</b>	
<b>Signature</b>	
<b>Title: President &amp; CEO</b>	

Dated: 2/22/21

**Water Treatment Product and Services - Bid Tabulation Page**

*Instructions: Please list the Annual Cost Per Unit listed in Column C, F, H and J for Boilers and Chillers based on the estimated quantities.*

*Annual Cost Per Unit price should include all services listed in the Scope of Services*

*\*Renewal Prices will be considered if CPS exercises the options to renew.*

Estimated Quantities	Boiler Type	Annual Cost PER UNIT (Service, Chemicals & Training)	Original Term of 2 years - Year One Annual System Cost	Original Term of 2 years - Year Two Annual System Cost	Year 3 Renewal - Annual Cost Per Unit (Service, Chemicals & Training)	Year 3 Annual Renewal Cost*	Year 4 Renewal - Annual Cost Per Unit (Service, Chemicals & Training)	Year 4 Annual Renewal Cost*	Year 5 Renewal - Annual Cost Per Unit (Service, Chemicals & Training)	Year 5 Annual Renewal Cost*
627	Hot Water Loop	\$ 245	\$ 153,615	\$ 153,615	\$ 250	\$ 156,610	\$ 255	\$ 159,743	\$ 261	\$ 163,736
767	Steam	\$ 895	\$ 686,465	\$ 686,465	\$ 912	\$ 699,851	\$ 931	\$ 713,848	\$ 954	\$ 731,694
	<b>Total Boiler Costs</b>		\$ 840,080	\$ 840,080		\$ 856,462		\$ 873,591		\$ 895,431

Estimated Quantities	Chiller Type	Annual Cost PER UNIT (Service, Chemicals & Training)	Original Term of 2 years - Year One Annual System Cost	Original Term of 2 years - Year Two Annual System Cost	Year 3 Renewal - Annual Cost Per Unit (Service, Chemicals & Training)	Year 3 Annual Renewal Cost*	Year 4 Renewal - Annual Cost Per Unit (Service, Chemicals & Training)	Year 4 Annual Renewal Cost*	Year 5 Renewal - Annual Cost Per Unit (Service, Chemicals & Training)	Year 5 Annual Renewal Cost*
191	Chiller-Air Cooled (Evaporated)	\$ 245	\$ 46,795	\$ 46,795	\$ 250	\$ 47,708	\$ 255	\$ 48,662	\$ 261	\$ 49,878
30	Chiller-Water Cooled (Closed Loop)	\$ 2,875	\$ 86,250	\$ 86,250	\$ 2,931	\$ 87,932	\$ 2,990	\$ 89,691	\$ 3,064	\$ 91,933
	<b>Total Chiller Costs</b>		\$ 133,045	\$ 133,045		\$ 135,639		\$ 138,352		\$ 141,811

<b>Total Boiler &amp; Chiller Costs</b>			\$ 973,125	\$ 973,125		\$ 992,101		\$ 1,011,943		\$ 1,037,242
---	--	--	------------	------------	--	------------	--	--------------	--	--------------

**Bidder Name:** Global Water Technology, Inc.

**Vendor Number:** 35426

**Bidder must provide printed name, signature, title, telephone number and name of authorized representative of the Bidder**

**Name of Authorized Representative of the Bidder:** Michael A. Byerley | Phone: 708-349-9991

**Signature**

**Title:** President & CEO



Dated: 2/22/21

## CPS Boilers

Biddable	Quality Region	FCID	Property Use	Campus Name	School Name	Address	Assess Year	Building Name	Building Square	Location	Item Name
1	QS-4B	51230	Active School	Abbott	Air Force Academy High School	3630 S Wells STREET, Chicago IL 6	2019	Addition 2	38154	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4B	51230	Active School	Abbott	Air Force Academy High School	3630 S Wells STREET, Chicago IL 6	2019	Addition 2	38154	Boiler Room	Condensing- Hot Water Boiler
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Main	31543	Mechanical Room	Boiler Auxiliary- Steam Boiler
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Main	31543	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Main	31543	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Addition	3959	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Addition	3959	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Annex		Entire Building	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H , Chicago IL 606	2019	Annex		Entire Building	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3B	51156	Active School	Agassiz	Louis A Agassiz Elementary School	2851 N Seminary AVENUE, Chicag	2014	Main	57743	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51156	Active School	Agassiz	Louis A Agassiz Elementary School	2851 N Seminary AVENUE, Chicag	2014	Main	57743	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51156	Active School	Agassiz	Louis A Agassiz Elementary School	2851 N Seminary AVENUE, Chicag	2014	Main	57743	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	54187	Active School	Albany Park/ Edison	Albany Park Multicultural Academy	4929 N Sawyer AVENUE, Chicago I	2014	Main	104203	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1A	54187	Active School	Albany Park/ Edison	Albany Park Multicultural Academy	4929 N Sawyer AVENUE, Chicago I	2014	Main	104203	Mechanical Room	Condensing- Hot Water Boiler
1	QS-3B	51157	Active School	Alcott	Louisa May Alcott College Preparato	2625 N Orchard STREET, Chicago	2014	Main	51310	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51157	Active School	Alcott	Louisa May Alcott College Preparato	2625 N Orchard STREET, Chicago	2014	Main	51310	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51175	Active School	Alcott Community H	Louisa May Alcott College Preparato	2957 N Hoyne AVENUE, Chicago IL	2014	Main	51852	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51175	Active School	Alcott Community H	Louisa May Alcott College Preparato	2957 N Hoyne AVENUE, Chicago IL	2014	Main	51852	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51501	Active School	Aldridge	Ira F Aldridge Elementary School	630 E 131st STREET, Chicago IL 6	2019	Main	45589	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9A	51501	Active School	Aldridge	Ira F Aldridge Elementary School	630 E 131st STREET, Chicago IL 6	2019	Main	45589	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-7A	51371	Active School	Altgeld	Daniel S Wentworth Elementary Scho	1340 W 71st STREET, Chicago IL 6	2014	Main	69366	Basement	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51371	Active School	Altgeld	Daniel S Wentworth Elementary Scho	1340 W 71st STREET, Chicago IL 6	2014	Main	69366	Basement	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51371	Active School	Altgeld	Daniel S Wentworth Elementary Scho	1340 W 71st STREET, Chicago IL 6	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7A	51371	Active School	Altgeld	Daniel S Wentworth Elementary Scho	1340 W 71st STREET, Chicago IL 6	2014	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-7A	51371	Active School	Altgeld	Daniel S Wentworth Elementary Scho	1340 W 71st STREET, Chicago IL 6	2014	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3A	51109	Active School	Ames	Marine Leadership Academy at Ames	1920 N Hamlin AVENUE, Chicago II	2014	Main	126540	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51109	Active School	Ames	Marine Leadership Academy at Ames	1920 N Hamlin AVENUE, Chicago II	2014	Main	126540	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	51109	Active School	Ames	Marine Leadership Academy at Ames	1920 N Hamlin AVENUE, Chicago II	2014	Main	126540	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51531	Active School	Amundsen HS	Roald Amundsen High School	5110 N Damen AVENUE, Chicago II	2014	Main	218950	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51531	Active School	Amundsen HS	Roald Amundsen High School	5110 N Damen AVENUE, Chicago II	2014	Main	218950	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51401	Active School	Ariel Elementary Co	Ariel Elementary Community Academ	1119 E 46th STREET, Chicago IL 6	2019	Addition 1	59963	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51401	Active School	Ariel Elementary Co	Ariel Elementary Community Academ	1119 E 46th STREET, Chicago IL 6	2019	Addition 1	59963	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51401	Active School	Ariel Elementary Co	Ariel Elementary Community Academ	1119 E 46th STREET, Chicago IL 6	2019	Addition 1	59963	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8A	51401	Active School	Ariel Elementary Co	Ariel Elementary Community Academ	1119 E 46th STREET, Chicago IL 6	2019	Addition 1	59963	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4B	51231	Active School	Armour	Phillip D Armour Elementary School	950 W 33rd PLACE, Chicago IL 60	2019	Main	51568	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51231	Active School	Armour	Phillip D Armour Elementary School	950 W 33rd PLACE, Chicago IL 60	2019	Main	51568	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	51231	Active School	Armour	Phillip D Armour Elementary School	950 W 33rd PLACE, Chicago IL 60	2019	Branch		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51231	Active School	Armour	Phillip D Armour Elementary School	950 W 33rd PLACE, Chicago IL 60	2019	Branch		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51044	Active School	Armstrong G	George Armstrong International Studi	2110 W Greenleaf AVENUE, Chicag	2019	Main	61724	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51044	Active School	Armstrong G	George Armstrong International Studi	2110 W Greenleaf AVENUE, Chicag	2019	Main	61724	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51044	Active School	Armstrong G	George Armstrong International Studi	2110 W Greenleaf AVENUE, Chicag	2019	Addition 2	70296	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51044	Active School	Armstrong G	George Armstrong International Studi	2110 W Greenleaf AVENUE, Chicag	2019	Addition 2	70296	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6B	51450	Active School	Ashburn	Ashburn Community Elementary Schc	8300 S St Louis AVENUE, Chicago	2019	Leased-Main	58580	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51450	Active School	Ashburn	Ashburn Community Elementary Schc	8300 S St Louis AVENUE, Chicago	2019	Leased-Main	58580	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51483	Active School	Ashe	Arthur R Ashe Elementary School	8505 S Ingleside AVENUE, Chicagc	2019	Main	55335	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51483	Active School	Ashe	Arthur R Ashe Elementary School	8505 S Ingleside AVENUE, Chicagc	2019	Main	55335	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51045	Active School	Audubon	John J Audubon Elementary School	3500 N Hoyne AVENUE, Chicago IL	2019	Main	47449	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51045	Active School	Audubon	John J Audubon Elementary School	3500 N Hoyne AVENUE, Chicago IL	2019	Main	47449	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51045	Active School	Audubon	John J Audubon Elementary School	3500 N Hoyne AVENUE, Chicago IL	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water Boiler
1	QS-3B	51045	Active School	Audubon	John J Audubon Elementary School	3500 N Hoyne AVENUE, Chicago IL	2019	Annex		Boiler Room	Non Condensing- Cast Iron- Force Draft- Hot Water Boiler
1	QS-3A	51675	Active School	Austin Community H	Austin College and Career Academy	231 N Pine AVENUE, Chicago IL 60	2014	Main	397258	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51675	Active School	Austin Community H	Austin College and Career Academy	231 N Pine AVENUE, Chicago IL 60	2014	Main	397258	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51458	Active School	Avalon Park	Avalon Park Elementary School	8045 S Kenwood AVENUE, Chicagc	2019	Main	38816	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51458	Active School	Avalon Park	Avalon Park Elementary School	8045 S Kenwood AVENUE, Chicagc	2019	Main	38816	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	54768	Active School	Azuela	Mariano Azuela Elementary School	4707 W Marquette ROAD, Chicago	2014	Main	94600	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	54768	Active School	Azuela	Mariano Azuela Elementary School	4707 W Marquette ROAD, Chicago	2014	Main	94600	Boiler Room	Condensing- Hot Water Boiler
1	QS-5B	59215	Active School	Back of the Yards	Back of the Yards IB HS	2111 W 47 STREET, Chicago IL 60	2014	Main	212285	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5B	59215	Active School	Back of the Yards	Back of the Yards IB HS	2111 W 47 STREET, Chicago IL 60	2014	Main	212285	Boiler Room	Condensing- Hot Water Boiler
1	QS-7A	51389	Active School	Banneker	Benjamin E Mays Elementary Acader	6656 S Normal BOULEVARD, Chic	2019	Main	65017	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51389	Active School	Banneker	Benjamin E Mays Elementary Acader	6656 S Normal BOULEVARD, Chic	2019	Main	65017	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51423	Active School	Barnard	Alice L Barnard Computer Math & Sci	10354 S Charles STREET, Chicago	2019	Main	47741	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51423	Active School	Barnard	Alice L Barnard Computer Math & Sci	10354 S Charles STREET, Chicago	2019	Main	47741	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51423	Active School	Barnard	Alice L Barnard Computer Math & Sci	10354 S Charles STREET, Chicago	2019	Main	47741	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51000	Active School	Barry	John Barry Elementary School	2828 N Kilbourn AVENUE, Chicago	2019	Main	64300	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51000	Active School	Barry	John Barry Elementary School	2828 N Kilbourn AVENUE, Chicago	2019	Main	64300	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51000	Active School	Barry	John Barry Elementary School	2828 N Kilbourn AVENUE, Chicago	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3B	51000	Active School	Barry	John Barry Elementary School	2828 N Kilbourn AVENUE, Chicago	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-7B	51372	Active School	Barton	Clara Barton Elementary School	7650 S Wolcott AVENUE, Chicago I	2019	Main	53503	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-7B	51372	Active School	Barton	Clara Barton Elementary School	7650 S Wolcott AVENUE, Chicago I	2019	Main	53503	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler

1	QS-7A	51373	Active School	Bass	Perkins Bass Elementary School	1140 W 66th STREET, Chicago IL 6	2019	Main	55478	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51373	Active School	Bass	Perkins Bass Elementary School	1140 W 66th STREET, Chicago IL 6	2019	Main	55478	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51373	Active School	Bass	Perkins Bass Elementary School	1140 W 66th STREET, Chicago IL 6	2019	Main	55478	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51373	Active School	Bass	Perkins Bass Elementary School	1140 W 66th STREET, Chicago IL 6	2019	Main	55478	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51046	Active School	Bateman	Newton Bateman Elementary School	4220 N Richmond STREET, Chicag	2019	Main	92937	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1A	51046	Active School	Bateman	Newton Bateman Elementary School	4220 N Richmond STREET, Chicag	2019	Main	92937	Boiler Room	Condensing- Hot Water Boiler
1	QS-1A	51046	Active School	Bateman	Newton Bateman Elementary School	4220 N Richmond STREET, Chicag	2019	Addition	58757	3rd Floor	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51046	Active School	Bateman	Newton Bateman Elementary School	4220 N Richmond STREET, Chicag	2019	Addition	58757	3rd Floor	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51021	Active School	Beard	Daniel C Beard Elementary School	6445 W Strong STREET, Chicago IL	2019	Main	16847	Mechanical Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-1B	51021	Active School	Beard	Daniel C Beard Elementary School	6445 W Strong STREET, Chicago IL	2019	Main	16847	Mechanical Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-1B	51021	Active School	Beard	Daniel C Beard Elementary School	6445 W Strong STREET, Chicago IL	2019	Linked Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51021	Active School	Beard	Daniel C Beard Elementary School	6445 W Strong STREET, Chicago IL	2019	Linked Addition		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51002	Active School	Beaubien	Jean Baptiste Beaubien Elementary S	5025 N Laramie AVENUE, Chicago	2019	Main	80395	Entire Building	Boiler Auxiliary- Non Condensing Steam Boiler
1	QS-1B	51002	Active School	Beaubien	Jean Baptiste Beaubien Elementary S	5025 N Laramie AVENUE, Chicago	2019	Main	80395	Entire Building	Non Condensing- Cast Iron- Force Draft- Steam Boiler
1	QS-1B	51002	Active School	Beaubien	Jean Baptiste Beaubien Elementary S	5025 N Laramie AVENUE, Chicago	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51002	Active School	Beaubien	Jean Baptiste Beaubien Elementary S	5025 N Laramie AVENUE, Chicago	2019	Linked Addition		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8A	51360	Active School	Beethoven	Ludwig Van Beethoven Elementary Sr	25 W 47th STREET, Chicago IL 606	2014	Main	84750	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51360	Active School	Beethoven	Ludwig Van Beethoven Elementary Sr	25 W 47th STREET, Chicago IL 606	2014	Main	84750	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2B	51180	Active School	Beidler	Jacob Beidler Elementary School	3151 W Walnut STREET, Chicago II	2019	Main	47320	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51180	Active School	Beidler	Jacob Beidler Elementary School	3151 W Walnut STREET, Chicago II	2019	Main	47320	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51180	Active School	Beidler	Jacob Beidler Elementary School	3151 W Walnut STREET, Chicago II	2019	Addition	39450	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2B	51180	Active School	Beidler	Jacob Beidler Elementary School	3151 W Walnut STREET, Chicago II	2019	Addition	39450	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-1A	51003	Active School	Belding	Hiram H Belding Elementary School	4257 N Tripp AVENUE, Chicago IL I	2014	Main	61160	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51003	Active School	Belding	Hiram H Belding Elementary School	4257 N Tripp AVENUE, Chicago IL I	2014	Main	61160	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51047	Active School	Bell	Alexander Graham Bell Elementary Sr	3730 N Oakley AVENUE, Chicago II	2019	Main	93084	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51047	Active School	Bell	Alexander Graham Bell Elementary Sr	3730 N Oakley AVENUE, Chicago II	2019	Main	93084	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51424	Active School	Bennett	Frank I Bennett Elementary School	10115 S Prairie AVENUE, Chicago I	2019	Main	67595	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51424	Active School	Bennett	Frank I Bennett Elementary School	10115 S Prairie AVENUE, Chicago I	2019	Main	67595	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	51223	Active School	Bethune	Joseph Kellman Corporate Communit	3030 W Arthington STREET, Chicag	2019	Main	75510	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51223	Active School	Bethune	Joseph Kellman Corporate Communit	3030 W Arthington STREET, Chicag	2019	Main	75510	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51491	Active School	Black	Robert A Black Magnet Elementary Sr	9101 S Euclid AVENUE, Chicago IL	2019	Main	31760	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51491	Active School	Black	Robert A Black Magnet Elementary Sr	9101 S Euclid AVENUE, Chicago IL	2019	Main	31760	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9B	51491	Active School	Black	Robert A Black Magnet Elementary Sr	9101 S Euclid AVENUE, Chicago IL	2019	Branch	34329	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51491	Active School	Black	Robert A Black Magnet Elementary Sr	9101 S Euclid AVENUE, Chicago IL	2019	Branch	34329	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51048	Active School	Blaine	James G Blaine Elementary School	1420 W Grace STREET, Chicago IL	2019	Main	50090	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51048	Active School	Blaine	James G Blaine Elementary School	1420 W Grace STREET, Chicago IL	2019	Main	50090	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51304	Active School	Blair	Blair Early Childhood Center	6751 W 63rd PLACE, Chicago IL 6C	2019	Main	14788	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	51304	Active School	Blair	Blair Early Childhood Center	6751 W 63rd PLACE, Chicago IL 6C	2019	Main	14788	Boiler Room	Condensing- Hot Water Boiler
1	QS-6A	51304	Active School	Blair	Blair Early Childhood Center	6751 W 63rd PLACE, Chicago IL 6C	2019	Addition	23160	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51304	Active School	Blair	Blair Early Childhood Center	6751 W 63rd PLACE, Chicago IL 6C	2019	Addition	23160	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6B	51606	Active School	Bogan HS	William J Bogan High School	3939 W 79th STREET, Chicago IL 6	2019	Main	184611	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51606	Active School	Bogan HS	William J Bogan High School	3939 W 79th STREET, Chicago IL 6	2019	Main	184611	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51387	Active School	Bond	Carrie Jacobs Bond Elementary Scho	7050 S May STREET, Chicago IL 6f	2019	Main	32730	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51387	Active School	Bond	Carrie Jacobs Bond Elementary Scho	7050 S May STREET, Chicago IL 6f	2019	Main	32730	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51049	Active School	Boone	Daniel Boone Elementary School	6710 N Washtenaw AVENUE, Chic	2019	Main	61749	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51049	Active School	Boone	Daniel Boone Elementary School	6710 N Washtenaw AVENUE, Chic	2019	Main	61749	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51460	Active School	Bouchet	Edward A Bouchet Math & Science Aca	7355 S Jeffery BOULEVARD, Chica	2014	Addition 1	55927	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51460	Active School	Bouchet	Edward A Bouchet Math & Science Aca	7355 S Jeffery BOULEVARD, Chica	2014	Addition 1	55927	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51460	Active School	Bouchet	Edward A Bouchet Math & Science Aca	7355 S Jeffery BOULEVARD, Chica	2014	Addition 1	55927	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51460	Active School	Bouchet	Edward A Bouchet Math & Science Aca	7355 S Jeffery BOULEVARD, Chica	2014	Addition 1	55927	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51627	Active School	Bowen Multiplex Fat	Bowen High School	2710 E 89th STREET, Chicago IL 6f	2019	Addition 1	40692	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51627	Active School	Bowen Multiplex Fat	Bowen High School	2710 E 89th STREET, Chicago IL 6f	2019	Addition 1	40692	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51627	Active School	Bowen Multiplex Fat	Bowen High School	2710 E 89th STREET, Chicago IL 6f	2019	Addition 4	82150	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-9B	51627	Active School	Bowen Multiplex Fat	Bowen High School	2710 E 89th STREET, Chicago IL 6f	2019	Addition 4	82150	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-8B	51459	Active School	Bradwell	Myra Bradwell Communications Arts &	7736 S Burnham AVENUE, Chicagc	2019	Main	41483	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51459	Active School	Bradwell	Myra Bradwell Communications Arts &	7736 S Burnham AVENUE, Chicagc	2019	Main	41483	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51459	Active School	Bradwell	Myra Bradwell Communications Arts &	7736 S Burnham AVENUE, Chicagc	2019	Addition 3	17041	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8B	51459	Active School	Bradwell	Myra Bradwell Communications Arts &	7736 S Burnham AVENUE, Chicagc	2019	Addition 3	17041	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51078	Active School	Brennemann	Joseph Brennemann Elementary Schi	4251 N Clarendon AVENUE, Chicag	2019	Main	48994	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2A	51078	Active School	Brennemann	Joseph Brennemann Elementary Schi	4251 N Clarendon AVENUE, Chicag	2019	Main	48994	Boiler Room	Condensing- Hot Water Boiler
1	QS-3B	51159	Active School	Brentano	Lorenz Brentano Math & Science Aca	2723 N Fairfield AVENUE, Chicago	2019	Main	117104	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51159	Active School	Brentano	Lorenz Brentano Math & Science Aca	2723 N Fairfield AVENUE, Chicago	2019	Main	117104	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51004	Active School	Bridge	Norman A Bridge Elementary School	3800 N New England AVENUE, Chi	2019	Main	74754	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51004	Active School	Bridge	Norman A Bridge Elementary School	3800 N New England AVENUE, Chi	2019	Main	74754	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51004	Active School	Bridge	Norman A Bridge Elementary School	3800 N New England AVENUE, Chi	2019	Leased-Branch		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51004	Active School	Bridge	Norman A Bridge Elementary School	3800 N New England AVENUE, Chi	2019	Leased-Branch		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9B	51497	Active School	Bright	Orville T Bright Elementary School	10740 S Calhoun AVENUE, Chicag	2019	Main	76354	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51497	Active School	Bright	Orville T Bright Elementary School	10740 S Calhoun AVENUE, Chicag	2019	Main	76354	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51497	Active School	Bright	Orville T Bright Elementary School	10740 S Calhoun AVENUE, Chicag	2019	Main	76354	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51497	Active School	Bright	Orville T Bright Elementary School	10740 S Calhoun AVENUE, Chicag	2019	Main	76354	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51497	Active School	Bright	Orville T Bright Elementary School	10740 S Calhoun AVENUE, Chicag	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51497	Active School	Bright	Orville T Bright Elementary School	10740 S Calhoun AVENUE, Chicag	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5B	51285	Active School	Brighton Park	Brighton Park Elementary School	3825 S Washtenaw AVENUE, Chica	2014	Main	24650	Basement	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler



1	QS-5B	51285	Active School	Brighton Park	Brighton Park Elementary School	3825 S Washtenaw AVENUE, Chic	2014	Main	24650	Basement	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51285	Active School	Brighton Park	Brighton Park Elementary School	3825 S Washtenaw AVENUE, Chic	2014	Addition 2	53000	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51285	Active School	Brighton Park	Brighton Park Elementary School	3825 S Washtenaw AVENUE, Chic	2014	Addition 2	53000	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-8A	51685	Active School	Bronzeville Classica	Bronzeville Classical Elementary Sch	8 W Root STREET, Chicago IL 606	2019	Main		Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8A	51685	Active School	Bronzeville Classica	Bronzeville Classical Elementary Sch	8 W Root STREET, Chicago IL 606	2019	Main		Boiler Room	Condensing- Hot Water Boiler
1	QS-9A	51632	Active School	Brooks	Gwendolyn Brooks College Preparato	250 E 111th STREET, Chicago IL 6	2019	Main	53111	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-9A	51632	Active School	Brooks	Gwendolyn Brooks College Preparato	250 E 111th STREET, Chicago IL 6	2019	Main	53111	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9A	51632	Active School	Brooks	Gwendolyn Brooks College Preparato	250 E 111th STREET, Chicago IL 6	2019	Main	53111	Mechanical Room	Condensing- Hot Water Boiler
1	QS-9A	51632	Active School	Brooks	Gwendolyn Brooks College Preparato	250 E 111th STREET, Chicago IL 6	2019	Main	53111	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9A	51512	Active School	Brown R	Ronald Brown Elementary Community	12607 S Union AVENUE, Chicago II	2019	Main	36229	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-9A	51512	Active School	Brown R	Ronald Brown Elementary Community	12607 S Union AVENUE, Chicago II	2019	Main	36229	Boiler Room	Condensing- Hot Water Boiler
1	QS-4B	51181	Active School	Brown W	William H Brown Elementary School	54 N Hermitage AVENUE, Chicago	2019	Main	49660	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51181	Active School	Brown W	William H Brown Elementary School	54 N Hermitage AVENUE, Chicago	2019	Main	49660	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51376	Active School	Brownell	Charles S Brownell Elementary Schoc	6741 S Michigan AVENUE, Chicagc	2019	Main	42620	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51376	Active School	Brownell	Charles S Brownell Elementary Schoc	6741 S Michigan AVENUE, Chicagc	2019	Main	42620	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51088	Active School	Brunson	Milton Brunson Math & Science Speci	932 N Central AVENUE, Chicago IL	2014	Main	102700	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51088	Active School	Brunson	Milton Brunson Math & Science Speci	932 N Central AVENUE, Chicago IL	2014	Main	102700	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2A	51050	Active School	Budlong	Lyman A Budlong Elementary School	2701 W Foster AVENUE, Chicago II	2019	Main	75773	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51050	Active School	Budlong	Lyman A Budlong Elementary School	2701 W Foster AVENUE, Chicago II	2019	Main	75773	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51050	Active School	Budlong	Lyman A Budlong Elementary School	2701 W Foster AVENUE, Chicago II	2019	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51050	Active School	Budlong	Lyman A Budlong Elementary School	2701 W Foster AVENUE, Chicago II	2019	Annex		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3A	51087	Active School	Burbank	Luther Burbank Elementary School	2035 N Mobile AVENUE, Chicago IL	2019	Main	90517	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	51087	Active School	Burbank	Luther Burbank Elementary School	2035 N Mobile AVENUE, Chicago IL	2019	Main	90517	Boiler Room	Condensing- Hot Water Boiler
1	QS-3A	51087	Active School	Burbank	Luther Burbank Elementary School	2035 N Mobile AVENUE, Chicago IL	2019	Addition	74847	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51087	Active School	Burbank	Luther Burbank Elementary School	2035 N Mobile AVENUE, Chicago IL	2019	Addition	74847	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8A	51347	Active School	Burke	Edmond Burke Elementary School	5386 S King DRIVE, Chicago IL 60	2019	Main	47913	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51347	Active School	Burke	Edmond Burke Elementary School	5386 S King DRIVE, Chicago IL 60	2019	Main	47913	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51160	Active School	Burley	Augustus H Burley Elementary Schoo	1630 W Barry AVENUE, Chicago IL	2019	Main	55812	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51160	Active School	Burley	Augustus H Burley Elementary Schoo	1630 W Barry AVENUE, Chicago IL	2019	Main	55812	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51510	Active School	Burnham @ Lawren	Burnham Elementary Inclusive Academi	9928 S Crandon AVENUE, Chicago	2019	Addition 3		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51510	Active School	Burnham @ Lawren	Burnham Elementary Inclusive Academi	9928 S Crandon AVENUE, Chicago	2019	Addition 3		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51461	Active School	Burnside	Burnside Elementary Scholastic Acad	650 E 91st PLACE, Chicago IL 606	2014	Addition 2	38272	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51461	Active School	Burnside	Burnside Elementary Scholastic Acad	650 E 91st PLACE, Chicago IL 606	2014	Addition 2	38272	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51133	Active School	Burr	Jonathan Burr Elementary School	1621 W Wabansia AVENUE, Chicag	2014	Main	60929	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51133	Active School	Burr	Jonathan Burr Elementary School	1621 W Wabansia AVENUE, Chicag	2014	Main	60929	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51263	Active School	Burroughs	John C Burroughs Elementary School	3542 S Washtenaw AVENUE, Chicz	2019	Main	49191	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51263	Active School	Burroughs	John C Burroughs Elementary School	3542 S Washtenaw AVENUE, Chicz	2019	Main	49191	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51289	Active School	Byrne	Michael M Byrne Elementary School	5329 S Oak Park AVENUE, Chicag	2019	Main	15864	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51289	Active School	Byrne	Michael M Byrne Elementary School	5329 S Oak Park AVENUE, Chicag	2019	Main	15864	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	51289	Active School	Byrne	Michael M Byrne Elementary School	5329 S Oak Park AVENUE, Chicag	2019	Addition 3	36830	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	51289	Active School	Byrne	Michael M Byrne Elementary School	5329 S Oak Park AVENUE, Chicag	2019	Addition 3	36830	Boiler Room	Condensing- Hot Water Boiler
1	QS-8B	51462	Active School	Caldwell	Charles P Caldwell Academy of Math	8546 S Cregier AVENUE, Chicago I	2019	Main	19933	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-8B	51462	Active School	Caldwell	Charles P Caldwell Academy of Math	8546 S Cregier AVENUE, Chicago I	2019	Main	19933	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-5B	51286	Active School	Calmecca Elementar	Calmecca Academy of Fine Arts and D	3456 W 38th STREET, Chicago IL 6	2019	Main	108624	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5B	51286	Active School	Calmecca Elementar	Calmecca Academy of Fine Arts and D	3456 W 38th STREET, Chicago IL 6	2019	Main	108624	Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51110	Active School	Cameron	Daniel R Cameron Elementary Schoo	1234 N Monticello AVENUE, Chicag	2014	Main	120281	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4A	51110	Active School	Cameron	Daniel R Cameron Elementary Schoo	1234 N Monticello AVENUE, Chicag	2014	Main	120281	Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51110	Active School	Cameron	Daniel R Cameron Elementary Schoo	1234 N Monticello AVENUE, Chicag	2014	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51110	Active School	Cameron	Daniel R Cameron Elementary Schoo	1234 N Monticello AVENUE, Chicag	2014	Annex		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	54764	Active School	Camras	Marvin Camras Elementary School	3000 N Mango AVENUE, Chicago II	2019	Main	98604	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	54764	Active School	Camras	Marvin Camras Elementary School	3000 N Mango AVENUE, Chicago II	2019	Main	98604	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51005	Active School	Canty	Arthur E Canty Elementary School	3740 N Panama AVENUE, Chicago	2019	Main	41329	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51005	Active School	Canty	Arthur E Canty Elementary School	3740 N Panama AVENUE, Chicago	2019	Main	41329	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51005	Active School	Canty	Arthur E Canty Elementary School	3740 N Panama AVENUE, Chicago	2019	Addition 3	39475	Entire Building	Condensing- Hot Water Boiler
1	QS-5A	51262	Active School	Cardenas	Lazaro Cardenas Elementary School	2524 S Central Park AVENUE, Chic	2019	Branch-Cardenas South		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51262	Active School	Cardenas	Lazaro Cardenas Elementary School	2524 S Central Park AVENUE, Chic	2019	Branch-Cardenas South		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51397	Active School	Carnegie	Andrew Carnegie Elementary School	1414 E 61st PLACE, Chicago IL 60	2019	Main	42735	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51397	Active School	Carnegie	Andrew Carnegie Elementary School	1414 E 61st PLACE, Chicago IL 60	2019	Main	42735	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Element	2929 W 83rd STREET, Chicago IL E	2019	Main	26642	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Element	2929 W 83rd STREET, Chicago IL E	2019	Main	26642	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Element	2929 W 83rd STREET, Chicago IL E	2019	Branch 1_Rosenwald		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Element	2929 W 83rd STREET, Chicago IL E	2019	Branch 1_Rosenwald		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Element	2929 W 83rd STREET, Chicago IL E	2019	Branch 2_Rosenwald Carroll		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Element	2929 W 83rd STREET, Chicago IL E	2019	Branch 2_Rosenwald Carroll		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	51317	Active School	Carson	Rachel Carson Elementary School	5516 S Maplewood AVENUE, Chica	2019	Main	62635	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51317	Active School	Carson	Rachel Carson Elementary School	5516 S Maplewood AVENUE, Chica	2019	Main	62635	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51317	Active School	Carson	Rachel Carson Elementary School	5516 S Maplewood AVENUE, Chica	2019	Annex	75380	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51317	Active School	Carson	Rachel Carson Elementary School	5516 S Maplewood AVENUE, Chica	2019	Annex	75380	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	51348	Active School	Carter	William W Carter Elementary School	5740 S Michigan AVENUE, Chicagc	2019	Main	60355	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51348	Active School	Carter	William W Carter Elementary School	5740 S Michigan AVENUE, Chicagc	2019	Main	60355	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51348	Active School	Carter	William W Carter Elementary School	5740 S Michigan AVENUE, Chicagc	2019	Main	60355	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S	901 E 133rd PLACE, Chicago IL 60	2019	Main-Bldg F	40250	Remote Building Boiler F	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S	901 E 133rd PLACE, Chicago IL 60	2019	Main-Bldg F	40250	Remote Building Boiler F	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler

1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S 901 E 133rd PLACE, Chicago IL 606	2019	Annex-Bldg A	16156	Mechanical Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S 901 E 133rd PLACE, Chicago IL 606	2019	Annex-Bldg A	16156	Mechanical Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S 901 E 133rd PLACE, Chicago IL 606	2019	Annex-Bldg B	14725	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S 901 E 133rd PLACE, Chicago IL 606	2019	Annex-Bldg B	14725	Boiler Room	Condensing- Hot Water Boiler
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S 901 E 133rd PLACE, Chicago IL 606	2019	Annex-Bldg D	19725	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9A	51499	Active School	Carver Primary Sch	George Washington Carver Primary S 901 E 133rd PLACE, Chicago IL 606	2019	Annex-Bldg D	19725	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4A	51117	Active School	Casals	Pablo Casals Elementary School 3501 W Potomac AVENUE, Chicago	2014	Main	66550	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51117	Active School	Casals	Pablo Casals Elementary School 3501 W Potomac AVENUE, Chicago	2014	Main	66550	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6B	51426	Active School	Cassell	George F Cassell Elementary School 11314 S Spaulding AVENUE, Chicago	2019	Main	16600	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51426	Active School	Cassell	George F Cassell Elementary School 11314 S Spaulding AVENUE, Chicago	2019	Main	16600	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2B	51194	Active School	Cather	Willa Cather Elementary School 2908 W Washington BOULEVARD, Chicago	2014	Main	52579	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-2B	51194	Active School	Cather	Willa Cather Elementary School 2908 W Washington BOULEVARD, Chicago	2014	Main	52579	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-2B	51199	Active School	Chalmers	Thomas Chalmers Specialty Element 2745 W Roosevelt ROAD, Chicago	2019	Main	56732	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2B	51199	Active School	Chalmers	Thomas Chalmers Specialty Element 2745 W Roosevelt ROAD, Chicago	2019	Main	56732	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51052	Active School	Chappell	Eliza Chappell Elementary School 2131 W Foster AVENUE, Chicago IL	2019	Main	21292	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51052	Active School	Chappell	Eliza Chappell Elementary School 2131 W Foster AVENUE, Chicago IL	2019	Main	21292	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51052	Active School	Chappell	Eliza Chappell Elementary School 2131 W Foster AVENUE, Chicago IL	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51052	Active School	Chappell	Eliza Chappell Elementary School 2131 W Foster AVENUE, Chicago IL	2019	Linked Addition		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3B	51111	Active School	Chase	Salmon P Chase Elementary School 2021 N Point STREET, Chicago IL 606	2014	Main	41959	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51111	Active School	Chase	Salmon P Chase Elementary School 2021 N Point STREET, Chicago IL 606	2014	Main	41959	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51111	Active School	Chase	Salmon P Chase Elementary School 2021 N Point STREET, Chicago IL 606	2014	Linked Addition		Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-3B	51111	Active School	Chase	Salmon P Chase Elementary School 2021 N Point STREET, Chicago IL 606	2014	Linked Addition		Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-5B	51330	Active School	Chavez	Cesar E Chavez Multicultural Academ 4747 S Marshfield AVENUE, Chicago	2019	Main	68408	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51330	Active School	Chavez	Cesar E Chavez Multicultural Academ 4747 S Marshfield AVENUE, Chicago	2019	Main	68408	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5B	51330	Active School	Chavez	Cesar E Chavez Multicultural Academ 4747 S Marshfield AVENUE, Chicago	2019	Leased-Branch		Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-5B	51330	Active School	Chavez	Cesar E Chavez Multicultural Academ 4747 S Marshfield AVENUE, Chicago	2019	Leased-Branch		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-1B	51041	Active School	Chicago Academy S	Chicago Academy Elementary School 3400 N Austin AVENUE, Chicago IL	2019	Leased-Main	231712	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51041	Active School	Chicago Academy S	Chicago Academy Elementary School 3400 N Austin AVENUE, Chicago IL	2019	Leased-Main	231712	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51634	Active School	Chicago Ag HS	Chicago High School for Agricultural S 3857 W 111th STREET, Chicago IL	2019	Main	17250	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51634	Active School	Chicago Ag HS	Chicago High School for Agricultural S 3857 W 111th STREET, Chicago IL	2019	Main	17250	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51634	Active School	Chicago Ag HS	Chicago High School for Agricultural S 3857 W 111th STREET, Chicago IL	2019	Addition	15000	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51634	Active School	Chicago Ag HS	Chicago High School for Agricultural S 3857 W 111th STREET, Chicago IL	2019	Addition	15000	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6B	51634	Active School	Chicago Ag HS	Chicago High School for Agricultural S 3857 W 111th STREET, Chicago IL	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51634	Active School	Chicago Ag HS	Chicago High School for Agricultural S 3857 W 111th STREET, Chicago IL	2019	Linked Addition		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8A	51589	Active School	Chicago Military HS	Chicago Military Academy High Schoc 3533 S Giles AVENUE, Chicago IL 606	2019	Main	68096	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51589	Active School	Chicago Military HS	Chicago Military Academy High Schoc 3533 S Giles AVENUE, Chicago IL 606	2019	Main	68096	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51589	Active School	Chicago Military HS	Chicago Military Academy High Schoc 3533 S Giles AVENUE, Chicago IL 606	2019	Main	68096	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	51625	Active School	Chicago Vocational	Chicago Vocational Career Academy I 2100 E 87th STREET, Chicago IL 606	2014	Main	521300	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8B	51625	Active School	Chicago Vocational	Chicago Vocational Career Academy I 2100 E 87th STREET, Chicago IL 606	2014	Main	521300	Boiler Room	Condensing- Hot Water Boiler
1	QS-8B	51625	Active School	Chicago Vocational	Chicago Vocational Career Academy I 2100 E 87th STREET, Chicago IL 606	2014	Annex-Hangar Buildi	26320	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-2B	51135	Active School	Chopin	Frederic Chopin Elementary School 2450 W Rice STREET, Chicago IL 606	2014	Main	96895	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-2B	51135	Active School	Chopin	Frederic Chopin Elementary School 2450 W Rice STREET, Chicago IL 606	2014	Main	96895	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51290	Active School	Christopher	Walter S Christopher Elementary Sch 5042 S Artesian AVENUE, Chicago	2019	Main	54500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51290	Active School	Christopher	Walter S Christopher Elementary Sch 5042 S Artesian AVENUE, Chicago	2019	Main	54500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51341	Active School	Claremont	Claremont Academy Elementary Schc 2300 W 64th STREET, Chicago IL 606	2019	Main	112806	Boiler Room	Non Condensing- Hot Water
1	QS-6A	51341	Active School	Claremont	Claremont Academy Elementary Schc 2300 W 64th STREET, Chicago IL 606	2019	Main	112806	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51086	Active School	Clark Elem	George Rogers Clark Elementary Sch 1045 S Monitor AVENUE, Chicago I	2014	Main	10900	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	51086	Active School	Clark Elem	George Rogers Clark Elementary Sch 1045 S Monitor AVENUE, Chicago I	2014	Main	10900	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51086	Active School	Clark Elem	George Rogers Clark Elementary Sch 1045 S Monitor AVENUE, Chicago I	2014	Addition	32700	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	51086	Active School	Clark Elem	George Rogers Clark Elementary Sch 1045 S Monitor AVENUE, Chicago I	2014	Addition	32700	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51502	Active School	Clay	Henry Clay Elementary School 13231 S Burley AVENUE, Chicago I	2019	Main	54590	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51502	Active School	Clay	Henry Clay Elementary School 13231 S Burley AVENUE, Chicago I	2019	Main	54590	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51006	Active School	Cleveland	Grover Cleveland Elementary School 3121 W Byron STREET, Chicago IL	2019	Main	93450	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51006	Active School	Cleveland	Grover Cleveland Elementary School 3121 W Byron STREET, Chicago IL	2019	Main	93450	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51053	Active School	Clinton	DeWitt Clinton Elementary School 6110 N Fairfield AVENUE, Chicago	2019	Main	79104	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51053	Active School	Clinton	DeWitt Clinton Elementary School 6110 N Fairfield AVENUE, Chicago	2019	Main	79104	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51053	Active School	Clinton	DeWitt Clinton Elementary School 6110 N Fairfield AVENUE, Chicago	2019	Addition 2	34416	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51053	Active School	Clinton	DeWitt Clinton Elementary School 6110 N Fairfield AVENUE, Chicago	2019	Addition 2	34416	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51427	Active School	Clissold	Henry R Clissold Elementary School 2350 W 110th PLACE, Chicago IL 6	2019	Main	59069	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6B	51427	Active School	Clissold	Henry R Clissold Elementary School 2350 W 110th PLACE, Chicago IL 6	2019	Main	59069	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51429	Active School	Coleman	Johnnie Coleman Elementary Acaden 1441 W 119th STREET, Chicago IL	2019	Main	34600	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9A	51519	Active School	Coleman	Johnnie Coleman Elementary Acaden 1441 W 119th STREET, Chicago IL	2019	Main	34600	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	51463	Active School	Coles	Edward Coles Elementary Language / 8442 S Phillips AVENUE, Chicago I	2014	Main	66649	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51463	Active School	Coles	Edward Coles Elementary Language / 8442 S Phillips AVENUE, Chicago I	2014	Main	66649	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51279	Active School	Columbia Explorers	Columbia Explorers Elementary Acad 4520 S Kedzie AVENUE, Chicago IL	2019	Main	83500	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51279	Active School	Columbia Explorers	Columbia Explorers Elementary Acad 4520 S Kedzie AVENUE, Chicago IL	2019	Main	83500	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2B	51136	Active School	Columbus	Christopher Columbus Elementary Sc 1003 N Leavitt STREET, Chicago IL	2014	Main	31872	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51136	Active School	Columbus	Christopher Columbus Elementary Sc 1003 N Leavitt STREET, Chicago IL	2014	Main	31872	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51428	Active School	Cook Elementary Sc	John W Cook Elementary School 8150 S Bishop STREET, Chicago IL	2019	Main	66070	Mechanical Building/Cen	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51428	Active School	Cook Elementary Sc	John W Cook Elementary School 8150 S Bishop STREET, Chicago IL	2019	Main	66070	Mechanical Building/Cen	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51055	Active School	Coonley	John C Coonley Elementary School 4046 N Leavitt STREET, Chicago IL	2019	Main	66959	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51055	Active School	Coonley	John C Coonley Elementary School 4046 N Leavitt STREET, Chicago IL	2019	Main	66959	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler

1	QS-5A	51232	Active School	Cooper	Peter Cooper Elementary Dual Langu	1624 W 19th STREET, Chicago IL 6	2019	Main	59400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51232	Active School	Cooper	Peter Cooper Elementary Dual Langu	1624 W 19th STREET, Chicago IL 6	2019	Main	59400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51232	Active School	Cooper	Peter Cooper Elementary Dual Langu	1624 W 19th STREET, Chicago IL 6	2019	Annex	71800	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5A	51232	Active School	Cooper	Peter Cooper Elementary Dual Langu	1624 W 19th STREET, Chicago IL 6	2019	Annex	71800	Boiler Room	Condensing- Hot Water Boiler
1	QS-7A	51318	Active School	Copernicus	Anna R. Langford Community Acaden	6010 S Throop STREET, Chicago IL	2019	Main	78575	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51318	Active School	Copernicus	Anna R. Langford Community Acaden	6010 S Throop STREET, Chicago IL	2019	Main	78575	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51318	Active School	Copernicus	Anna R. Langford Community Acaden	6010 S Throop STREET, Chicago IL	2019	Main	78575	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51318	Active School	Copernicus	Anna R. Langford Community Acaden	6010 S Throop STREET, Chicago IL	2019	Main	78575	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51265	Active School	Corkery	Daniel J Corkery Elementary School	2510 S Kildare AVENUE, Chicago II	2019	Main	67120	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51265	Active School	Corkery	Daniel J Corkery Elementary School	2510 S Kildare AVENUE, Chicago II	2019	Main	67120	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	51564	Active School	Crane HS	Richard T Crane Medical Preparatory	2245 W Jackson BOULEVARD, Chi	2019	Main	371560	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51564	Active School	Crane HS	Richard T Crane Medical Preparatory	2245 W Jackson BOULEVARD, Chi	2019	Main	371560	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51200	Active School	Crown	Crown Community Academy of Fine A	2128 S Saint Louis AVENUE, Chica	2019	Main	63352	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-4A	51200	Active School	Crown	Crown Community Academy of Fine A	2128 S Saint Louis AVENUE, Chica	2019	Main	63352	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-7B	51436	Active School	Cuffe	Paul Cuffe Math-Science Technology	8324 S Racine AVENUE, Chicago II	2014	Main	82120	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51436	Active School	Cuffe	Paul Cuffe Math-Science Technology	8324 S Racine AVENUE, Chicago II	2014	Main	82120	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9A	51430	Active School	Curtis	George W Curtis Elementary School	11445 S State STREET, Chicago IL	2019	Main	61030	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51430	Active School	Curtis	George W Curtis Elementary School	11445 S State STREET, Chicago IL	2019	Main	61030	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51334	Active School	Daley	Richard J Daley Elementary Academy	5024 S Wolcott AVENUE, Chicago I	2019	Main	73350	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51334	Active School	Daley	Richard J Daley Elementary Academy	5024 S Wolcott AVENUE, Chicago I	2019	Main	73350	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3B	51112	Active School	Darwin	Charles R Darwin Elementary School	3116 W Belden AVENUE, Chicago I	2019	Main	61807	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51112	Active School	Darwin	Charles R Darwin Elementary School	3116 W Belden AVENUE, Chicago I	2019	Main	61807	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	54217	Active School	Davis M Magnet	Sir Miles Davis Magnet Elementary Ac	6740 S Paulina STREET, Chicago II	2014	Main	104200	3rd floor Mechanical Roc	Boiler Auxiliary- Condensing Hot Water
1	QS-7A	54217	Active School	Davis M Magnet	Sir Miles Davis Magnet Elementary Ac	6740 S Paulina STREET, Chicago II	2014	Main	104200	3rd floor Mechanical Roc	Condensing- Hot Water Boiler
1	QS-5B	51266	Active School	Davis N	Nathan S Davis Elementary School	3014 W 39th PLACE, Chicago IL 60	2019	Main	45675	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51266	Active School	Davis N	Nathan S Davis Elementary School	3014 W 39th PLACE, Chicago IL 60	2019	Main	45675	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51266	Active School	Davis N	Nathan S Davis Elementary School	3014 W 39th PLACE, Chicago IL 60	2019	Main	45675	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51266	Active School	Davis N	Nathan S Davis Elementary School	3014 W 39th PLACE, Chicago IL 60	2019	Annex	34018	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51266	Active School	Davis N	Nathan S Davis Elementary School	3014 W 39th PLACE, Chicago IL 60	2019	Annex	34018	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6B	51291	Active School	Dawes	Charles Gates Dawes Elementary Sch	3810 W 81st PLACE, Chicago IL 60	2019	Main	70461	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51291	Active School	Dawes	Charles Gates Dawes Elementary Sch	3810 W 81st PLACE, Chicago IL 60	2019	Main	70461	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51151	Active School	De Diego	Jose De Diego Elementary Communit	1313 N Claremont AVENUE, Chica	2014	Main	175571	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51151	Active School	De Diego	Jose De Diego Elementary Communit	1313 N Claremont AVENUE, Chica	2014	Main	175571	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51271	Active School	De Dominguez	Josefa Ortiz De Dominguez Elementa	3000 S Lawndale AVENUE, Chicag	2014	Main	63900	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51271	Active School	De Dominguez	Josefa Ortiz De Dominguez Elementa	3000 S Lawndale AVENUE, Chicag	2014	Main	63900	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1A	51056	Active School	Decatur	Stephen Decatur Classical Elementar	7030 N Sacramento AVENUE, Chic	2019	Main	23834	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51056	Active School	Decatur	Stephen Decatur Classical Elementar	7030 N Sacramento AVENUE, Chic	2019	Main	23834	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51182	Active School	Delano	Genevieve Melody Elementary Schoo	3937 W Wilcox STREET, Chicago II	2019	Main	60600	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51182	Active School	Delano	Genevieve Melody Elementary Schoo	3937 W Wilcox STREET, Chicago II	2019	Main	60600	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51182	Active School	Delano	Genevieve Melody Elementary Schoo	3937 W Wilcox STREET, Chicago II	2019	Addition	26320	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51182	Active School	Delano	Genevieve Melody Elementary Schoo	3937 W Wilcox STREET, Chicago II	2019	Addition	26320	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-7A	51377	Active School	Deneen	Charles S Deneen Elementary School	7240 S Wabash AVENUE, Chicago	2019	Main	33076	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51377	Active School	Deneen	Charles S Deneen Elementary School	7240 S Wabash AVENUE, Chicago	2019	Main	33076	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51107	Active School	Depriest	Oscar DePriest Elementary School	139 S Parkside AVENUE, Chicago I	2019	Main	106650	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51107	Active School	Depriest	Oscar DePriest Elementary School	139 S Parkside AVENUE, Chicago I	2019	Main	106650	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51008	Active School	Dever	William E Dever Elementary School	3436 N Osceola AVENUE, Chicago	2019	Main	38530	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51008	Active School	Dever	William E Dever Elementary School	3436 N Osceola AVENUE, Chicago	2019	Main	38530	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51349	Active School	Dewey	Dewey Elementary Academy of Fine	5415 S Union AVENUE, Chicago IL	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51349	Active School	Dewey	Dewey Elementary Academy of Fine	5415 S Union AVENUE, Chicago IL	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51019	Active School	Disney II (Irving Parl	Disney II Magnet School	3815 N Kedvale AVENUE, Chicago	2019	Main	50560	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1A	51019	Active School	Disney II (Irving Parl	Disney II Magnet School	3815 N Kedvale AVENUE, Chicago	2019	Main	50560	Boiler Room	Condensing- Hot Water Boiler
1	QS-7B	51464	Active School	Dixon	Arthur Dixon Elementary School	8306 S Saint Lawrence AVENUE, C	2014	Main	101627	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7B	51464	Active School	Dixon	Arthur Dixon Elementary School	8306 S Saint Lawrence AVENUE, C	2014	Main	101627	Boiler Room	Condensing- Hot Water Boiler
1	QS-8A	51613	Active School	Donoghue	University of Chicago - Donoghue	707 E 37th STREET, Chicago IL 60	2019	Main	74828	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51613	Active School	Donoghue	University of Chicago - Donoghue	707 E 37th STREET, Chicago IL 60	2019	Main	74828	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	52300	Active School	Doolittle East	James R Doolittle Jr Elementary Sch	521 E 35th STREET, Chicago IL 60	2014	Annex (Urban Prep)		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	52300	Active School	Doolittle East	James R Doolittle Jr Elementary Sch	521 E 35th STREET, Chicago IL 60	2014	Annex (Urban Prep)		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 6	2019	Main		Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 6	2019	Main		Boiler Room	Condensing- Hot Water Boiler
1	QS-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 6	2019	Branch-Old-Linked Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 6	2019	Branch-Old-Linked Addition		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 6	2019	Branch-Old-Main		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 6	2019	Branch-Old-Main		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2B	51137	Active School	Drummond	Thomas Drummond Elementary Scho	1845 W Cortland STREET, Chicago	2019	Main	47500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51137	Active School	Drummond	Thomas Drummond Elementary Scho	1845 W Cortland STREET, Chicago	2019	Main	47500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51137	Active School	Drummond	Thomas Drummond Elementary Scho	1845 W Cortland STREET, Chicago	2019	Main	47500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51137	Active School	Drummond	Thomas Drummond Elementary Scho	1845 W Cortland STREET, Chicago	2019	Main	47500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51580	Active School	DuSable	Bronzeville Scholastic Academy High	4934 S Wabash AVENUE, Chicago	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51580	Active School	DuSable	Bronzeville Scholastic Academy High	4934 S Wabash AVENUE, Chicago	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51580	Active School	DuSable	Bronzeville Scholastic Academy High	4934 S Wabash AVENUE, Chicago	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51580	Active School	DuSable	Bronzeville Scholastic Academy High	4934 S Wabash AVENUE, Chicago	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51580	Active School	DuSable	Bronzeville Scholastic Academy High	4934 S Wabash AVENUE, Chicago	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51526	Active School	Dubois	William E B Dubois Elementary Schoc	330 E 133rd STREET, Chicago IL 6	2019	Main	27248	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water

1	QS-9A	51526	Active School	Dubois	William E B Dubois Elementary Schoc 330 E 133rd STREET, Chicago IL 6	2019	Main	27248	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	51417	Active School	Dulles	John Foster Dulles Elementary School 6311 S Calumet AVENUE, Chicago	2019	Main	70786	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51417	Active School	Dulles	John Foster Dulles Elementary School 6311 S Calumet AVENUE, Chicago	2019	Main	70786	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51418	Active School	Dumas	James Wadsworth Elementary School 6650 S Ellis AVENUE, Chicago IL 6	2019	Main	64558	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8B	51418	Active School	Dumas	James Wadsworth Elementary School 6650 S Ellis AVENUE, Chicago IL 6	2019	Main	64558	Boiler Room	Condensing- Hot Water Boiler
1	QS-8B	51418	Active School	Dumas	James Wadsworth Elementary School 6650 S Ellis AVENUE, Chicago IL 6	2019	Main	64558	Boiler Room	Condensing- Hot Water Boiler
1	QS-8B	51578	Active School	Dunbar HS	Paul Laurence Dunbar Career Acader 3000 S King DRIVE, Chicago IL 60	2014	Main	319937	Basement	Boiler Auxiliary- Steam Boiler
1	QS-8B	51578	Active School	Dunbar HS	Paul Laurence Dunbar Career Acader 3000 S King DRIVE, Chicago IL 60	2014	Main	319937	Basement	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-8B	51578	Active School	Dunbar HS	Paul Laurence Dunbar Career Acader 3000 S King DRIVE, Chicago IL 60	2014	Main	319937	Mechanical Building/Cen	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51578	Active School	Dunbar HS	Paul Laurence Dunbar Career Acader 3000 S King DRIVE, Chicago IL 60	2014	Main	319937	Mechanical Building/Cen	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51446	Active School	Dunne	Dunne Technology Academy 10845 S Union AVENUE Chicago IL	2014	Main - demoed		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51446	Active School	Dunne	Dunne Technology Academy 10845 S Union AVENUE Chicago IL	2014	Main - demoed		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51314	Active School	Durkin Park	Durkin Park Elementary School 8445 S Kolin AVENUE, Chicago IL 6	2019	Main	39928	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51314	Active School	Durkin Park	Durkin Park Elementary School 8445 S Kolin AVENUE, Chicago IL 6	2019	Main	39928	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6B	51314	Active School	Durkin Park	Durkin Park Elementary School 8445 S Kolin AVENUE, Chicago IL 6	2019	Linked Addition 2		Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	51314	Active School	Durkin Park	Durkin Park Elementary School 8445 S Kolin AVENUE, Chicago IL 6	2019	Linked Addition 2		Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51218	Active School	Dvorak	Dvorak Technology Academy 3615 W 16th STREET, Chicago IL 6	2019	Main	69287	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4A	51218	Active School	Dvorak	Dvorak Technology Academy 3615 W 16th STREET, Chicago IL 6	2019	Main	69287	Boiler Room	Condensing- Hot Water Boiler
1	QS-8A	51585	Active School	Dyett	Walter Henri Dyett High School for the 555 E 51st STREET, Chicago IL 60	2019	Main	120706	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51585	Active School	Dyett	Walter Henri Dyett High School for the 555 E 51st STREET, Chicago IL 60	2019	Main	120706	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9B	51490	Active School	Earhart	Amelia Earhart Options for Knowledge 1710 E 93rd STREET, Chicago IL 6	2019	Main	13080	Entire Building	Boiler Auxiliary- Steam Boiler
1	QS-9B	51490	Active School	Earhart	Amelia Earhart Options for Knowledge 1710 E 93rd STREET, Chicago IL 6	2019	Main	13080	Entire Building	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-9B	51490	Active School	Earhart	Amelia Earhart Options for Knowledge 1710 E 93rd STREET, Chicago IL 6	2019	Addition 2	11635	Entire Building	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51490	Active School	Earhart	Amelia Earhart Options for Knowledge 1710 E 93rd STREET, Chicago IL 6	2019	Addition 2	11635	Entire Building	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6A	51293	Active School	Eberhart	John F Eberhart Elementary School 3400 W 65th PLACE, Chicago IL 60	2014	Main	78703	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51293	Active School	Eberhart	John F Eberhart Elementary School 3400 W 65th PLACE, Chicago IL 60	2014	Main	78703	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51293	Active School	Eberhart	John F Eberhart Elementary School 3400 W 65th PLACE, Chicago IL 60	2014	Main	78703	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51293	Active School	Eberhart	John F Eberhart Elementary School 3400 W 65th PLACE, Chicago IL 60	2014	Addition	81635	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51293	Active School	Eberhart	John F Eberhart Elementary School 3400 W 65th PLACE, Chicago IL 60	2014	Addition	81635	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-1B	51009	Active School	Ebinger	Christian Ebinger Elementary School 7350 W Pratt AVENUE, Chicago IL 1	2014	Main	61518	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51009	Active School	Ebinger	Christian Ebinger Elementary School 7350 W Pratt AVENUE, Chicago IL 1	2014	Main	61518	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51010	Active School	Ebinger	Christian Ebinger Elementary School 7350 W Pratt AVENUE, Chicago IL 1	2014	Main	61518	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51010	Active School	Edgebrook	Edgebrook Elementary School 6525 N Hiawatha AVENUE, Chicago	2019	Main	18347	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51010	Active School	Edgebrook	Edgebrook Elementary School 6525 N Hiawatha AVENUE, Chicago	2019	Main	18347	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51010	Active School	Edgebrook	Edgebrook Elementary School 6525 N Hiawatha AVENUE, Chicago	2019	Main	18347	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51010	Active School	Edgebrook	Edgebrook Elementary School 6525 N Hiawatha AVENUE, Chicago	2019	Main	18347	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51010	Active School	Edgebrook	Edgebrook Elementary School 6525 N Hiawatha AVENUE, Chicago	2019	Addition 3	35298	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51010	Active School	Edgebrook	Edgebrook Elementary School 6525 N Hiawatha AVENUE, Chicago	2019	Addition 3	35298	Boiler Room	Condensing- Hot Water Boiler
1	QS-1B	51001	Active School	Edison Park	Edison Park Elementary School 6220 N Olcott AVENUE, Chicago IL	2019	Main	34423	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-1B	51001	Active School	Edison Park	Edison Park Elementary School 6220 N Olcott AVENUE, Chicago IL	2019	Main	34423	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-1B	51001	Active School	Edison Park	Edison Park Elementary School 6220 N Olcott AVENUE, Chicago IL	2019	Addition	26052	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51001	Active School	Edison Park	Edison Park Elementary School 6220 N Olcott AVENUE, Chicago IL	2019	Addition	26052	Mechanical Room	Condensing- Hot Water Boiler
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Main	81150	Mechanical Building/Cen	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Main	81150	Mechanical Building/Cen	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Addition 2	50193	Mechanical Room	Condensing- Hot Water Boiler
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Branch		Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-5B	51294	Active School	Edwards	Richard Edwards Elementary School 4815 S Karlov AVENUE, Chicago IL	2019	Branch		Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-3A	54725	Active School	Ellington Elementary	Edward K Ellington Elementary Schoc 243 N Parkside AVENUE, Chicago I	2014	Main	112380	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	54725	Active School	Ellington Elementary	Edward K Ellington Elementary Schoc 243 N Parkside AVENUE, Chicago I	2014	Main	112380	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4A	51201	Active School	Ericson	Leif Ericson Elementary Scholastic Ac 3600 W 5th AVENUE, Chicago IL 6	2014	Main	74410	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-4A	51201	Active School	Ericson	Leif Ericson Elementary Scholastic Ac 3600 W 5th AVENUE, Chicago IL 6	2014	Main	74410	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-6B	51431	Active School	Esmond	Esmond Elementary School 1865 W Montvale AVENUE, Chicago	2019	Main	16300	Basement	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51431	Active School	Esmond	Esmond Elementary School 1865 W Montvale AVENUE, Chicago	2019	Main	16300	Basement	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51431	Active School	Esmond	Esmond Elementary School 1865 W Montvale AVENUE, Chicago	2019	Addition 2	20000	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	51431	Active School	Esmond	Esmond Elementary School 1865 W Montvale AVENUE, Chicago	2019	Addition 2	20000	Boiler Room	Condensing- Hot Water Boiler
1	QS-5B	51267	Active School	Everett	Edward Everett Elementary School 3419 S Bell AVENUE, Chicago IL 6	2019	Main	47850	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51267	Active School	Everett	Edward Everett Elementary School 3419 S Bell AVENUE, Chicago IL 6	2019	Main	47850	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51267	Active School	Everett	Edward Everett Elementary School 3419 S Bell AVENUE, Chicago IL 6	2019	Main	47850	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51267	Active School	Everett	Edward Everett Elementary School 3419 S Bell AVENUE, Chicago IL 6	2019	Main	47850	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51340	Active School	Evergreen	Evergreen Academy Middle School 3537 S Paulina STREET, Chicago IL	2014	Main	50060	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-5B	51340	Active School	Evergreen	Evergreen Academy Middle School 3537 S Paulina STREET, Chicago IL	2014	Main	50060	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-7B	51451	Active School	Evers	Medgar Evers Elementary School 9811 S Lowe AVENUE, Chicago IL 6	2019	Main	52968	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7B	51451	Active School	Evers	Medgar Evers Elementary School 9811 S Lowe AVENUE, Chicago IL 6	2019	Main	52968	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7B	51451	Active School	Evers	Medgar Evers Elementary School 9811 S Lowe AVENUE, Chicago IL 6	2019	Main	52968	Boiler Room	Condensing- Hot Water Boiler
1	QS-3A	51011	Active School	Falconer	Laughlin Falconer Elementary School 3020 N Lamon AVENUE, Chicago IL	2019	Main	82716	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51011	Active School	Falconer	Laughlin Falconer Elementary School 3020 N Lamon AVENUE, Chicago IL	2019	Main	82716	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51011	Active School	Falconer	Laughlin Falconer Elementary School 3020 N Lamon AVENUE, Chicago IL	2019	Main	82716	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51011	Active School	Falconer	Laughlin Falconer Elementary School 3020 N Lamon AVENUE, Chicago IL	2019	Addition	82797	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51011	Active School	Falconer	Laughlin Falconer Elementary School 3020 N Lamon AVENUE, Chicago IL	2019	Addition	82797	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2B	51189	Active School	Faraday	Michael Faraday Elementary School 3250 W Monroe STREET, Chicago	2019	Main	61645	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler

1	QS-2B	51189	Active School	Faraday	Michael Faraday Elementary School	3250 W Monroe STREET, Chicago	2019	Main	61645	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51012	Active School	Farnsworth	James B Farnsworth Elementary Sch	5414 N Linder AVENUE, Chicago IL	2019	Main	76762	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51012	Active School	Farnsworth	James B Farnsworth Elementary Sch	5414 N Linder AVENUE, Chicago IL	2019	Main	76762	Boiler Room	Condensing- Hot Water Boiler
1	QS-9A	51628	Active School	Fenger HS	Christian Fenger Academy High Scho	11220 S Wallace STREET, Chicago	2019	Main	341000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51628	Active School	Fenger HS	Christian Fenger Academy High Scho	11220 S Wallace STREET, Chicago	2019	Main	341000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51628	Active School	Fenger HS	Christian Fenger Academy High Scho	11220 S Wallace STREET, Chicago	2019	Main	341000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51628	Active School	Fenger HS	Christian Fenger Academy High Scho	11220 S Wallace STREET, Chicago	2019	Main	341000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51628	Active School	Fenger HS	Christian Fenger Academy High Scho	11220 S Wallace STREET, Chicago	2019	Main	341000	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water Boiler
1	QS-9A	51628	Active School	Fenger HS	Christian Fenger Academy High Scho	11220 S Wallace STREET, Chicago	2019	Main	341000	Mechanical Room	Non Condensing- Cast Iron- Atmospheric- Hot Water Boiler
1	QS-8B	51399	Active School	Fermi	South Shore Fine Arts Academy	1415 E 70th STREET, Chicago IL 6t	2019	Main	76945	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51399	Active School	Fermi	South Shore Fine Arts Academy	1415 E 70th STREET, Chicago IL 6t	2019	Main	76945	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51432	Active School	Fernwood	Fernwood Elementary School	10041 S Union AVENUE, Chicago IL	2014	Main	31180	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51432	Active School	Fernwood	Fernwood Elementary School	10041 S Union AVENUE, Chicago IL	2014	Main	31180	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51057	Active School	Field	Eugene Field Elementary School	7019 N Ashland AVENUE, Chicago	2019	Addition 1	49713	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51057	Active School	Field	Eugene Field Elementary School	7019 N Ashland AVENUE, Chicago	2019	Addition 1	49713	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51273	Active School	Finkl	William F Finkl Elementary School	2332 S Western AVENUE, Chicago	2014	Main	71980	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51273	Active School	Finkl	William F Finkl Elementary School	2332 S Western AVENUE, Chicago	2014	Main	71980	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51532	Active School	Foreman HS	Edwin G. Foreman College and Caree	3235 N LeClaire AVENUE, Chicago	2014	Main	221236	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51532	Active School	Foreman HS	Edwin G. Foreman College and Caree	3235 N LeClaire AVENUE, Chicago	2014	Main	221236	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51532	Active School	Foreman HS	Edwin G. Foreman College and Caree	3235 N LeClaire AVENUE, Chicago	2014	Main	221236	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51532	Active School	Foreman HS	Edwin G. Foreman College and Caree	3235 N LeClaire AVENUE, Chicago	2014	Main	221236	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51433	Active School	Fort Dearborn	Fort Dearborn Elementary School	9025 S Throop STREET, Chicago IL	2019	Main	65765	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51433	Active School	Fort Dearborn	Fort Dearborn Elementary School	9025 S Throop STREET, Chicago IL	2019	Main	65765	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51434	Active School	Foster Park	Foster Park Elementary School	8530 S Wood STREET, Chicago IL	2014	Main	17910	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51434	Active School	Foster Park	Foster Park Elementary School	8530 S Wood STREET, Chicago IL	2014	Main	17910	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3B	51161	Active School	Franklin	Franklin Elementary Fine Arts Center	225 W Evergreen AVENUE, Chicago	2019	Main	53097	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51161	Active School	Franklin	Franklin Elementary Fine Arts Center	225 W Evergreen AVENUE, Chicago	2019	Main	53097	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51222	Active School	FrazierMultiplex Bui	Frazier Prospective IB Magnet ES	4027 W Greshaw STREET, Chicag	2014	Main	72000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51222	Active School	FrazierMultiplex Bui	Frazier Prospective IB Magnet ES	4027 W Greshaw STREET, Chicag	2014	Main	72000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51351	Active School	Fuller	Melville W Fuller Elementary School	4214 S St Lawrence AVENUE, Chic	2014	Main	91800	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51351	Active School	Fuller	Melville W Fuller Elementary School	4214 S St Lawrence AVENUE, Chic	2014	Main	91800	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51321	Active School	Fulton	Robert Fulton Elementary School	5300 S Hermitage AVENUE, Chicag	2019	Main	75628	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51321	Active School	Fulton	Robert Fulton Elementary School	5300 S Hermitage AVENUE, Chicag	2019	Main	75628	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51114	Active School	Funston	Frederick Funston Elementary School	2010 N Central Park AVENUE, Chic	2014	Main	53265	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51114	Active School	Funston	Frederick Funston Elementary School	2010 N Central Park AVENUE, Chic	2014	Main	53265	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51114	Active School	Funston	Frederick Funston Elementary School	2010 N Central Park AVENUE, Chic	2014	Linked Addition		Entire Building	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3B	51114	Active School	Funston	Frederick Funston Elementary School	2010 N Central Park AVENUE, Chic	2014	Linked Addition		Entire Building	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5B	51609	Active School	Gage Park HS	Gage Park High School	5630 S Rockwell STREET, Chicago	2019	Main	219411	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51609	Active School	Gage Park HS	Gage Park High School	5630 S Rockwell STREET, Chicago	2019	Main	219411	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51609	Active School	Gage Park HS	Gage Park High School	5630 S Rockwell STREET, Chicago	2019	Main	219411	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51609	Active School	Gage Park HS	Gage Park High School	5630 S Rockwell STREET, Chicago	2019	Main	219411	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51058	Active School	Gale	Stephen F Gale Elementary Commu	1631 W Jonquil TERRACE, Chicag	2019	Main	91665	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51058	Active School	Gale	Stephen F Gale Elementary Commu	1631 W Jonquil TERRACE, Chicag	2019	Main	91665	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51058	Active School	Gale	Stephen F Gale Elementary Commu	1631 W Jonquil TERRACE, Chicag	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51058	Active School	Gale	Stephen F Gale Elementary Commu	1631 W Jonquil TERRACE, Chicag	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4B	51240	Active School	Galileo	Galileo Math & Science Scholastic Ac	820 S Carpenter STREET, Chicago	2019	Main	42469	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51240	Active School	Galileo	Galileo Math & Science Scholastic Ac	820 S Carpenter STREET, Chicago	2019	Main	42469	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51505	Active School	Gallistel Language #	Matthew Gallistel Elementary Langua	10347 S Ewing AVENUE, Chicago I	2014	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51505	Active School	Gallistel Language #	Matthew Gallistel Elementary Langua	10347 S Ewing AVENUE, Chicago I	2014	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51505	Active School	Gallistel Language #	Matthew Gallistel Elementary Langua	10347 S Ewing AVENUE, Chicago I	2014	1		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51505	Active School	Gallistel Language #	Matthew Gallistel Elementary Langua	10347 S Ewing AVENUE, Chicago I	2014	1		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51013	Active School	Garvy J	John W Garvy Elementary School	5225 N Oak Park AVENUE, Chicag	2019	Main	26875	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51013	Active School	Garvy J	John W Garvy Elementary School	5225 N Oak Park AVENUE, Chicag	2019	Main	26875	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51013	Active School	Garvy J	John W Garvy Elementary School	5225 N Oak Park AVENUE, Chicag	2019	Addition 2		Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51013	Active School	Garvy J	John W Garvy Elementary School	5225 N Oak Park AVENUE, Chicag	2019	Addition 2		Mechanical Room	Condensing- Hot Water Boiler
1	QS-5A	51270	Active School	Gary	Joseph E Gary Elementary School	3740 W 31st STREET, Chicago IL 6	2014	Main	92770	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51270	Active School	Gary	Joseph E Gary Elementary School	3740 W 31st STREET, Chicago IL 6	2014	Main	92770	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	54663	Active School	George Westinghou	George Westinghouse College Prep	3223 W Franklin BOULEVARD, Chi	2014	Main	224604	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4A	54663	Active School	George Westinghou	George Westinghouse College Prep	3223 W Franklin BOULEVARD, Chi	2014	Main	224604	Boiler Room	Condensing- Hot Water Boiler
1	QS-9B	51466	Active School	Gillespie	Frank L Gillespie Elementary School	9301 S State STREET, Chicago IL 6	2014	Main	60700	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51466	Active School	Gillespie	Frank L Gillespie Elementary School	9301 S State STREET, Chicago IL 6	2014	Main	60700	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51115	Active School	Goethe Elementary	Johann W von Goethe Elementary Sc	2236 N Rockwell STREET, Chicago	2014	Main	57508	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51115	Active School	Goethe Elementary	Johann W von Goethe Elementary Sc	2236 N Rockwell STREET, Chicago	2014	Main	57508	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	54793	Active School	Goode HS	Sarah E. Goode STEM Academy	7651 S Homan AVENUE, Chicago IL	2014	Main	208200	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	54793	Active School	Goode HS	Sarah E. Goode STEM Academy	7651 S Homan AVENUE, Chicago IL	2014	Main	208200	Boiler Room	Condensing- Hot Water Boiler
1	QS-7A	51320	Active School	Goodlow	Charles W Earle Elementary School	2040 W 62nd STREET, Chicago IL 6	2019	Main	67506	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7A	51320	Active School	Goodlow	Charles W Earle Elementary School	2040 W 62nd STREET, Chicago IL 6	2019	Main	67506	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2A	51059	Active School	Goudy	William C. Goudy Technology Acader	5120 N Winthrop AVENUE, Chicagc	2019	Main	48127	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51059	Active School	Goudy	William C. Goudy Technology Acader	5120 N Winthrop AVENUE, Chicagc	2019	Main	48127	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51059	Active School	Goudy	William C. Goudy Technology Acader	5120 N Winthrop AVENUE, Chicagc	2019	Addition 2		Entire Building	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51059	Active School	Goudy	William C. Goudy Technology Acader	5120 N Winthrop AVENUE, Chicagc	2019	Addition 2		Entire Building	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4B	51352	Active School	Graham Elem	Alexander Graham Elementary Schoc	4436 S Union AVENUE, Chicago IL	2019	Main	73500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51352	Active School	Graham Elem	Alexander Graham Elementary Schoc	4436 S Union AVENUE, Chicago IL	2019	Main	73500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler

1	QS-1B	51014	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, Chicago	2019	Main	67435	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51014	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, Chicago	2019	Main	67435	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51014	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, Chicago	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51014	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, Chicago	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51014	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, Chicago	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51014	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, Chicago	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51051	Active School	Greeley	Horace Greeley Elementary School	832 W Sheridan ROAD, Chicago IL	2019	Main	60718	Boiler Room	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-2A	51051	Active School	Greeley	Horace Greeley Elementary School	832 W Sheridan ROAD, Chicago IL	2019	Main	60718	Boiler Room	Electric- Hot Water Boiler
1	QS-5B	51323	Active School	Greene N	Nathanael Greene Elementary School	3525 S Honore STREET, Chicago II	2019	Main	82455	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51323	Active School	Greene N	Nathanael Greene Elementary School	3525 S Honore STREET, Chicago II	2019	Main	82455	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4A	51203	Active School	Gregory	John Milton Gregory Elementary Schc	3715 W Polk STREET, Chicago IL 6	2014	Main	85100	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51203	Active School	Gregory	John Milton Gregory Elementary Schc	3715 W Polk STREET, Chicago IL 6	2014	Main	85100	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51435	Active School	Gresham	Walter Q Gresham Elementary Schoo	8524 S Green STREET, Chicago IL	2019	Main	41588	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51435	Active School	Gresham	Walter Q Gresham Elementary Schoo	8524 S Green STREET, Chicago IL	2019	Main	41588	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51435	Active School	Gresham	Walter Q Gresham Elementary Schoo	8524 S Green STREET, Chicago IL	2019	Addition 2	48387	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51435	Active School	Gresham	Walter Q Gresham Elementary Schoo	8524 S Green STREET, Chicago IL	2019	Addition 2	48387	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	51295	Active School	Grimes	Robert L Grimes Elementary School	5450 W 64th PLACE, Chicago IL 60	2019	Main	12302	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-6A	51295	Active School	Grimes	Robert L Grimes Elementary School	5450 W 64th PLACE, Chicago IL 60	2019	Main	12302	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Atmospheric- Steam Boiler
1	QS-6A	51295	Active School	Grimes	Robert L Grimes Elementary School	5450 W 64th PLACE, Chicago IL 60	2019	Branch-Fleming		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51295	Active School	Grimes	Robert L Grimes Elementary School	5450 W 64th PLACE, Chicago IL 60	2019	Branch-Fleming		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51507	Active School	Grissom	Virgil Grissom Elementary School	12810 S Escanaba AVENUE, Chica	2019	Main	29878	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51507	Active School	Grissom	Virgil Grissom Elementary School	12810 S Escanaba AVENUE, Chica	2019	Main	29878	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5B	51272	Active School	Gunsaulus	Frank W Gunsaulus Elementary Scho	4420 S Sacramento AVENUE, Chic	2019	Main	106519	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51272	Active School	Gunsaulus	Frank W Gunsaulus Elementary Scho	4420 S Sacramento AVENUE, Chic	2019	Main	106519	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	51236	Active School	Haines	John Charles Haines Elementary Sch	247 W 23rd PLACE, Chicago IL 60E	2019	Main	75558	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51236	Active School	Haines	John Charles Haines Elementary Sch	247 W 23rd PLACE, Chicago IL 60E	2019	Main	75558	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6A	51296	Active School	Hale	Nathan Hale Elementary School	6140 S Melvina AVENUE, Chicago I	2019	Main	63323	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51296	Active School	Hale	Nathan Hale Elementary School	6140 S Melvina AVENUE, Chicago I	2019	Main	63323	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51496	Active School	Haley	Alex Haley Elementary Academy	11411 S Eggleston AVENUE, Chicag	2014	Main	64306	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51496	Active School	Haley	Alex Haley Elementary Academy	11411 S Eggleston AVENUE, Chicag	2014	Main	64306	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51060	Active School	Hamilton	Alexander Hamilton Elementary Scho	1650 W Cornelia AVENUE, Chicagc	2019	Main	74643	Basement	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51060	Active School	Hamilton	Alexander Hamilton Elementary Scho	1650 W Cornelia AVENUE, Chicagc	2019	Main	74643	Basement	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51324	Active School	Hamline	John H Hamline Elementary School	4747 S Bishop STREET, Chicago IL	2019	Addition	35521	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51324	Active School	Hamline	John H Hamline Elementary School	4747 S Bishop STREET, Chicago IL	2019	Addition	35521	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5B	51324	Active School	Hamline	John H Hamline Elementary School	4747 S Bishop STREET, Chicago IL	2019	Branch	37552	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51324	Active School	Hamline	John H Hamline Elementary School	4747 S Bishop STREET, Chicago IL	2019	Branch	37552	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	51204	Active School	Hammond	Charles G Hammond Elementary Scho	2819 W 21st PLACE, Chicago IL 60	2014	Main	38104	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51204	Active School	Hammond	Charles G Hammond Elementary Scho	2819 W 21st PLACE, Chicago IL 60	2014	Main	38104	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51288	Active School	Hampton	Lionel Hampton Fine & Performing Ar	3434 W 77th STREET, Chicago IL 6	2019	Main	98776	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-6B	51288	Active School	Hampton	Lionel Hampton Fine & Performing Ar	3434 W 77th STREET, Chicago IL 6	2019	Main	98776	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-6A	51605	Active School	Hancock HS	John Hancock College Preparatory Hi	4034 W 56th STREET, Chicago IL 6	2014	Main	169086	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51605	Active School	Hancock HS	John Hancock College Preparatory Hi	4034 W 56th STREET, Chicago IL 6	2014	Main	169086	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51121	Active School	Hanson Park	Hanson Park Elementary School	5411 W Fullerton AVENUE, Chicagc	2019	Main	74400	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	51121	Active School	Hanson Park	Hanson Park Elementary School	5411 W Fullerton AVENUE, Chicagc	2019	Main	74400	Boiler Room	Condensing- Hot Water Boiler
1	QS-3A	51121	Active School	Hanson Park	Hanson Park Elementary School	5411 W Fullerton AVENUE, Chicagc	2019	Leased-Branch	32476	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51121	Active School	Hanson Park	Hanson Park Elementary School	5411 W Fullerton AVENUE, Chicagc	2019	Leased-Branch	32476	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51121	Active School	Hanson Park	Hanson Park Elementary School	5411 W Fullerton AVENUE, Chicagc	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51121	Active School	Hanson Park	Hanson Park Elementary School	5411 W Fullerton AVENUE, Chicagc	2019	Linked Addition		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51630	Active School	Harlan HS	John M Harlan Community Academy I	9652 S Michigan AVENUE, Chicagc	2019	Main	152196	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-9B	51630	Active School	Harlan HS	John M Harlan Community Academy I	9652 S Michigan AVENUE, Chicagc	2019	Main	152196	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-7A	51610	Active School	Harper HS	William Rainey Harper High School	6520 S Wood STREET, Chicago IL I	2019	Main	174822	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-7A	51610	Active School	Harper HS	William Rainey Harper High School	6520 S Wood STREET, Chicago IL I	2019	Main	174822	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-7A	51610	Active School	Harper HS	William Rainey Harper High School	6520 S Wood STREET, Chicago IL I	2019	Main	174822	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-8A	51402	Active School	Harte	Bret Harte Elementary School	1556 E 56th STREET, Chicago IL 6E	2019	Addition 1	15537	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51402	Active School	Harte	Bret Harte Elementary School	1556 E 56th STREET, Chicago IL 6E	2019	Addition 1	15537	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-7B	51378	Active School	Harvard	John Harvard Elementary School of E	7527 S Harvard AVENUE, Chicago	2019	Main	54868	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51378	Active School	Harvard	John Harvard Elementary School of E	7527 S Harvard AVENUE, Chicago	2019	Main	54868	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51015	Active School	Haugan	Helge A Haugan Elementary School	4540 N Hamlin AVENUE, Chicago II	2019	Main	130162	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51015	Active School	Haugan	Helge A Haugan Elementary School	4540 N Hamlin AVENUE, Chicago II	2019	Main	130162	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51162	Active School	Hawthorne	Hawthorne Elementary Scholastic Acc	3319 N Clifton AVENUE, Chicago IL	2019	Addition 1	44969	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51162	Active School	Hawthorne	Hawthorne Elementary Scholastic Acc	3319 N Clifton AVENUE, Chicago IL	2019	Addition 1	44969	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51091	Active School	Hay	John Hay Elementary Community Aca	1018 N Laramie AVENUE, Chicago	2014	Main	94900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51091	Active School	Hay	John Hay Elementary Community Aca	1018 N Laramie AVENUE, Chicago	2014	Main	94900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51061	Active School	Hayt	Stephen K Hayt Elementary School	1518 W Granville AVENUE, Chicagr	2019	Main	78600	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51061	Active School	Hayt	Stephen K Hayt Elementary School	1518 W Granville AVENUE, Chicagr	2019	Main	78600	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51061	Active School	Hayt	Stephen K Hayt Elementary School	1518 W Granville AVENUE, Chicagr	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51061	Active School	Hayt	Stephen K Hayt Elementary School	1518 W Granville AVENUE, Chicagr	2019	Linked Addition		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4B	51237	Active School	Healy	Robert Healy Elementary School	3010 S Parnell AVENUE, Chicago II	2019	Main	68618	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-4B	51237	Active School	Healy	Robert Healy Elementary School	3010 S Parnell AVENUE, Chicago II	2019	Main	68618	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-4B	51237	Active School	Healy	Robert Healy Elementary School	3010 S Parnell AVENUE, Chicago II	2019	Main	68618	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-4B	51237	Active School	Healy	Robert Healy Elementary School	3010 S Parnell AVENUE, Chicago II	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51237	Active School	Healy	Robert Healy Elementary School	3010 S Parnell AVENUE, Chicago II	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	52467	Active School	Hearst	Phoebe Apperson Hearst Elementary	4640 S Lamon AVENUE, Chicago II	2014	Main		Boiler Room	Boiler Auxiliary- Steam Boiler

1	QS-6A	52467	Active School	Hearst	Phoebe Apperson Hearst Elementary	4640 S Lamont AVENUE, Chicago IL	2014	Main		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-6A	52467	Active School	Hearst	Phoebe Apperson Hearst Elementary	4640 S Lamont AVENUE, Chicago IL	2014	Annex	29461	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	52467	Active School	Hearst	Phoebe Apperson Hearst Elementary	4640 S Lamont AVENUE, Chicago IL	2014	Annex	29461	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51325	Active School	Hedges	James Hedges Elementary School	4747 S Winchester AVENUE, Chica	2019	Main	50925	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51325	Active School	Hedges	James Hedges Elementary School	4747 S Winchester AVENUE, Chica	2019	Main	50925	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51325	Active School	Hedges	James Hedges Elementary School	4747 S Winchester AVENUE, Chica	2019	Addition	51015	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51325	Active School	Hedges	James Hedges Elementary School	4747 S Winchester AVENUE, Chica	2019	Addition	51015	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4A	51186	Active School	Hefferan	Helen M Hefferan Elementary School	4409 W Wilcox STREET, Chicago IL	2014	Main	60934	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51186	Active School	Hefferan	Helen M Hefferan Elementary School	4409 W Wilcox STREET, Chicago IL	2014	Main	60934	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51326	Active School	Henderson	Charles R Henderson Elementary Sch	5650 S Wolcott AVENUE, Chicago I	2014	Main	81110	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7A	51326	Active School	Henderson	Charles R Henderson Elementary Sch	5650 S Wolcott AVENUE, Chicago I	2014	Main	81110	Boiler Room	Condensing- Hot Water Boiler
1	QS-8A	51353	Active School	Hendricks	Thomas A Hendricks Elementary Cor	4316 S Princeton AVENUE, Chicag	2014	Main	56857	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51353	Active School	Hendricks	Thomas A Hendricks Elementary Cor	4316 S Princeton AVENUE, Chicag	2014	Main	56857	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51016	Active School	Henry	Patrick Henry Elementary School	4250 N Saint Louis AVENUE, Chica	2019	Main	75700	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51016	Active School	Henry	Patrick Henry Elementary School	4250 N Saint Louis AVENUE, Chica	2019	Main	75700	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51016	Active School	Henry	Patrick Henry Elementary School	4250 N Saint Louis AVENUE, Chica	2019	Annex		Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-1A	51016	Active School	Henry	Patrick Henry Elementary School	4250 N Saint Louis AVENUE, Chica	2019	Annex		Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-2B	51187	Active School	Herbert	Robert Nathaniel Dett Elementary Sch	2131 W Monroe STREET, Chicago	2019	Main	70600	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-2B	51187	Active School	Herbert	Robert Nathaniel Dett Elementary Sch	2131 W Monroe STREET, Chicago	2019	Main	70600	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-6A	54697	Active School	Hernandez	Irene C. Hernandez Middle School for	3510 W 55th STREET, Chicago IL 6	2014	Main	127162	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	54697	Active School	Hernandez	Irene C. Hernandez Middle School for	3510 W 55th STREET, Chicago IL 6	2014	Main	127162	Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51205	Active School	Herzl	Theodore Herzl Elementary School	3711 W Douglas BOULEVARD, Chi	2014	Main	142911	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51205	Active School	Herzl	Theodore Herzl Elementary School	3711 W Douglas BOULEVARD, Chi	2014	Main	142911	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51017	Active School	Hibbard	William G Hibbard Elementary School	3244 W Ainslie STREET, Chicago IL	2019	Main	97100	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51017	Active School	Hibbard	William G Hibbard Elementary School	3244 W Ainslie STREET, Chicago IL	2019	Main	97100	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51017	Active School	Hibbard	William G Hibbard Elementary School	3244 W Ainslie STREET, Chicago IL	2019	Addition	72800	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51017	Active School	Hibbard	William G Hibbard Elementary School	3244 W Ainslie STREET, Chicago IL	2019	Addition	72800	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9A	51524	Active School	Higgins	Thomas J Higgins Elementary Commi	11710 S Morgan STREET, Chicago	2014	Main	30500	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-9A	51524	Active School	Higgins	Thomas J Higgins Elementary Commi	11710 S Morgan STREET, Chicago	2014	Main	30500	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-7A	51393	Active School	Hinton	Dr. Martin L. King Jr Academy of Soci	644 W 71st STREET, Chicago IL 60	2019	Main	71892	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51393	Active School	Hinton	Dr. Martin L. King Jr Academy of Soci	644 W 71st STREET, Chicago IL 60	2019	Main	71892	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51611	Active School	Hirsch HS	Emil G Hirsch Metropolitan High Scho	7740 S Ingleside AVENUE, Chicagc	2019	Main	217770	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51611	Active School	Hirsch HS	Emil G Hirsch Metropolitan High Scho	7740 S Ingleside AVENUE, Chicagc	2019	Main	217770	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51611	Active School	Hirsch HS	Emil G Hirsch Metropolitan High Scho	7740 S Ingleside AVENUE, Chicagc	2019	Main	217770	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51611	Active School	Hirsch HS	Emil G Hirsch Metropolitan High Scho	7740 S Ingleside AVENUE, Chicagc	2019	Main	217770	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51611	Active School	Hirsch HS	Emil G Hirsch Metropolitan High Scho	7740 S Ingleside AVENUE, Chicagc	2019	Main	217770	Roof	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51611	Active School	Hirsch HS	Emil G Hirsch Metropolitan High Scho	7740 S Ingleside AVENUE, Chicagc	2019	Main	217770	Roof	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51018	Active School	Hitch	Rufus M Hitch Elementary School	5625 N McVicker AVENUE, Chicagc	2019	Main	72250	Mechanical Building/Cen	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51018	Active School	Hitch	Rufus M Hitch Elementary School	5625 N McVicker AVENUE, Chicagc	2019	Main	72250	Mechanical Building/Cen	Condensing- Hot Water Boiler
1	QS-4B	51239	Active School	Holden	Charles N Holden Elementary School	1104 W 31st STREET, Chicago IL 6	2019	Main	57060	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51239	Active School	Holden	Charles N Holden Elementary School	1104 W 31st STREET, Chicago IL 6	2019	Main	57060	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51354	Active School	Holmes	Oliver Wendell Holmes Elementary Sc	955 W Garfield BOULEVARD, Chica	2019	Main	41857	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7A	51354	Active School	Holmes	Oliver Wendell Holmes Elementary Sc	955 W Garfield BOULEVARD, Chica	2019	Main	41857	Boiler Room	Condensing- Hot Water Boiler
1	QS-4B	52307	Active School	Hope Institue	Hope Institute Learning Academy	1628 W Washington BOULEVARD,	2014	Main	208370	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4B	52307	Active School	Hope Institue	Hope Institute Learning Academy	1628 W Washington BOULEVARD,	2014	Main	208370	Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51092	Active School	Howe	Julia Ward Howe Elementary School	720 N Lorel AVENUE, Chicago IL 60	2014	Addition	42777	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51092	Active School	Howe	Julia Ward Howe Elementary School	720 N Lorel AVENUE, Chicago IL 60	2014	Addition	42777	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51206	Active School	Howland	North Lawndale College Prep - Christi	1616 S Spaulding AVENUE, Chicag	2019	Addition 2	43225	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51206	Active School	Howland	North Lawndale College Prep - Christi	1616 S Spaulding AVENUE, Chicag	2019	Addition 2	43225	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51206	Active School	Howland	North Lawndale College Prep - Christi	1616 S Spaulding AVENUE, Chicag	2019	Addition 2	43225	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51206	Active School	Howland	North Lawndale College Prep - Christi	1616 S Spaulding AVENUE, Chicag	2019	Addition 2	43225	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51468	Active School	Hoyne	Thomas Hoyne Elementary School	8905 S Crandon AVENUE, Chicago	2014	Main	17859	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51468	Active School	Hoyne	Thomas Hoyne Elementary School	8905 S Crandon AVENUE, Chicago	2014	Main	17859	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51468	Active School	Hoyne	Thomas Hoyne Elementary School	8905 S Crandon AVENUE, Chicago	2014	Addition	10125	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51468	Active School	Hoyne	Thomas Hoyne Elementary School	8905 S Crandon AVENUE, Chicago	2014	Addition	10125	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6A	51616	Active School	Hubbard HS	Gurdon S Hubbard High School	6200 S Hamlin AVENUE, Chicago II	2019	Main	106900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51616	Active School	Hubbard HS	Gurdon S Hubbard High School	6200 S Hamlin AVENUE, Chicago II	2019	Main	106900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51616	Active School	Hubbard HS	Gurdon S Hubbard High School	6200 S Hamlin AVENUE, Chicago II	2019	Main	106900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51616	Active School	Hubbard HS	Gurdon S Hubbard High School	6200 S Hamlin AVENUE, Chicago II	2019	Main	106900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51616	Active School	Hubbard HS	Gurdon S Hubbard High School	6200 S Hamlin AVENUE, Chicago II	2019	Addition 2	37400	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	51616	Active School	Hubbard HS	Gurdon S Hubbard High School	6200 S Hamlin AVENUE, Chicago II	2019	Addition 2	37400	Mechanical Room	Condensing- Hot Water Boiler
1	QS-4A	51207	Active School	Hughes C	Charles Evans Hughes Elementary Sc	4247 W 15th STREET, Chicago IL 6	2014	Main	49043	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51207	Active School	Hughes C	Charles Evans Hughes Elementary Sc	4247 W 15th STREET, Chicago IL 6	2014	Main	49043	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	51298	Active School	Hurley	Edward N Hurley Elementary School	3849 W 69th PLACE, Chicago IL 60	2019	Main	35666	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51298	Active School	Hurley	Edward N Hurley Elementary School	3849 W 69th PLACE, Chicago IL 60	2019	Main	35666	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51298	Active School	Hurley	Edward N Hurley Elementary School	3849 W 69th PLACE, Chicago IL 60	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51298	Active School	Hurley	Edward N Hurley Elementary School	3849 W 69th PLACE, Chicago IL 60	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	51612	Active School	Hyde Park HS	Hyde Park Academy High School	6220 S Stony Island AVENUE, Chic	2014	Main	252761	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8B	51612	Active School	Hyde Park HS	Hyde Park Academy High School	6220 S Stony Island AVENUE, Chic	2014	Main	252761	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8B	51612	Active School	Hyde Park HS	Hyde Park Academy High School	6220 S Stony Island AVENUE, Chic	2014	Main	252761	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	51612	Active School	Hyde Park HS	Hyde Park Academy High School	6220 S Stony Island AVENUE, Chic	2014	Main	252761	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2B	51211	Active School	Irving Elementary Sc	Washington Irving Elementary School	749 S Oakley BOULEVARD, Chicaç	2019	Main	55148	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2B	51211	Active School	Irving Elementary Sc	Washington Irving Elementary School	749 S Oakley BOULEVARD, Chicaç	2019	Main	55148	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler

1	QS-4B	51243	Active School	Jackson A	Andrew Jackson Elementary	1340 W Harrison STREET, Chicago	2019	Main	74135	Entire Building	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51243	Active School	Jackson A	Andrew Jackson Elementary	1340 W Harrison STREET, Chicago	2019	Main	74135	Entire Building	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3B	51062	Active School	Jahn	Friedrich L. Jahn Elementary of the Fi	3149 N Wolcott AVENUE, Chicago I	2019	Main	83029	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51062	Active School	Jahn	Friedrich L. Jahn Elementary of the Fi	3149 N Wolcott AVENUE, Chicago I	2019	Main	83029	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51063	Active School	Jamieson	Minnie Mars Jamieson Elementary	Sc 5650 N Mozart STREET, Chicago IL	2019	Main	57758	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51063	Active School	Jamieson	Minnie Mars Jamieson Elementary	Sc 5650 N Mozart STREET, Chicago IL	2019	Main	57758	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51063	Active School	Jamieson	Minnie Mars Jamieson Elementary	Sc 5650 N Mozart STREET, Chicago IL	2019	Addition 2	37761	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2A	51063	Active School	Jamieson	Minnie Mars Jamieson Elementary	Sc 5650 N Mozart STREET, Chicago IL	2019	Addition 2	37761	Mechanical Room	Condensing- Hot Water Boiler
1	QS-4B	51219	Active School	Jensen	Jensen Elementary Scholastic Acader	3030 W Harrison STREET, Chicago	2014	Main	56273	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-4B	51219	Active School	Jensen	Jensen Elementary Scholastic Acader	3030 W Harrison STREET, Chicago	2014	Main	56273	Boiler Room	Condensing- Hot Water Boiler
1	QS-4B	51220	Active School	Johnson	James Weldon Johnson Elementary	Sc 1420 S Albany AVENUE, Chicago IL	2019	Main	56581	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-4B	51220	Active School	Johnson	James Weldon Johnson Elementary	Sc 1420 S Albany AVENUE, Chicago IL	2019	Main	56581	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-4B	51220	Active School	Johnson	James Weldon Johnson Elementary	Sc 1420 S Albany AVENUE, Chicago IL	2019	Annex-CPC	14841	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51220	Active School	Johnson	James Weldon Johnson Elementary	Sc 1420 S Albany AVENUE, Chicago IL	2019	Annex-CPC	14841	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4B	51563	Active School	Jones HS	William Jones College Preparatory Hi	606 S State STREET, Chicago IL 6C	2014	Linked Addition-Bldg A (Old Main)		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51563	Active School	Jones HS	William Jones College Preparatory Hi	606 S State STREET, Chicago IL 6C	2014	Linked Addition-Bldg A (Old Main)		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51563	Active School	Jones HS	William Jones College Preparatory Hi	606 S State STREET, Chicago IL 6C	2014	Linked Addition-Bldg A (Old Main)		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51375	Active School	Joplin	Scott Joplin Elementary School	7931 S Honore STREET, Chicago IL	2019	Main	77483	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-7B	51375	Active School	Joplin	Scott Joplin Elementary School	7931 S Honore STREET, Chicago IL	2019	Main	77483	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-1A	51054	Active School	Jordan	Jordan Elementary Community Schoc	7414 N Wolcott AVENUE, Chicago I	2019	Main	66950	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51054	Active School	Jordan	Jordan Elementary Community Schoc	7414 N Wolcott AVENUE, Chicago I	2019	Main	66950	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5A	51570	Active School	Juarez HS	Benito Juarez Community Academy H	1510 W Cermak ROAD, Chicago IL	2019	Main-Building C	158600	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5A	51570	Active School	Juarez HS	Benito Juarez Community Academy H	1510 W Cermak ROAD, Chicago IL	2019	Main-Building C	158600	Boiler Room	Condensing- Hot Water Boiler
1	QS-9A	51637	Active School	Julian HS	Percy L Julian High School	10330 S Elizabeth STREET, Chicag	2019	Main	186327	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9A	51637	Active School	Julian HS	Percy L Julian High School	10330 S Elizabeth STREET, Chicag	2019	Main	186327	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	51242	Active School	Jungman	Joseph Jungman Elementary School	1746 S Miller STREET, Chicago IL	2014	Main	62100	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51242	Active School	Jungman	Joseph Jungman Elementary School	1746 S Miller STREET, Chicago IL	2014	Main	62100	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51442	Active School	Keller	Annie Keller Regional Gifted Center	3020 W 108th STREET, Chicago IL	2019	Main	36864	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51442	Active School	Keller	Annie Keller Regional Gifted Center	3020 W 108th STREET, Chicago IL	2019	Main	36864	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6B	51437	Active School	Kellogg	Kate S Kellogg Elementary School	9241 S Leavitt STREET, Chicago IL	2014	Main	18315	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51437	Active School	Kellogg	Kate S Kellogg Elementary School	9241 S Leavitt STREET, Chicago IL	2014	Main	18315	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Main	224663	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Main	224663	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Main	224663	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Main	224663	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Main	224663	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Addition	73769	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago	2019	Addition	73769	Boiler Room	Condensing- Hot Water Boiler
1	QS-3B	51552	Active School	Kelvyn Park HS	Kelvyn Park High School	4343 W Wrightwood AVE, Chicago I	2014	Main	98284	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51552	Active School	Kelvyn Park HS	Kelvyn Park High School	4343 W Wrightwood AVE, Chicago I	2014	Main	98284	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51552	Active School	Kelvyn Park HS	Kelvyn Park High School	4343 W Wrightwood AVE, Chicago I	2014	Main	98284	Mechanical Room	Boiler Auxiliary- Steam Boiler
1	QS-3B	51552	Active School	Kelvyn Park HS	Kelvyn Park High School	4343 W Wrightwood AVE, Chicago I	2014	Main	98284	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Atmospheric- Steam Boiler
1	QS-6A	51299	Active School	Kennedy/Kinzie	John F Kennedy High School	5625 S Mobile AVENUE, Chicago IL	2014	Main (Kinzie)	111615	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-6A	51299	Active School	Kennedy/Kinzie	John F Kennedy High School	5625 S Mobile AVENUE, Chicago IL	2014	Main (Kinzie)	111615	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-6A	51299	Active School	Kennedy/Kinzie	John F Kennedy High School	5625 S Mobile AVENUE, Chicago IL	2014	Linked Addition (Ken	233791	Mechanical Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51299	Active School	Kennedy/Kinzie	John F Kennedy High School	5625 S Mobile AVENUE, Chicago IL	2014	Linked Addition (Ken	233791	Mechanical Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51586	Active School	Kenwood	Kenwood Academy High School	5015 S Blackstone AVENUE, Chicag	2014	Main-Academic_Unit	105996	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51586	Active School	Kenwood	Kenwood Academy High School	5015 S Blackstone AVENUE, Chicag	2014	Main-Academic_Unit	105996	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51379	Active School	Kershaw	Joshua D Kershaw Elementary Schoc	6450 S Lowe AVENUE, Chicago IL I	2019	Main	51900	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7A	51379	Active School	Kershaw	Joshua D Kershaw Elementary Schoc	6450 S Lowe AVENUE, Chicago IL I	2019	Main	51900	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1A	58049	Active School	Kilmer	Joyce Kilmer Elementary School	6700 N Greenview AVENUE, Chicag	2019	Linked Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	58049	Active School	Kilmer	Joyce Kilmer Elementary School	6700 N Greenview AVENUE, Chicag	2019	Linked Addition		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-8B	51588	Active School	King HS	Dr Martin Luther King Jr College Pre	4445 S Drexel BOULEVARD, Chica	2019	Main	310545	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51588	Active School	King HS	Dr Martin Luther King Jr College Pre	4445 S Drexel BOULEVARD, Chica	2019	Main	310545	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51469	Active School	Kipling	Rudyard Kipling Elementary School	9351 S Wallace STREET, Chicago I	2019	Main	31653	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51469	Active School	Kipling	Rudyard Kipling Elementary School	9351 S Wallace STREET, Chicago I	2019	Main	31653	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8A	51405	Active School	Kozminski	Charles Kozminski Elementary Comm	936 E 54th STREET, Chicago IL 60	2014	Main	63345	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51405	Active School	Kozminski	Charles Kozminski Elementary Comm	936 E 54th STREET, Chicago IL 60	2014	Main	63345	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51132	Active School	LaSalle II at Anders	LaSalle II Magnet Elementary School	1148 N Honore STREET, Chicago I	2019	Addition	58876	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51132	Active School	LaSalle II at Anders	LaSalle II Magnet Elementary School	1148 N Honore STREET, Chicago I	2019	Addition	58876	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51139	Active School	Lafayette	Chicago High School for the Arts	2714 W Augusta BOULEVARD, Chi	2014	Main	84400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51139	Active School	Lafayette	Chicago High School for the Arts	2714 W Augusta BOULEVARD, Chi	2014	Main	84400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51139	Active School	Lafayette	Chicago High School for the Arts	2714 W Augusta BOULEVARD, Chi	2014	Main	84400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51139	Active School	Lafayette	Chicago High School for the Arts	2714 W Augusta BOULEVARD, Chi	2014	Main	84400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51533	Active School	Lake View HS	Lake View High School	4015 N Ashland AVENUE, Chicago	2019	Main	81386	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-2A	51533	Active School	Lake View HS	Lake View High School	4015 N Ashland AVENUE, Chicago	2019	Main	81386	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler
1	QS-3B	51534	Active School	Lane Technical HS	Albert G Lane Technical High School	2501 W Addison STREET, Chicago	2014	Main	707164	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-3B	51534	Active School	Lane Technical HS	Albert G Lane Technical High School	2501 W Addison STREET, Chicago	2014	Main	707164	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-3B	51534	Active School	Lane Technical HS	Albert G Lane Technical High School	2501 W Addison STREET, Chicago	2014	Main	707164	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler
1	QS-3B	51534	Active School	Lane Technical HS	Albert G Lane Technical High School	2501 W Addison STREET, Chicago	2014	Main	707164	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler



1	QS-5B	51327	Active School	Lara	Agustin Lara Elementary Academy	4619 S Wolcott AVENUE, Chicago I	2019	Main	67964	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51327	Active School	Lara	Agustin Lara Elementary Academy	4619 S Wolcott AVENUE, Chicago I	2019	Main	67964	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3B	52615	Active School	Lasalle	LaSalle Elementary Language Acader	1734 N Orleans STREET, Chicago I	2019	Main	47156	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	52615	Active School	Lasalle	LaSalle Elementary Language Acader	1734 N Orleans STREET, Chicago I	2019	Main	47156	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51449	Active School	Lavizzo	Mildred I Lavizzo Elementary School	138 W 109th STREET, Chicago IL 6	2014	Main	83900	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9A	51449	Active School	Lavizzo	Mildred I Lavizzo Elementary School	138 W 109th STREET, Chicago IL 6	2014	Main	83900	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4A	51209	Active School	Lawndale	Lawndale Elementary Community Ac	3500 W Douglas BOULEVARD, Chi	2014	Main	77725	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-4A	51209	Active School	Lawndale	Lawndale Elementary Community Ac	3500 W Douglas BOULEVARD, Chi	2014	Main	77725	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Atmospheric- Steam Boiler
1	QS-4A	51209	Active School	Lawndale	Lawndale Elementary Community Ac	3500 W Douglas BOULEVARD, Chi	2014	Branch		Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-4A	51209	Active School	Lawndale	Lawndale Elementary Community Ac	3500 W Douglas BOULEVARD, Chi	2014	Branch		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Atmospheric- Steam Boiler
1	QS-6A	51313	Active School	Lee	Richard Henry Lee Elementary Schoo	6448 S Tripp AVENUE, Chicago IL 6	2014	Main	10687	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	51313	Active School	Lee	Richard Henry Lee Elementary Schoo	6448 S Tripp AVENUE, Chicago IL 6	2014	Main	10687	Boiler Room	Condensing- Hot Water Boiler
1	QS-6A	51313	Active School	Lee	Richard Henry Lee Elementary Schoo	6448 S Tripp AVENUE, Chicago IL 6	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51313	Active School	Lee	Richard Henry Lee Elementary Schoo	6448 S Tripp AVENUE, Chicago IL 6	2014	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51065	Active School	Lemoyne Elementar	Inter-American Elementary Magnet Sc	851 W Waveland AVENUE, Chicag	2014	Main	90864	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51065	Active School	Lemoyne Elementar	Inter-American Elementary Magnet Sc	851 W Waveland AVENUE, Chicag	2014	Main	90864	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51065	Active School	Lemoyne Elementar	Inter-American Elementary Magnet Sc	851 W Waveland AVENUE, Chicag	2014	Main	90864	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51065	Active School	Lemoyne Elementar	Inter-American Elementary Magnet Sc	851 W Waveland AVENUE, Chicag	2014	Main	90864	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51392	Active School	Lenart	Lenart Elementary Regional Gifted Ce	8101 S LaSalle STREET, Chicago IL	2014	Main	60474	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51392	Active School	Lenart	Lenart Elementary Regional Gifted Ce	8101 S LaSalle STREET, Chicago IL	2014	Main	60474	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51094	Active School	Lewis	Leslie Lewis Elementary School	1431 N Leamington AVENUE, Chic	2014	Main	63800	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	51094	Active School	Lewis	Leslie Lewis Elementary School	1431 N Leamington AVENUE, Chic	2014	Main	63800	Boiler Room	Condensing- Hot Water Boiler
1	QS-3A	51094	Active School	Lewis	Leslie Lewis Elementary School	1431 N Leamington AVENUE, Chic	2014	Addition	65153	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	51094	Active School	Lewis	Leslie Lewis Elementary School	1431 N Leamington AVENUE, Chic	2014	Addition	65153	Boiler Room	Condensing- Hot Water Boiler
1	QS-7A	51328	Active School	Libby Elementary Sc	Arthur A Libby Elementary School	5300 S Loomis BOULEVARD, Chic	2019	Main	69500	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7A	51328	Active School	Libby Elementary Sc	Arthur A Libby Elementary School	5300 S Loomis BOULEVARD, Chic	2019	Main	69500	Boiler Room	Condensing- Hot Water Boiler
1	QS-7A	51328	Active School	Libby Elementary Sc	Arthur A Libby Elementary School	5300 S Loomis BOULEVARD, Chic	2019	Annex		Penthouse	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-7A	51328	Active School	Libby Elementary Sc	Arthur A Libby Elementary School	5300 S Loomis BOULEVARD, Chic	2019	Annex		Penthouse	Electric- Hot Water Boiler
1	QS-3B	51165	Active School	Lincoln	Abraham Lincoln Elementary School	615 W Kemper PLACE, Chicago IL	2014	Main	31633	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51165	Active School	Lincoln	Abraham Lincoln Elementary School	615 W Kemper PLACE, Chicago IL	2014	Main	31633	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51554	Active School	Lincoln Park HS	Lincoln Park High School	2001 N Orchard STREET, Chicago	2014	Main	113640	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-3B	51554	Active School	Lincoln Park HS	Lincoln Park High School	2001 N Orchard STREET, Chicago	2014	Main	113640	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler
1	QS-3B	51554	Active School	Lincoln Park HS	Lincoln Park High School	2001 N Orchard STREET, Chicago	2014	Annex		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51554	Active School	Lincoln Park HS	Lincoln Park High School	2001 N Orchard STREET, Chicago	2014	Annex		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	52292	Active School	Lindblom HS	Robert Lindblom Math & Science Acad	6130 S Wolcott AVENUE, Chicago I	2014	Main	305788	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	52292	Active School	Lindblom HS	Robert Lindblom Math & Science Acad	6130 S Wolcott AVENUE, Chicago I	2014	Main	305788	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	52292	Active School	Lindblom HS	Robert Lindblom Math & Science Acad	6130 S Wolcott AVENUE, Chicago I	2014	Main	305788	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	52292	Active School	Lindblom HS	Robert Lindblom Math & Science Acad	6130 S Wolcott AVENUE, Chicago I	2014	Main	305788	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	52616	Active School	Linne	Carl von Linne Elementary School	3221 N Sacramento AVENUE, Chic	2019	Main	22440	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	52616	Active School	Linne	Carl von Linne Elementary School	3221 N Sacramento AVENUE, Chic	2019	Main	22440	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	52616	Active School	Linne	Carl von Linne Elementary School	3221 N Sacramento AVENUE, Chic	2019	Addition 2	32830	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3B	52616	Active School	Linne	Carl von Linne Elementary School	3221 N Sacramento AVENUE, Chic	2019	Addition 2	32830	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5A	51264	Active School	Little Village Elem	Little Village Elementary School	2620 S Lawndale AVENUE, Chicag	2014	Main	68870	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51264	Active School	Little Village Elem	Little Village Elementary School	2620 S Lawndale AVENUE, Chicag	2014	Main	68870	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	51638	Active School	Little Village Multiple	Greater Lawndale High School For Sc	3120 S Kostner AVENUE, Chicago I	2014	Main	290134	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51638	Active School	Little Village Multiple	Greater Lawndale High School For Sc	3120 S Kostner AVENUE, Chicago I	2014	Main	290134	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	51118	Active School	Lloyd	Henry D Lloyd Elementary School	2103 N Lamon AVENUE, Chicago IL	2014	Main	53654	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51118	Active School	Lloyd	Henry D Lloyd Elementary School	2103 N Lamon AVENUE, Chicago IL	2014	Main	53654	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51118	Active School	Lloyd	Henry D Lloyd Elementary School	2103 N Lamon AVENUE, Chicago IL	2014	Addition 3	56323	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	51118	Active School	Lloyd	Henry D Lloyd Elementary School	2103 N Lamon AVENUE, Chicago IL	2014	Addition 3	56323	Boiler Room	Condensing- Hot Water Boiler
1	QS-3A	51697	Active School	Locke J	Josephine C Locke Elementary Schoc	2845 N Newcastle AVENUE, Chicag	2014	Main	63252	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51697	Active School	Locke J	Josephine C Locke Elementary Schoc	2845 N Newcastle AVENUE, Chicag	2014	Main	63252	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51697	Active School	Locke J	Josephine C Locke Elementary Schoc	2845 N Newcastle AVENUE, Chicag	2014	Main	63252	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51697	Active School	Locke J	Josephine C Locke Elementary Schoc	2845 N Newcastle AVENUE, Chicag	2014	Main	63252	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51697	Active School	Locke J	Josephine C Locke Elementary Schoc	2845 N Newcastle AVENUE, Chicag	2014	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51697	Active School	Locke J	Josephine C Locke Elementary Schoc	2845 N Newcastle AVENUE, Chicag	2014	Linked Addition		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3B	52618	Active School	Logandale	Avondale-Logandale Elementary Sch	3212 W George STREET, Chicago I	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	52618	Active School	Logandale	Avondale-Logandale Elementary Sch	3212 W George STREET, Chicago I	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	52618	Active School	Logandale	Avondale-Logandale Elementary Sch	3212 W George STREET, Chicago I	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3B	52618	Active School	Logandale	Avondale-Logandale Elementary Sch	3212 W George STREET, Chicago I	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2A	54765	Active School	Lorca	Federico Garcia Lorca Elementary Sc	3231 N Springfield AVENUE, Chicag	2014	Main	105599	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2A	54765	Active School	Lorca	Federico Garcia Lorca Elementary Sc	3231 N Springfield AVENUE, Chicag	2014	Main	105599	Boiler Room	Condensing- Hot Water Boiler
1	QS-3A	51096	Active School	Lovett	Joseph Lovett Elementary School	6333 W Bloomingdale AVENUE, Ch	2014	Main	68400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51096	Active School	Lovett	Joseph Lovett Elementary School	6333 W Bloomingdale AVENUE, Ch	2014	Main	68400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51096	Active School	Lovett	Joseph Lovett Elementary School	6333 W Bloomingdale AVENUE, Ch	2014	Main	68400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51096	Active School	Lovett	Joseph Lovett Elementary School	6333 W Bloomingdale AVENUE, Ch	2014	Main	68400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51096	Active School	Lovett	Joseph Lovett Elementary School	6333 W Bloomingdale AVENUE, Ch	2014	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51096	Active School	Lovett	Joseph Lovett Elementary School	6333 W Bloomingdale AVENUE, Ch	2014	Annex		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2B	51119	Active School	Lowell	James Russell Lowell Elementary Sch	3320 W Hirsch STREET, Chicago IL	2014	Main	49900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51119	Active School	Lowell	James Russell Lowell Elementary Sch	3320 W Hirsch STREET, Chicago IL	2014	Main	49900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51686	Active School	Lozano / Rowe	Chai Rowe Elementary Charter School	1501 N Greenview AVENUE, Chicag	2014	Main (Rowe Charter)		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51686	Active School	Lozano / Rowe	Chai Rowe Elementary Charter School	1501 N Greenview AVENUE, Chicag	2014	Main (Rowe Charter)		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51686	Active School	Lozano / Rowe	Chai Rowe Elementary Charter School	1501 N Greenview AVENUE, Chicag	2014	Annex (Lozano)		Penthouse	Boiler Auxiliary- Non Condensing Hot Water

1	QS-2B	51686	Active School	Lozano / Rowe Chai Rowe Elementary Charter School	1501 N Greenview AVENUE, Chicago	2014	Annex (Lozano)	Penthouse	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler		
1	QS-3A	52617	Active School	Lyon	Mary Lyon Elementary School	2941 N McVicker AVENUE, Chicago	2019	Main	60092	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	52617	Active School	Lyon	Mary Lyon Elementary School	2941 N McVicker AVENUE, Chicago	2019	Main	60092	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	52617	Active School	Lyon	Mary Lyon Elementary School	2941 N McVicker AVENUE, Chicago	2019	Addition	53326	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	52617	Active School	Lyon	Mary Lyon Elementary School	2941 N McVicker AVENUE, Chicago	2019	Addition	53326	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5A	51281	Active School	Madero	Francisco I Madero Middle School	3202 W 28th STREET, Chicago IL 6	2014	Main	62071	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51281	Active School	Madero	Francisco I Madero Middle School	3202 W 28th STREET, Chicago IL 6	2014	Main	62071	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-8B	51470	Active School	Madison	James Madison Elementary School	7433 S Dorchester AVENUE, Chicago	2014	Main	47500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51470	Active School	Madison	James Madison Elementary School	7433 S Dorchester AVENUE, Chicago	2014	Main	47500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51167	Active School	Manierre	George Manierre Elementary School	1420 N Hudson AVENUE, Chicago	2014	Main	25168	Mechanical Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51167	Active School	Manierre	George Manierre Elementary School	1420 N Hudson AVENUE, Chicago	2014	Main	25168	Mechanical Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51167	Active School	Manierre	George Manierre Elementary School	1420 N Hudson AVENUE, Chicago	2014	Addition 3_Ferguson	24110	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3B	51167	Active School	Manierre	George Manierre Elementary School	1420 N Hudson AVENUE, Chicago	2014	Addition 3_Ferguson	24110	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2B	51565	Active School	Manley HS	Manley Career Academy High School	2935 W Polk STREET, Chicago IL 6	2019	Main	213820	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51565	Active School	Manley HS	Manley Career Academy High School	2935 W Polk STREET, Chicago IL 6	2019	Main	213820	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51471	Active School	Mann	Horace Mann Elementary School	8050 S Chappel AVENUE, Chicago	2014	Main	82739	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51471	Active School	Mann	Horace Mann Elementary School	8050 S Chappel AVENUE, Chicago	2014	Main	82739	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51300	Active School	Marquette	Marquette Elementary School	6550 S Richmond STREET, Chicago	2019	Main	95744	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51300	Active School	Marquette	Marquette Elementary School	6550 S Richmond STREET, Chicago	2019	Main	95744	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51300	Active School	Marquette	Marquette Elementary School	6550 S Richmond STREET, Chicago	2019	Main	95744	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51300	Active School	Marquette	Marquette Elementary School	6550 S Richmond STREET, Chicago	2019	Main	95744	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51300	Active School	Marquette	Marquette Elementary School	6550 S Richmond STREET, Chicago	2019	Linked Addition		Penthouse	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	51300	Active School	Marquette	Marquette Elementary School	6550 S Richmond STREET, Chicago	2019	Linked Addition		Penthouse	Condensing- Hot Water Boiler
1	QS-9B	54222	Active School	Marsh ES	John L Marsh Elementary School	9822 S Exchange AVENUE, Chicago	2014	Main	57470	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	54222	Active School	Marsh ES	John L Marsh Elementary School	9822 S Exchange AVENUE, Chicago	2014	Main	57470	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4A	51566	Active School	Marshall HS	John Marshall Metropolitan High Sch	3250 W Adams STREET, Chicago IL	2019	Main	80659	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51566	Active School	Marshall HS	John Marshall Metropolitan High Sch	3250 W Adams STREET, Chicago IL	2019	Main	80659	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51566	Active School	Marshall HS	John Marshall Metropolitan High Sch	3250 W Adams STREET, Chicago IL	2019	Main	80659	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51566	Active School	Marshall HS	John Marshall Metropolitan High Sch	3250 W Adams STREET, Chicago IL	2019	Main	80659	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51042	Active School	Marshall Middle	Disney II Magnet School	3900 N Lawndale AVENUE, Chicago	2014	Main	125776	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51042	Active School	Marshall Middle	Disney II Magnet School	3900 N Lawndale AVENUE, Chicago	2014	Main	125776	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51210	Active School	Mason	Roswell B Mason Elementary School	4217 W 18th STREET, Chicago IL 6	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51210	Active School	Mason	Roswell B Mason Elementary School	4217 W 18th STREET, Chicago IL 6	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51210	Active School	Mason	Roswell B Mason Elementary School	4217 W 18th STREET, Chicago IL 6	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51210	Active School	Mason	Roswell B Mason Elementary School	4217 W 18th STREET, Chicago IL 6	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51535	Active School	Mather HS	Stephen T Mather High School	5835 N Lincoln AVENUE, Chicago II	2014	Main	169809	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water Boiler
1	QS-2A	51535	Active School	Mather HS	Stephen T Mather High School	5835 N Lincoln AVENUE, Chicago II	2014	Main	169809	Boiler Room	Non Condensing- Cast Iron- Force Draft- Hot Water Boiler
1	QS-3A	51098	Active School	May	George Leland Elementary School	512 S Laverne AVENUE, Chicago	2019	Main	50050	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51098	Active School	May	George Leland Elementary School	512 S Laverne AVENUE, Chicago	2019	Main	50050	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51098	Active School	May	George Leland Elementary School	512 S Laverne AVENUE, Chicago	2019	Addition 2	29287	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51098	Active School	May	George Leland Elementary School	512 S Laverne AVENUE, Chicago	2019	Addition 2	29287	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3B	51168	Active School	Mayer	Oscar Mayer Magnet School	2250 N Clifton AVENUE, Chicago IL	2019	Main	73514	Basement	Boiler Auxiliary- Condensing Hot Water
1	QS-3B	51168	Active School	Mayer	Oscar Mayer Magnet School	2250 N Clifton AVENUE, Chicago IL	2019	Main	73514	Basement	Condensing- Hot Water Boiler
1	QS-8A	51406	Active School	Mayo	Ida B Wells Preparatory Elementary A	249 E 37th STREET, Chicago IL 60	2019	Main	62750	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8A	51406	Active School	Mayo	Ida B Wells Preparatory Elementary A	249 E 37th STREET, Chicago IL 60	2019	Main	62750	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3A	51116	Active School	McAuliffe	Sharon Christa McAuliffe Elementary	1841 N Springfield AVENUE, Chicago	2014	Main	90799	Boiler Room	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-3A	51116	Active School	McAuliffe	Sharon Christa McAuliffe Elementary	1841 N Springfield AVENUE, Chicago	2014	Main	90799	Boiler Room	Electric- Hot Water Boiler
1	QS-3A	51116	Active School	McAuliffe	Sharon Christa McAuliffe Elementary	1841 N Springfield AVENUE, Chicago	2014	Main	90799	Entire Building	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51116	Active School	McAuliffe	Sharon Christa McAuliffe Elementary	1841 N Springfield AVENUE, Chicago	2014	Main	90799	Entire Building	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3A	51116	Active School	McAuliffe	Sharon Christa McAuliffe Elementary	1841 N Springfield AVENUE, Chicago	2014	Main	90799	Mechanical Room	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-3A	51116	Active School	McAuliffe	Sharon Christa McAuliffe Elementary	1841 N Springfield AVENUE, Chicago	2014	Main	90799	Mechanical Room	Electric- Hot Water Boiler
1	QS-4B	51244	Active School	McClellan	George B McClellan Elementary Sch	3527 S Wallace STREET, Chicago I	2014	Main	58108	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51244	Active School	McClellan	George B McClellan Elementary Sch	3527 S Wallace STREET, Chicago I	2014	Main	58108	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51277	Active School	McCormick	Cyrus H McCormick Elementary Scho	2712 S Sawyer AVENUE, Chicago I	2014	Main	77900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51277	Active School	McCormick	Cyrus H McCormick Elementary Scho	2712 S Sawyer AVENUE, Chicago I	2014	Main	77900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51079	Active School	McCutcheon	John T McCutcheon Elementary Scho	4865 N Sheridan ROAD, Chicago IL	2019	Main	25250	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51079	Active School	McCutcheon	John T McCutcheon Elementary Scho	4865 N Sheridan ROAD, Chicago IL	2019	Main	25250	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51472	Active School	McDade	James E McDade Elementary Classic	8801 S Indiana AVENUE, Chicago I	2014	Main	22579	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51472	Active School	McDade	James E McDade Elementary Classic	8801 S Indiana AVENUE, Chicago I	2014	Main	22579	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51488	Active School	McDowell	Mary E McDowell Elementary School	1419 E 89th STREET, Chicago IL 6	2014	Main	12300	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-9B	51488	Active School	McDowell	Mary E McDowell Elementary School	1419 E 89th STREET, Chicago IL 6	2014	Main	12300	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Atmospheric- Steam Boiler
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Main		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Main		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Addition		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Addition		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago	2019	Addition		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	51105	Active School	McNair	Ronald E McNair Elementary School	4820 W Walton STREET, Chicago II	2014	Main	98596	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-3A	51105	Active School	McNair	Ronald E McNair Elementary School	4820 W Walton STREET, Chicago II	2014	Main	98596	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-2A	51067	Active School	McPherson	James B McPherson Elementary Sch	4728 N Wolcott AVENUE, Chicago I	2014	Main	14018	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51067	Active School	McPherson	James B McPherson Elementary Sch	4728 N Wolcott AVENUE, Chicago I	2014	Main	14018	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler

1	1	QS-2A	51067	Active School	McPherson	James B McPherson Elementary Sch	4728 N Wolcott AVENUE, Chicago I	2014	Addition 3	69623	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-2A	51067	Active School	McPherson	James B McPherson Elementary Sch	4728 N Wolcott AVENUE, Chicago I	2014	Addition 3	69623	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	1	QS-4B	51688	Active School	Medill	DeVry University Advantage Academy	1326 W 14th PLACE, Chicago IL 60	2014	Main (Urban Prep)	110540	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-4B	51688	Active School	Medill	DeVry University Advantage Academy	1326 W 14th PLACE, Chicago IL 60	2014	Main (Urban Prep)	110540	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-4B	51688	Active School	Medill	DeVry University Advantage Academy	1326 W 14th PLACE, Chicago IL 60	2014	Main (Urban Prep)	110540	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-4B	51688	Active School	Medill	DeVry University Advantage Academy	1326 W 14th PLACE, Chicago IL 60	2014	Main (Urban Prep)	110540	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-4B	51688	Active School	Medill	DeVry University Advantage Academy	1326 W 14th PLACE, Chicago IL 60	2014	Annex (Chicago Academy Advanced Te		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-4B	51688	Active School	Medill	DeVry University Advantage Academy	1326 W 14th PLACE, Chicago IL 60	2014	Annex (Chicago Academy Advanced Te		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-9A	51503	Active School	Metcalfe	Ralph H Metcalfe Elementary Commu	12339 S Normal AVENUE, Chicago	2019	Main	76400	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-9A	51503	Active School	Metcalfe	Ralph H Metcalfe Elementary Commu	12339 S Normal AVENUE, Chicago	2019	Main	76400	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	1	QS-9B	51480	Active School	Mireles	Arnold Mireles Elementary Academy	9000 S Exchange AVENUE, Chicag	2014	Main	39375	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-9B	51480	Active School	Mireles	Arnold Mireles Elementary Academy	9000 S Exchange AVENUE, Chicag	2014	Main	39375	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-2B	51140	Active School	Mitchell Elementary	Ellen Mitchell Elementary School	2233 W Ohio STREET, Chicago IL 6	2019	Main	50700	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-2B	51140	Active School	Mitchell Elementary	Ellen Mitchell Elementary School	2233 W Ohio STREET, Chicago IL 6	2019	Main	50700	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-8A	51363	Active School	Mollison	Irvin C Mollison Elementary School	4415 S King DRIVE, Chicago IL 606	2019	Main	43300	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	1	QS-8A	51363	Active School	Mollison	Irvin C Mollison Elementary School	4415 S King DRIVE, Chicago IL 606	2019	Main	43300	Boiler Room	Condensing- Hot Water Boiler
1	1	QS-3B	51020	Active School	Monroe	James Monroe Elementary School	3651 W Schubert AVENUE, Chicag	2014	Main	77064	Boiler Room	Boiler Auxiliary- Steam Boiler
1	1	QS-3B	51020	Active School	Monroe	James Monroe Elementary School	3651 W Schubert AVENUE, Chicag	2014	Main	77064	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Atmospheric- Steam Boiler
1	1	QS-3B	51020	Active School	Monroe	James Monroe Elementary School	3651 W Schubert AVENUE, Chicag	2014	Linked Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-3B	51020	Active School	Monroe	James Monroe Elementary School	3651 W Schubert AVENUE, Chicag	2014	Linked Addition		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	1	QS-2B	51122	Active School	Moos Elementary S	Bernhard Moos Elementary School	1711 N California AVENUE, Chicag	2014	Main	82022	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-2B	51122	Active School	Moos Elementary S	Bernhard Moos Elementary School	1711 N California AVENUE, Chicag	2014	Main	82022	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-2B	51122	Active School	Moos Elementary S	Bernhard Moos Elementary School	1711 N California AVENUE, Chicag	2014	Addition	57687	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-2B	51122	Active School	Moos Elementary S	Bernhard Moos Elementary School	1711 N California AVENUE, Chicag	2014	Addition	57687	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	1	QS-6B	51631	Active School	Morgan Park HS	Morgan Park High School	1744 W Pryor AVENUE, Chicago IL	2014	Addition	101977	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	1	QS-6B	51631	Active School	Morgan Park HS	Morgan Park High School	1744 W Pryor AVENUE, Chicago IL	2014	Addition	101977	Boiler Room	Condensing- Hot Water Boiler
1	1	QS-6A	51303	Active School	Morrill	Donald Morrill Math & Science Elem	6011 S Rockwell STREET, Chicago	2014	Main	77600	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-6A	51303	Active School	Morrill	Donald Morrill Math & Science Elem	6011 S Rockwell STREET, Chicago	2014	Main	77600	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-2B	51150	Active School	Morton	Morton School of Excellence	431 N Troy STREET, Chicago IL 60	2014	Main	71504	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-2B	51150	Active School	Morton	Morton School of Excellence	431 N Troy STREET, Chicago IL 60	2014	Main	71504	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	1	QS-6B	51441	Active School	Mount Greenwood	Mount Greenwood Elementary Schoo	10841 S Homan AVENUE, Chicago	2014	Main	36600	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-6B	51441	Active School	Mount Greenwood	Mount Greenwood Elementary Schoo	10841 S Homan AVENUE, Chicago	2014	Main	36600	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-6B	51441	Active School	Mount Greenwood	Mount Greenwood Elementary Schoo	10841 S Homan AVENUE, Chicago	2014	Addition 2	26190	1st Floor	Boiler Auxiliary- Condensing Hot Water
1	1	QS-6B	51441	Active School	Mount Greenwood	Mount Greenwood Elementary Schoo	10841 S Homan AVENUE, Chicago	2014	Addition 2	26190	1st Floor	Condensing- Hot Water Boiler
1	1	QS-9A	51443	Active School	Mount Vernon	Mount Vernon Elementary School	10540 S Morgan STREET, Chicago	2014	Main	82650	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-9A	51443	Active School	Mount Vernon	Mount Vernon Elementary School	10540 S Morgan STREET, Chicago	2014	Main	82650	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-3B	51123	Active School	Mozart	Wolfgang A Mozart Elementary Schoo	2200 N Hamlin AVENUE, Chicago II	2019	Main	56765	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-3B	51123	Active School	Mozart	Wolfgang A Mozart Elementary Schoo	2200 N Hamlin AVENUE, Chicago II	2019	Main	56765	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-3B	51123	Active School	Mozart	Wolfgang A Mozart Elementary Schoo	2200 N Hamlin AVENUE, Chicago II	2019	Linked Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-3B	51123	Active School	Mozart	Wolfgang A Mozart Elementary Schoo	2200 N Hamlin AVENUE, Chicago II	2019	Linked Addition		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	1	QS-1A	51022	Active School	Murphy	John B Murphy Elementary School	3539 W Grace STREET, Chicago IL	2019	Main	85287	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-1A	51022	Active School	Murphy	John B Murphy Elementary School	3539 W Grace STREET, Chicago IL	2019	Main	85287	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-8A	51355	Active School	Murray	Phillip Murray Elementary Language	# 5335 S Kenwood AVENUE, Chicag	2014	Main	29338	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-8A	51355	Active School	Murray	Phillip Murray Elementary Language	# 5335 S Kenwood AVENUE, Chicag	2014	Main	29338	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-8A	51355	Active School	Murray	Phillip Murray Elementary Language	# 5335 S Kenwood AVENUE, Chicag	2014	Addition 2	27886	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-8A	51355	Active School	Murray	Phillip Murray Elementary Language	# 5335 S Kenwood AVENUE, Chicag	2014	Addition 2	27886	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	1	QS-4B	51254	Active School	NTA	National Teachers Elementary Acader	55 W Cermak ROAD, Chicago IL 6C	2019	Main	92500	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-4B	51254	Active School	NTA	National Teachers Elementary Acader	55 W Cermak ROAD, Chicago IL 6C	2019	Main	92500	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	1	QS-3A	51099	Active School	Nash	Henry H Nash Elementary School	4837 W Erie STREET, Chicago IL 6	2014	Main	53212	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-3A	51099	Active School	Nash	Henry H Nash Elementary School	4837 W Erie STREET, Chicago IL 6	2014	Main	53212	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-7B	51473	Active School	Neil	Jane A Neil Elementary School	8555 S Michigan AVENUE, Chicag	2014	Main	57071	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	1	QS-7B	51473	Active School	Neil	Jane A Neil Elementary School	8555 S Michigan AVENUE, Chicag	2014	Main	57071	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	1	QS-2A	51068	Active School	Nettelhorst	Louis Nettelhorst Elementary School	3252 N Broadway STREET, Chicag	2019	Main	46576	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-2A	51068	Active School	Nettelhorst	Louis Nettelhorst Elementary School	3252 N Broadway STREET, Chicag	2019	Main	46576	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-1A	51080	Active School	New Field	New Field Elementary School	1707 W Morse AVENUE, Chicago IL	2019	Main	85500	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-1A	51080	Active School	New Field	New Field Elementary School	1707 W Morse AVENUE, Chicago IL	2019	Main	85500	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	1	QS-3B	51170	Active School	Newberry	Walter L Newberry Math & Science Ac	700 W Willow STREET, Chicago IL	2014	Main	44944	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-3B	51170	Active School	Newberry	Walter L Newberry Math & Science Ac	700 W Willow STREET, Chicago IL	2014	Main	44944	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-7A	51374	Active School	Nicholson	Lillian R. Nicholson STEM Academy	6006 S Peoria STREET, Chicago IL	2019	Main	47960	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-7A	51374	Active School	Nicholson	Lillian R. Nicholson STEM Academy	6006 S Peoria STREET, Chicago IL	2019	Main	47960	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary Sch	5250 S Rockwell STREET, Chicago	2019	Main	71880	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary Sch	5250 S Rockwell STREET, Chicago	2019	Main	71880	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary Sch	5250 S Rockwell STREET, Chicago	2019	Main	71880	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary Sch	5250 S Rockwell STREET, Chicago	2019	Main	71880	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary Sch	5250 S Rockwell STREET, Chicago	2019	Addition	56750	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary Sch	5250 S Rockwell STREET, Chicago	2019	Addition	56750	Boiler Room	Condensing- Hot Water Boiler
1	1	QS-8B	51467	Active School	Ninos Heroes	Ninos Heroes Elementary Academic C	8344 S Commercial AVENUE, Chic	2014	Main	73518	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	1	QS-8B	51467	Active School	Ninos Heroes	Ninos Heroes Elementary Academic C	8344 S Commercial AVENUE, Chic	2014	Main	73518	Boiler Room	Condensing- Hot Water Boiler
1	1	QS-3B	51124	Active School	Nixon	William P Nixon Elementary School	2121 N Keeler AVENUE, Chicago IL	2019	Main	94016	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	1	QS-3B	51124	Active School	Nixon	William P Nixon Elementary School	2121 N Keeler AVENUE, Chicago IL	2019	Main	94016	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	1	QS-3B	51124	Active School	Nixon	William P Nixon Elementary School	2121 N Keeler AVENUE, Chicago IL	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	1	QS-3B	51124	Active School	Nixon	William P Nixon Elementary School	2121 N Keeler AVENUE, Chicago IL	2019	Linked Addition		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	1	QS-4A	51125	Active School	Nobel	Alfred Nobel Elementary School	4127 W Hirsch STREET, Chicago IL	2014	Main	75800	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler

1	QS-4A	51125	Active School	Nobel	Alfred Nobel Elementary School	4127 W Hirsch STREET, Chicago IL	2014	Main	75800	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51043	Active School	North River	North River Elementary School	4416 N Troy STREET, Chicago IL 6	2019	Leased-Main	42197	Entire Building	Boiler Auxiliary- Steam Boiler
1	QS-1A	51043	Active School	North River	North River Elementary School	4416 N Troy STREET, Chicago IL 6	2019	Leased-Main	42197	Entire Building	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-4A	51550	Active School	North-Grand HS	North-Grand High School	4338 W Wabansia AVENUE, Chicag	2014	Main	205094	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51550	Active School	North-Grand HS	North-Grand High School	4338 W Wabansia AVENUE, Chicag	2014	Main	205094	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1A	51543	Active School	Northside CP HS	Northside College Preparatory High S	5501 N Kedzie AVENUE, Chicago IL	2014	Main	222600	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51543	Active School	Northside CP HS	Northside College Preparatory High S	5501 N Kedzie AVENUE, Chicago IL	2014	Main	222600	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1A	51542	Active School	Northside Learning C	Northside Learning Center High Scho	3730 W Bryn Mawr AVENUE, Chica	2019	Main	39950	Penthouse	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-1A	51542	Active School	Northside Learning C	Northside Learning Center High Scho	3730 W Bryn Mawr AVENUE, Chica	2019	Main	39950	Penthouse	Electric- Hot Water Boiler
1	QS-3A	51120	Active School	Northwest/Belmont+	Northwest Middle School	5252 W Palmer STREET, Chicago I	2019	Main	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler	
1	QS-3A	51120	Active School	Northwest/Belmont+	Northwest Middle School	5252 W Palmer STREET, Chicago I	2019	Main	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler	
1	QS-3A	51120	Active School	Northwest/Belmont+	Northwest Middle School	5252 W Palmer STREET, Chicago I	2019	Leased-Pre-K	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water	
1	QS-3A	51120	Active School	Northwest/Belmont+	Northwest Middle School	5252 W Palmer STREET, Chicago I	2019	Leased-Pre-K	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler	
1	QS-1B	51023	Active School	Norwood Park	Norwood Park Elementary School	5900 N Nina AVENUE, Chicago IL 6	2019	Main	56330	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51023	Active School	Norwood Park	Norwood Park Elementary School	5900 N Nina AVENUE, Chicago IL 6	2019	Main	56330	Boiler Room	Condensing- Hot Water Boiler
1	QS-7A	51329	Active School	O'Toole	Luke O'Toole Elementary School	6550 S Seeley AVENUE, Chicago IL	2014	Main	78700	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-7A	51329	Active School	O'Toole	Luke O'Toole Elementary School	6550 S Seeley AVENUE, Chicago IL	2014	Main	78700	Boiler Room	Condensing- Hot Water Boiler
1	QS-8B	51474	Active School	O'Keeffe	Isabelle C O'Keeffe Elementary Scho	6940 S Merrill AVENUE, Chicago IL	2019	Main	66238	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51474	Active School	O'Keeffe	Isabelle C O'Keeffe Elementary Scho	6940 S Merrill AVENUE, Chicago IL	2019	Main	66238	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51171	Active School	Ogden Elem	William B Ogden Elementary School	24 W Walton STREET, Chicago IL 6	2014	Main	132724	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2B	51171	Active School	Ogden Elem	William B Ogden Elementary School	24 W Walton STREET, Chicago IL 6	2014	Main	132724	Boiler Room	Condensing- Hot Water Boiler
1	QS-2B	51134	Active School	Ogden HS	William B Ogden Elementary School	1250 W Erie STREET, Chicago IL 6	2014	Main	93355	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51134	Active School	Ogden HS	William B Ogden Elementary School	1250 W Erie STREET, Chicago IL 6	2014	Main	93355	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51380	Active School	Oglesby	Richard J Oglesby Elementary School	7646 S Green STREET, Chicago IL	2014	Main	77140	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51380	Active School	Oglesby	Richard J Oglesby Elementary School	7646 S Green STREET, Chicago IL	2014	Main	77140	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51380	Active School	Oglesby	Richard J Oglesby Elementary School	7646 S Green STREET, Chicago IL	2014	Main	77140	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51380	Active School	Oglesby	Richard J Oglesby Elementary School	7646 S Green STREET, Chicago IL	2014	Main	77140	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51024	Active School	Onahan	William J Onahan Elementary School	6634 W Raven STREET, Chicago IL	2019	Main	61130	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51024	Active School	Onahan	William J Onahan Elementary School	6634 W Raven STREET, Chicago IL	2019	Main	61130	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51024	Active School	Onahan	William J Onahan Elementary School	6634 W Raven STREET, Chicago IL	2019	Linked Addition	Boiler Room	Boiler Auxiliary- Condensing Hot Water	
1	QS-1B	51024	Active School	Onahan	William J Onahan Elementary School	6634 W Raven STREET, Chicago IL	2019	Linked Addition	Boiler Room	Condensing- Hot Water Boiler	
1	QS-1B	51025	Active School	Oriole Park	Oriole Park Elementary School	5424 N Oketo AVENUE, Chicago IL	2019	Main	38534	Mechanical Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51025	Active School	Oriole Park	Oriole Park Elementary School	5424 N Oketo AVENUE, Chicago IL	2019	Main	38534	Mechanical Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51025	Active School	Oriole Park	Oriole Park Elementary School	5424 N Oketo AVENUE, Chicago IL	2019	Addition	37942	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51025	Active School	Oriole Park	Oriole Park Elementary School	5424 N Oketo AVENUE, Chicago IL	2019	Addition	37942	Boiler Room	Condensing- Hot Water Boiler
1	QS-5A	51256	Active School	Orozco	Orozco Fine Arts & Sciences Element	1940 W 18th STREET, Chicago IL 6	2014	Main	107722	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51256	Active School	Orozco	Orozco Fine Arts & Sciences Element	1940 W 18th STREET, Chicago IL 6	2014	Main	107722	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3B	51143	Active School	Otis	James Otis Elementary School	525 N Armour STREET, Chicago IL	2014	Addition 1	12280	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51143	Active School	Otis	James Otis Elementary School	525 N Armour STREET, Chicago IL	2014	Addition 1	12280	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51143	Active School	Otis	James Otis Elementary School	525 N Armour STREET, Chicago IL	2014	Field House	1st Floor	Boiler Auxiliary- Non Condensing Hot Water	
1	QS-3B	51143	Active School	Otis	James Otis Elementary School	525 N Armour STREET, Chicago IL	2014	Field House	1st Floor	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler	
1	QS-6B	51444	Active School	Owen	William Bishop Owen Scholastic Acad	8247 S Christiana AVENUE, Chicag	2019	Main	18117	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51444	Active School	Owen	William Bishop Owen Scholastic Acad	8247 S Christiana AVENUE, Chicag	2019	Main	18117	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9A	51506	Active School	Owens	Jesse Owens Elementary Community	12302 S State STREET, Chicago IL	2019	Main	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler	
1	QS-9A	51506	Active School	Owens	Jesse Owens Elementary Community	12302 S State STREET, Chicago IL	2019	Main	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler	
1	QS-1B	51026	Active School	Palmer	John Palmer Elementary School	5051 N Kenneth AVENUE, Chicago	2014	Main	68290	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51026	Active School	Palmer	John Palmer Elementary School	5051 N Kenneth AVENUE, Chicago	2014	Main	68290	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51026	Active School	Palmer	John Palmer Elementary School	5051 N Kenneth AVENUE, Chicago	2014	Annex	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water	
1	QS-1B	51026	Active School	Palmer	John Palmer Elementary School	5051 N Kenneth AVENUE, Chicago	2014	Annex	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler	
1	QS-7A	51382	Active School	Park Manor	Park Manor Elementary School	7037 S Rhodes AVENUE, Chicago I	2014	Main	62706	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-7A	51382	Active School	Park Manor	Park Manor Elementary School	7037 S Rhodes AVENUE, Chicago I	2014	Main	62706	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-7A	51381	Active School	Parker	Francis W Parker Elementary Commu	6800 S Stewart AVENUE, Chicago I	2014	Main	265000	Mechanical Building/Cen	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51381	Active School	Parker	Francis W Parker Elementary Commu	6800 S Stewart AVENUE, Chicago I	2014	Main	265000	Mechanical Building/Cen	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51381	Active School	Parker	Francis W Parker Elementary Commu	6800 S Stewart AVENUE, Chicago I	2014	Main	265000	Mechanical Building/Cen	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51381	Active School	Parker	Francis W Parker Elementary Commu	6800 S Stewart AVENUE, Chicago I	2014	Main	265000	Mechanical Building/Cen	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51475	Active School	Parkside	Parkside Elementary Community Acac	6938 S East End AVENUE, Chicagc	2019	Main	75104	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51475	Active School	Parkside	Parkside Elementary Community Acac	6938 S East End AVENUE, Chicagc	2019	Main	75104	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	Main	77900	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	Main	77900	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	Annex	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water	
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	Annex	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler	
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	Midway Academy	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler	
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	Midway Academy	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler	
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	St Camilus	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water	
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	St Camilus	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler	
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago I	2014	St Camilus	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler	
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory Hi	1034 N Wells STREET, Chicago IL I	2019	Main	167870	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory Hi	1034 N Wells STREET, Chicago IL I	2019	Main	167870	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory Hi	1034 N Wells STREET, Chicago IL I	2019	Addition	48605	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory Hi	1034 N Wells STREET, Chicago IL I	2019	Addition	48605	Mechanical Room	Condensing- Hot Water Boiler
1	QS-5B	51345	Active School	Peace and Educatio	Peace & Education Coalition HS	4946 S Paulina STREET, Chicago II	2014	Main	20650	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5B	51345	Active School	Peace and Educatio	Peace & Education Coalition HS	4946 S Paulina STREET, Chicago II	2014	Main	20650	Boiler Room	Condensing- Hot Water Boiler
1	QS-6A	51307	Active School	Peck	Ferdinand Peck Elementary School	3826 W 58th STREET, Chicago IL 6	2014	Main	76131	Mechanical Building/Cen	Boiler Auxiliary- Condensing Hot Water

1	QS-6A	51307	Active School	Peck	Ferdinand Peck Elementary School	3826 W 58th STREET, Chicago IL 6	2014	Main	76131	Mechanical Building/Cen	Condensing- Hot Water Boiler
1	QS-6A	51307	Active School	Peck	Ferdinand Peck Elementary School	3826 W 58th STREET, Chicago IL 6	2014	Annex		Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	51307	Active School	Peck	Ferdinand Peck Elementary School	3826 W 58th STREET, Chicago IL 6	2014	Annex		Boiler Room	Condensing- Hot Water Boiler
1	QS-2A	51069	Active School	Peirce	Helen Peirce International Studies ES	1423 W Bryn Mawr AVENUE, Chica	2019	Main	59563	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51069	Active School	Peirce	Helen Peirce International Studies ES	1423 W Bryn Mawr AVENUE, Chica	2019	Main	59563	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51069	Active School	Peirce	Helen Peirce International Studies ES	1423 W Bryn Mawr AVENUE, Chica	2019	Addition	71850	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51069	Active School	Peirce	Helen Peirce International Studies ES	1423 W Bryn Mawr AVENUE, Chica	2019	Addition	71850	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4A	51212	Active School	Penn	William Penn Elementary School	1616 S Avers AVENUE, Chicago IL	2019	Main	158325	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51212	Active School	Penn	William Penn Elementary School	1616 S Avers AVENUE, Chicago IL	2019	Main	158325	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	52428	Active School	Perez	Manuel Perez Elementary School	1241 W 19th STREET, Chicago IL 6	2014	Main	65134	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	52428	Active School	Perez	Manuel Perez Elementary School	1241 W 19th STREET, Chicago IL 6	2014	Main	65134	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	52428	Active School	Perez	Manuel Perez Elementary School	1241 W 19th STREET, Chicago IL 6	2014	Annex		Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-5A	52428	Active School	Perez	Manuel Perez Elementary School	1241 W 19th STREET, Chicago IL 6	2014	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-8B	51682	Active School	Pershing West (Dou John J Pershing Elementary Humaniti	3200 S Calumet AVENUE, Chicago		2014	Main	71688	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51682	Active School	Pershing West (Dou John J Pershing Elementary Humaniti	3200 S Calumet AVENUE, Chicago		2014	Main	71688	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51682	Active School	Pershing West (Dou John J Pershing Elementary Humaniti	3200 S Calumet AVENUE, Chicago		2014	Main	71688	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51682	Active School	Pershing West (Dou John J Pershing Elementary Humaniti	3200 S Calumet AVENUE, Chicago		2014	Main	71688	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51027	Active School	Peterson	Mary Gage Peterson Elementary Sch	5510 N Christiana AVENUE, Chicag	2014	Main	65087	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51027	Active School	Peterson	Mary Gage Peterson Elementary Sch	5510 N Christiana AVENUE, Chicag	2014	Main	65087	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51408	Active School	Phillips HS	Wendell Phillips Academy High Schoc	244 E Pershing ROAD, Chicago IL (	2014	Main	146759	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-8A	51408	Active School	Phillips HS	Wendell Phillips Academy High Schoc	244 E Pershing ROAD, Chicago IL (	2014	Main	146759	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler
1	QS-2B	51185	Active School	Phoenix Military Aca	Phoenix Military Academy High Schoc	145 S Campbell AVENUE, Chicago	2019	Main	52028	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51185	Active School	Phoenix Military Aca	Phoenix Military Academy High Schoc	145 S Campbell AVENUE, Chicago	2019	Main	52028	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51185	Active School	Phoenix Military Aca	Phoenix Military Academy High Schoc	145 S Campbell AVENUE, Chicago	2019	Addition 3	27310	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2B	51185	Active School	Phoenix Military Aca	Phoenix Military Academy High Schoc	145 S Campbell AVENUE, Chicago	2019	Addition 3	27310	Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51127	Active School	Piccolo	Brian Piccolo Elementary Specialty Sc	1040 N Keeler AVENUE, Chicago IL	2014	Main	106755	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51127	Active School	Piccolo	Brian Piccolo Elementary Specialty Sc	1040 N Keeler AVENUE, Chicago IL	2014	Main	106755	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51248	Active School	Pickard	Josiah Pickard Elementary School	2301 W 21st PLACE, Chicago IL 60	2014	Main	69555	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51248	Active School	Pickard	Josiah Pickard Elementary School	2301 W 21st PLACE, Chicago IL 60	2014	Main	69555	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51248	Active School	Pickard	Josiah Pickard Elementary School	2301 W 21st PLACE, Chicago IL 60	2014	Addition	46690	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51248	Active School	Pickard	Josiah Pickard Elementary School	2301 W 21st PLACE, Chicago IL 60	2014	Addition	46690	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5A	51241	Active School	Pilsen	Pilsen Elementary Community Acader	1420 W 17th STREET, Chicago IL 6	2019	Main	61287	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51241	Active School	Pilsen	Pilsen Elementary Community Acader	1420 W 17th STREET, Chicago IL 6	2019	Main	61287	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51477	Active School	Pirie	John T Pirie Fine Arts & Academic Ce	650 E 85th STREET, Chicago IL 60	2014	Main	43063	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51213	Active School	Plamondon	Ambrose Plamondon Elementary Sch	2642 W 15th PLACE, Chicago IL 60	2014	Main	38751	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51213	Active School	Plamondon	Ambrose Plamondon Elementary Sch	2642 W 15th PLACE, Chicago IL 60	2014	Main	38751	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51213	Active School	Plamondon	Ambrose Plamondon Elementary Sch	2642 W 15th PLACE, Chicago IL 60	2014	Main	38751	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4B	51213	Active School	Plamondon	Ambrose Plamondon Elementary Sch	2642 W 15th PLACE, Chicago IL 60	2014	Main	38751	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9A	51513	Active School	Poe	Edgar Allan Poe Elementary Classical	10538 S Langley AVENUE, Chicagc	2019	Main	38332	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51513	Active School	Poe	Edgar Allan Poe Elementary Classical	10538 S Langley AVENUE, Chicagc	2019	Main	38332	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51028	Active School	Portage Park	Portage Park Elementary School	5330 W Berteau AVENUE, Chicago	2019	Main	101885	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51028	Active School	Portage Park	Portage Park Elementary School	5330 W Berteau AVENUE, Chicago	2019	Main	101885	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51028	Active School	Portage Park	Portage Park Elementary School	5330 W Berteau AVENUE, Chicago	2019	Addition	43890	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51028	Active School	Portage Park	Portage Park Elementary School	5330 W Berteau AVENUE, Chicago	2019	Addition	43890	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8B	54776	Active School	Powell	Adam Clayton Powell Paideia Commu	7511 S South Shore DRIVE, Chicag	2014	Main	113516	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8B	54776	Active School	Powell	Adam Clayton Powell Paideia Commu	7511 S South Shore DRIVE, Chicag	2014	Main	113516	Mechanical Room	Condensing- Hot Water Boiler
1	QS-3B	51173	Active School	Prescott	William H Prescott Elementary School	1632 W Wrightwood AVENUE, Chic	2019	Main	33794	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51173	Active School	Prescott	William H Prescott Elementary School	1632 W Wrightwood AVENUE, Chic	2019	Main	33794	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	54698	Active School	Prieto	Dr Jorge Prieto Math and Science	2231 N Central AVENUE, Chicago I	2014	Main	106218	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	54698	Active School	Prieto	Dr Jorge Prieto Math and Science	2231 N Central AVENUE, Chicago I	2014	Main	106218	Boiler Room	Condensing- Hot Water Boiler
1	QS-2B	51149	Active School	Pritzker	A.N. Pritzker School	2009 W Schiller STREET, Chicago I	2014	Main	66300	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2B	51149	Active School	Pritzker	A.N. Pritzker School	2009 W Schiller STREET, Chicago I	2014	Main	66300	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-3A	51548	Active School	Prosser HS	Charles Allen Prosser Career Academ	2148 N Long AVENUE, Chicago IL (	2014	Main	68059	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51548	Active School	Prosser HS	Charles Allen Prosser Career Academ	2148 N Long AVENUE, Chicago IL (	2014	Main	68059	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51548	Active School	Prosser HS	Charles Allen Prosser Career Academ	2148 N Long AVENUE, Chicago IL (	2014	Main	68059	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51548	Active School	Prosser HS	Charles Allen Prosser Career Academ	2148 N Long AVENUE, Chicago IL (	2014	Main	68059	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51029	Active School	Prussing	Ernst Prussing Elementary School	4650 N Menard AVENUE, Chicago I	2014	Main	66493	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51029	Active School	Prussing	Ernst Prussing Elementary School	4650 N Menard AVENUE, Chicago I	2014	Main	66493	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51145	Active School	Pulaski	Pulaski International School of Chicag	2230 W McLean AVENUE, Chicago	2019	Main	76304	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51145	Active School	Pulaski	Pulaski International School of Chicag	2230 W McLean AVENUE, Chicago	2019	Main	76304	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9A	51514	Active School	Pullman	George M Pullman Elementary Schoo	11311 S Forrestville AVENUE, Chic	2014	Main	80075	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51514	Active School	Pullman	George M Pullman Elementary Schoo	11311 S Forrestville AVENUE, Chic	2014	Main	80075	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51574	Active School	Raby HS	Al Raby High School	3545 W Fulton BOULEVARD, Chic	2014	Main	156248	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4A	51574	Active School	Raby HS	Al Raby High School	3545 W Fulton BOULEVARD, Chic	2014	Main	156248	Boiler Room	Condensing- Hot Water Boiler
1	QS-7B	51322	Active School	Randolph	Asa Philip Randolph Elementary Schc	7316 S Hoyne AVENUE, Chicago IL	2014	Main	78450	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51322	Active School	Randolph	Asa Philip Randolph Elementary Schc	7316 S Hoyne AVENUE, Chicago IL	2014	Main	78450	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51070	Active School	Ravenswood	Ravenswood Elementary School	4332 N Paulina STREET, Chicago I	2019	Main	40510	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51070	Active School	Ravenswood	Ravenswood Elementary School	4332 N Paulina STREET, Chicago I	2019	Main	40510	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51410	Active School	Ray	William H Ray Elementary School	5631 S Kimbark AVENUE, Chicago	2019	Main	84500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51410	Active School	Ray	William H Ray Elementary School	5631 S Kimbark AVENUE, Chicago	2019	Main	84500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51410	Active School	Ray	William H Ray Elementary School	5631 S Kimbark AVENUE, Chicago	2019	Addition 2	23876	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-8B	51410	Active School	Ray	William H Ray Elementary School	5631 S Kimbark AVENUE, Chicago	2019	Addition 2	23876	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-8A	51411	Active School	Reavis	William C Reavis Math & Science Spe	834 E 50th STREET, Chicago IL 60	2019	Main	25067	Boiler Room	Boiler Auxiliary- Condensing Hot Water

1	QS-8A	51411	Active School	Reavis	William C Reavis Math & Science Spe	834 E 50th STREET, Chicago IL 606	2019	Main	25067	Boiler Room	Condensing- Hot Water Boiler
1	QS-8A	51411	Active School	Reavis	William C Reavis Math & Science Spe	834 E 50th STREET, Chicago IL 606	2019	Addition	32440	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-8A	51411	Active School	Reavis	William C Reavis Math & Science Spe	834 E 50th STREET, Chicago IL 606	2019	Addition	32440	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-2A	51030	Active School	Reilly	Frank W Reilly Elementary School	3650 W School STREET, Chicago IL	2019	Main	75830	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2A	51030	Active School	Reilly	Frank W Reilly Elementary School	3650 W School STREET, Chicago IL	2019	Main	75830	Boiler Room	Condensing- Hot Water Boiler
1	QS-2A	51030	Active School	Reilly	Frank W Reilly Elementary School	3650 W School STREET, Chicago IL	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51030	Active School	Reilly	Frank W Reilly Elementary School	3650 W School STREET, Chicago IL	2019	Linked Addition		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1B	51031	Active School	Reinberg	Peter A Reinberg Elementary School	3425 N Major AVENUE, Chicago IL	2019	Main	60570	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51031	Active School	Reinberg	Peter A Reinberg Elementary School	3425 N Major AVENUE, Chicago IL	2019	Main	60570	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51031	Active School	Reinberg	Peter A Reinberg Elementary School	3425 N Major AVENUE, Chicago IL	2019	Linked Addition		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1B	51031	Active School	Reinberg	Peter A Reinberg Elementary School	3425 N Major AVENUE, Chicago IL	2019	Linked Addition		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-8B	51478	Active School	Revere	Paul Revere Elementary School	1010 E 72nd STREET, Chicago IL 6	2014	Main	39210	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51478	Active School	Revere	Paul Revere Elementary School	1010 E 72nd STREET, Chicago IL 6	2014	Main	39210	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51478	Active School	Revere	Paul Revere Elementary School	1010 E 72nd STREET, Chicago IL 6	2014	Main	39210	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51478	Active School	Revere	Paul Revere Elementary School	1010 E 72nd STREET, Chicago IL 6	2014	Main	39210	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51579	Active School	Richards	Ellen H Richards Career Academy Hi	5009 S Laffin STREET, Chicago IL 6	2019	Main	49376	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51579	Active School	Richards	Ellen H Richards Career Academy Hi	5009 S Laffin STREET, Chicago IL 6	2019	Main	49376	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51579	Active School	Richards	Ellen H Richards Career Academy Hi	5009 S Laffin STREET, Chicago IL 6	2019	Linked Addition 1		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51579	Active School	Richards	Ellen H Richards Career Academy Hi	5009 S Laffin STREET, Chicago IL 6	2019	Linked Addition 1		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5B	51579	Active School	Richards	Ellen H Richards Career Academy Hi	5009 S Laffin STREET, Chicago IL 6	2019	Linked Addition 2		Penthouse	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51579	Active School	Richards	Ellen H Richards Career Academy Hi	5009 S Laffin STREET, Chicago IL 6	2019	Linked Addition 2		Penthouse	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-1A	51071	Active School	Rogers	Philip Rogers Elementary School	7345 N Washtenaw AVENUE, Chic	2014	Main	16000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-1A	51071	Active School	Rogers	Philip Rogers Elementary School	7345 N Washtenaw AVENUE, Chic	2014	Main	16000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-1A	51071	Active School	Rogers	Philip Rogers Elementary School	7345 N Washtenaw AVENUE, Chic	2014	Main	16000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler
1	QS-1A	51071	Active School	Rogers	Philip Rogers Elementary School	7345 N Washtenaw AVENUE, Chic	2014	Main	16000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- High Pressure Boiler
1	QS-1A	51536	Active School	Roosevelt HS	Theodore Roosevelt High School	3436 W Wilson AVENUE, Chicago I	2014	Main	319900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51536	Active School	Roosevelt HS	Theodore Roosevelt High School	3436 W Wilson AVENUE, Chicago I	2014	Main	319900	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51536	Active School	Roosevelt HS	Theodore Roosevelt High School	3436 W Wilson AVENUE, Chicago I	2014	Main	319900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51536	Active School	Roosevelt HS	Theodore Roosevelt High School	3436 W Wilson AVENUE, Chicago I	2014	Main	319900	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51536	Active School	Roosevelt HS	Theodore Roosevelt High School	3436 W Wilson AVENUE, Chicago I	2014	Main	319900	Mechanical Room	Boiler Auxiliary- Steam Boiler
1	QS-1A	51536	Active School	Roosevelt HS	Theodore Roosevelt High School	3436 W Wilson AVENUE, Chicago I	2014	Main	319900	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-7B	51384	Active School	Ruggles	Martha Ruggles Elementary School	7831 S Prairie AVENUE, Chicago IL	2014	Main	88210	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51384	Active School	Ruggles	Martha Ruggles Elementary School	7831 S Prairie AVENUE, Chicago IL	2014	Main	88210	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51278	Active School	Ruiz	Irma C Ruiz Elementary School	2410 S Leavitt STREET, Chicago IL	2014	Main	73217	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51278	Active School	Ruiz	Irma C Ruiz Elementary School	2410 S Leavitt STREET, Chicago IL	2014	Main	73217	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-7B	51479	Active School	Ryder	William H Ryder Math & Science Spe	8716 S Wallace STREET, Chicago I	2014	Main	38000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51479	Active School	Ryder	William H Ryder Math & Science Spe	8716 S Wallace STREET, Chicago I	2014	Main	38000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51146	Active School	Ryerson	Laura S Ward Elementary School	646 N Lawndale AVENUE, Chicago	2019	Main	49705	Mechanical Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51146	Active School	Ryerson	Laura S Ward Elementary School	646 N Lawndale AVENUE, Chicago	2019	Main	49705	Mechanical Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	52340	Active School	STEM Magnet	STEM Magnet Academy	1522 W Fillmore STREET, Chicago	2019	Addition	32113	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	52340	Active School	STEM Magnet	STEM Magnet Academy	1522 W Fillmore STREET, Chicago	2019	Addition	32113	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	52340	Active School	STEM Magnet	STEM Magnet Academy	1522 W Fillmore STREET, Chicago	2019	Addition	32113	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	52340	Active School	STEM Magnet	STEM Magnet Academy	1522 W Fillmore STREET, Chicago	2019	Addition	32113	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51153	Active School	Sabin	Albert R Sabin Elementary Magnet Sc	2216 W Hirsch STREET, Chicago IL	2014	Main	95219	Mechanical Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51153	Active School	Sabin	Albert R Sabin Elementary Magnet Sc	2216 W Hirsch STREET, Chicago IL	2014	Main	95219	Mechanical Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51176	Active School	Salazar	Ruben Salazar Elementary Bilingual C	160 W Wendell STREET, Chicago IL	2014	Main	45084	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51176	Active School	Salazar	Ruben Salazar Elementary Bilingual C	160 W Wendell STREET, Chicago IL	2014	Main	45084	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51312	Active School	Sandoval	Socorro Sandoval Elementary School	5534 S Saint Louis AVENUE, Chica	2019	Main	108534	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51312	Active School	Sandoval	Socorro Sandoval Elementary School	5534 S Saint Louis AVENUE, Chica	2019	Main	108534	Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	51275	Active School	Saucedo	Maria Saucedo Elementary Scholastic	2850 W 24th BOULEVARD, Chicag	2014	Addition (Telpochcall	40822	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51275	Active School	Saucedo	Maria Saucedo Elementary Scholastic	2850 W 24th BOULEVARD, Chicag	2014	Addition (Telpochcall	40822	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51032	Active School	Sauganash	Sauganash Elementary School	6040 N Kilpatrick AVENUE, Chicag	2019	Main	18818	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-1A	51032	Active School	Sauganash	Sauganash Elementary School	6040 N Kilpatrick AVENUE, Chicag	2019	Main	18818	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-1A	51032	Active School	Sauganash	Sauganash Elementary School	6040 N Kilpatrick AVENUE, Chicag	2019	Addition 2	41498	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1A	51032	Active School	Sauganash	Sauganash Elementary School	6040 N Kilpatrick AVENUE, Chicag	2019	Addition 2	41498	Mechanical Room	Condensing- Hot Water Boiler
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago I	2014	Main	79788	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago I	2014	Main	79788	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago I	2014	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water Boiler
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago I	2014	Annex		Mechanical Room	Non Condensing- Cast Iron- Force Draft- Hot Water Boiler
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago I	2014	Annex		Mechanical Room	Non Condensing- Cast Iron- Force Draft- Hot Water Boiler
1	QS-3A	51101	Active School	Sayre	Harriet E Sayre Elementary Language	1850 N Newland AVENUE, Chicago	2019	Main	79775	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51101	Active School	Sayre	Harriet E Sayre Elementary Language	1850 N Newland AVENUE, Chicago	2019	Main	79775	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51033	Active School	Scammon	Jonathan Y Scammon Elementary Sch	4201 W Henderson STREET, Chica	2019	Main	63802	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51033	Active School	Scammon	Jonathan Y Scammon Elementary Sch	4201 W Henderson STREET, Chica	2019	Main	63802	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51033	Active School	Scammon	Jonathan Y Scammon Elementary Sch	4201 W Henderson STREET, Chica	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51033	Active School	Scammon	Jonathan Y Scammon Elementary Sch	4201 W Henderson STREET, Chica	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9B	51517	Active School	Schmid	Theophilus Schmid Elementary Schoc	9755 S Greenwood AVENUE, Chic	2019	Main	18020	Mechanical Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51517	Active School	Schmid	Theophilus Schmid Elementary Schoc	9755 S Greenwood AVENUE, Chic	2019	Main	18020	Mechanical Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51128	Active School	Schubert	Franz Peter Schubert Elementary Sch	2727 N Long AVENUE, Chicago IL 6	2019	Main	78000	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51128	Active School	Schubert	Franz Peter Schubert Elementary Sch	2727 N Long AVENUE, Chicago IL 6	2019	Main	78000	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51128	Active School	Schubert	Franz Peter Schubert Elementary Sch	2727 N Long AVENUE, Chicago IL 6	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51128	Active School	Schubert	Franz Peter Schubert Elementary Sch	2727 N Long AVENUE, Chicago IL 6	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-2A	51537	Active School	Schurz HS	Carl Schurz High School	3601 N Milwaukee AVENUE, Chica	2014	Main	455800	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler

1	QS-2A	51537	Active School	Schurz HS	Carl Schurz High School	3601 N Milwaukee AVENUE, Chicago	2014	Main	455800	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51538	Active School	Senn HS	Nicholas Senn High School	5900 N Glenwood AVENUE, Chicago	2014	Addition 1	33906	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2A	51538	Active School	Senn HS	Nicholas Senn High School	5900 N Glenwood AVENUE, Chicago	2014	Addition 1	33906	Boiler Room	Condensing- Hot Water Boiler
1	QS-5B	51332	Active School	Seward	William H Seward Communication Art	4600 S Hermitage AVENUE, Chicago	2019	Main	46265	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51332	Active School	Seward	William H Seward Communication Art	4600 S Hermitage AVENUE, Chicago	2019	Main	46265	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51412	Active School	Sexton	John Fiske Elementary School	6020 S Langley AVENUE, Chicago	2019	Main	70878	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51412	Active School	Sexton	John Fiske Elementary School	6020 S Langley AVENUE, Chicago	2019	Main	70878	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4B	51247	Active School	Sheridan	Mark Sheridan Math & Science Acad	533 W 27th STREET, Chicago IL 60	2014	Main	68750	Basement	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51247	Active School	Sheridan	Mark Sheridan Math & Science Acad	533 W 27th STREET, Chicago IL 60	2014	Main	68750	Basement	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7A	51358	Active School	Sherman	William T Sherman Elementary Schoc	1000 W 52nd STREET, Chicago IL 60	2014	Main	18423	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7A	51358	Active School	Sherman	William T Sherman Elementary Schoc	1000 W 52nd STREET, Chicago IL 60	2014	Main	18423	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-7A	51359	Active School	Sherwood	Jesse Sherwood Elementary School	245 W 57th STREET, Chicago IL 60	2014	Main	32352	Boiler Room	Boiler Auxiliary- Non Condensing Steam Boiler
1	QS-7A	51359	Active School	Sherwood	Jesse Sherwood Elementary School	245 W 57th STREET, Chicago IL 60	2014	Main	32352	Boiler Room	Non Condensing- Cast Iron- Force Draft- Steam Boiler
1	QS-5B	51333	Active School	Shields	James Shields Elementary School	4250 S Rockwell STREET, Chicago	2014	Main	41030	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5B	51333	Active School	Shields	James Shields Elementary School	4250 S Rockwell STREET, Chicago	2014	Main	41030	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51333	Active School	Shields	James Shields Elementary School	4250 S Rockwell STREET, Chicago	2014	Annex	36100	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5B	51333	Active School	Shields	James Shields Elementary School	4250 S Rockwell STREET, Chicago	2014	Annex	36100	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5B	55216	Active School	Shields Middle Schc	James Shields Middle School	2611 W 48th STREET, Chicago IL 6	2019	Main	95265	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-5B	55216	Active School	Shields Middle Schc	James Shields Middle School	2611 W 48th STREET, Chicago IL 6	2019	Main	95265	Mechanical Room	Condensing- Hot Water Boiler
1	QS-8A	51413	Active School	Shoesmith	Beulah Shoesmith Elementary School	1330 E 50th STREET, Chicago IL 6	2019	Main	36887	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8A	51413	Active School	Shoesmith	Beulah Shoesmith Elementary School	1330 E 50th STREET, Chicago IL 6	2019	Main	36887	Boiler Room	Condensing- Hot Water Boiler
1	QS-9A	51516	Active School	Shoop	John D Shoop Math-Science Technic	11140 S Bishop STREET, Chicago I	2014	Main	88546	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9A	51516	Active School	Shoop	John D Shoop Math-Science Technic	11140 S Bishop STREET, Chicago I	2014	Main	88546	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51604	Active School	Simeon HS	Neal F Simeon Career Academy High	8147 S Vincennes AVENUE, Chicago	2014	Main	210316	Penthouse	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51604	Active School	Simeon HS	Neal F Simeon Career Academy High	8147 S Vincennes AVENUE, Chicago	2014	Main	210316	Penthouse	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-7B	51604	Active School	Simeon HS	Neal F Simeon Career Academy High	8147 S Vincennes AVENUE, Chicago	2014	Linked Addition		Mechanical Room	Boiler Auxiliary- Steam Boiler
1	QS-7B	51604	Active School	Simeon HS	Neal F Simeon Career Academy High	8147 S Vincennes AVENUE, Chicago	2014	Linked Addition		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-4B	51567	Active School	Simpson HS	Simpson Academy HS for Young Wor	1321 S Paulina STREET, Chicago IL	2014	Main	18593	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4B	51567	Active School	Simpson HS	Simpson Academy HS for Young Wor	1321 S Paulina STREET, Chicago IL	2014	Main	18593	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51174	Active School	Skinner North	Skinner North	640 W Scott STREET, Chicago IL 6	2019	Main	68922	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-3B	51174	Active School	Skinner North	Skinner North	640 W Scott STREET, Chicago IL 6	2019	Main	68922	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-4B	54719	Active School	Skinner West	Mark Skinner Elementary School	1260 W Adams STREET, Chicago IL	2014	Main	102055	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4B	54719	Active School	Skinner West	Mark Skinner Elementary School	1260 W Adams STREET, Chicago IL	2014	Main	102055	Boiler Room	Condensing- Hot Water Boiler
1	QS-1B	51035	Active School	Smyser	Washington D Smyser Elementary Sc	4310 N Melvina AVENUE, Chicago	2014	Main	60861	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51035	Active School	Smyser	Washington D Smyser Elementary Sc	4310 N Melvina AVENUE, Chicago	2014	Main	60861	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51035	Active School	Smyser	Washington D Smyser Elementary Sc	4310 N Melvina AVENUE, Chicago	2014	Main	60861	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51035	Active School	Smyser	Washington D Smyser Elementary Sc	4310 N Melvina AVENUE, Chicago	2014	Main	60861	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51035	Active School	Smyser	Washington D Smyser Elementary Sc	4310 N Melvina AVENUE, Chicago	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51250	Active School	Smyth	John M Smyth Elementary School	1059 W 13th STREET, Chicago IL 6	2014	Addition 2	28381	Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-4B	51250	Active School	Smyth	John M Smyth Elementary School	1059 W 13th STREET, Chicago IL 6	2014	Addition 2	28381	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51036	Active School	Solomon	Hannah G Solomon Elementary Scho	6206 N Hamlin AVENUE, Chicago IL	2014	Main	18083	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51036	Active School	Solomon	Hannah G Solomon Elementary Scho	6206 N Hamlin AVENUE, Chicago IL	2014	Main	18083	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-6A	54767	Active School	Solorio HS	Alcott High School for the Humaniti	5400 S St Louis AVENUE, Chicago	2014	Main	213710	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6A	54767	Active School	Solorio HS	Alcott High School for the Humaniti	5400 S St Louis AVENUE, Chicago	2014	Main	213710	Boiler Room	Condensing- Hot Water Boiler
1	QS-4B	58744	Active School	South Loop	South Loop Elementary School	1601 S Dearborn STREET, Chicago	2019	Main (New)		3rd Floor	Boiler Auxiliary- Condensing Hot Water
1	QS-4B	58744	Active School	South Loop	South Loop Elementary School	1601 S Dearborn STREET, Chicago	2019	Main (New)		3rd Floor	Condensing- Hot Water Boiler
1	QS-4B	58744	Active School	South Loop	South Loop Elementary School	1601 S Dearborn STREET, Chicago	2019	Branch @ Plymouth	57995	Boiler Room	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-4B	58744	Active School	South Loop	South Loop Elementary School	1601 S Dearborn STREET, Chicago	2019	Branch @ Plymouth	57995	Boiler Room	Electric- Hot Water Boiler
1	QS-8B	54787	Active School	South Shore Interna	Ogden International High School	1955 E 75th STREET, Chicago IL 6	2014	Main	213710	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8B	54787	Active School	South Shore Interna	Ogden International High School	1955 E 75th STREET, Chicago IL 6	2014	Main	213710	Boiler Room	Condensing- Hot Water Boiler
1	QS-7B	51617	Active School	Southside Occ HS	Southside Occupational Academy Hig	7342 S Hoyne AVENUE, Chicago IL	2019	Main	36840	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-7B	51617	Active School	Southside Occ HS	Southside Occupational Academy Hig	7342 S Hoyne AVENUE, Chicago IL	2019	Main	36840	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-7B	51617	Active School	Southside Occ HS	Southside Occupational Academy Hig	7342 S Hoyne AVENUE, Chicago IL	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-7B	51617	Active School	Southside Occ HS	Southside Occupational Academy Hig	7342 S Hoyne AVENUE, Chicago IL	2019	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4A	51102	Active School	Spencer	Spencer Technology Academy	214 N Laverne AVENUE, Chicago	2019	Main	39496	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-4A	51102	Active School	Spencer	Spencer Technology Academy	214 N Laverne AVENUE, Chicago	2019	Main	39496	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-5A	51280	Active School	Spry Community Lin	John Spry Elementary Community Sc	2400 S Marshall BOULEVARD, Chi	2014	Main	62370	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51280	Active School	Spry Community Lin	John Spry Elementary Community Sc	2400 S Marshall BOULEVARD, Chi	2014	Main	62370	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-7B	51395	Active School	Stagg	Amos Alonzo Stagg Elementary Scho	7424 S Morgan STREET, Chicago IL	2014	Main	68227	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51395	Active School	Stagg	Amos Alonzo Stagg Elementary Scho	7424 S Morgan STREET, Chicago IL	2014	Main	68227	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51553	Active School	Steinmetz HS	Charles P Steinmetz College Preparal	3030 N Mobile AVENUE, Chicago IL	2014	Main	384200	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51553	Active School	Steinmetz HS	Charles P Steinmetz College Preparal	3030 N Mobile AVENUE, Chicago IL	2014	Main	384200	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51553	Active School	Steinmetz HS	Charles P Steinmetz College Preparal	3030 N Mobile AVENUE, Chicago IL	2014	Main	384200	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51553	Active School	Steinmetz HS	Charles P Steinmetz College Preparal	3030 N Mobile AVENUE, Chicago IL	2014	Main	384200	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Main	72903	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Main	72903	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Main	72903	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Main	72903	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Addition	30426	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Addition	30426	Boiler Room	Condensing- Hot Water Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Branch		Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-6B	51309	Active School	Stevenson	Adlai E Stevenson Elementary School	8010 S Kostner AVENUE, Chicago I	2019	Branch		Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler

1	QS-1B	51034	Active School	Stock	Frederick Stock Elementary School	7507 W Birchwood AVENUE, Chicago	2019	Main	17355	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51034	Active School	Stock	Frederick Stock Elementary School	7507 W Birchwood AVENUE, Chicago	2019	Main	17355	Boiler Room	Condensing- Hot Water Boiler
1	QS-2A	51073	Active School	Stockton	Mary E Courtenay Elementary Langue	4420 N Beacon STREET, Chicago I	2014	Main	92490	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2A	51073	Active School	Stockton	Mary E Courtenay Elementary Langue	4420 N Beacon STREET, Chicago I	2014	Main	92490	Boiler Room	Condensing- Hot Water Boiler
1	QS-1A	51074	Active School	Stone	Stone Elementary Scholastic Academ	6239 N Leavitt STREET, Chicago IL	2019	Main	65617	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51074	Active School	Stone	Stone Elementary Scholastic Academ	6239 N Leavitt STREET, Chicago IL	2019	Main	65617	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51129	Active School	Stowe	Harriet Beecher Stowe Elementary Sc	3444 W Wabansia AVENUE, Chicago	2014	Main	113500	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51129	Active School	Stowe	Harriet Beecher Stowe Elementary Sc	3444 W Wabansia AVENUE, Chicago	2014	Main	113500	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	52294	Active School	Suder	Suder Montessori Magnet ES	2022 W Washington BOULEVARD,	2019	Main	71500	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-2B	52294	Active School	Suder	Suder Montessori Magnet ES	2022 W Washington BOULEVARD,	2019	Main	71500	Boiler Room	Condensing- Hot Water Boiler
1	QS-8B	51481	Active School	Sullivan	William K New Sullivan Elementary S	8331 S Mackinaw AVENUE, Chicag	2014	Main	218126	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-8B	51481	Active School	Sullivan	William K New Sullivan Elementary S	8331 S Mackinaw AVENUE, Chicag	2014	Main	218126	Boiler Room	Condensing- Hot Water Boiler
1	QS-1A	51539	Active School	Sullivan HS	Roger C Sullivan High School	6631 N Bosworth AVENUE, Chicag	2019	Main	218067	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51539	Active School	Sullivan HS	Roger C Sullivan High School	6631 N Bosworth AVENUE, Chicag	2019	Main	218067	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51539	Active School	Sullivan HS	Roger C Sullivan High School	6631 N Bosworth AVENUE, Chicag	2019	Main	218067	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51539	Active School	Sullivan HS	Roger C Sullivan High School	6631 N Bosworth AVENUE, Chicag	2019	Main	218067	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Main	47020	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Main	47020	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Annex		Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Annex		Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Annex		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4A	51190	Active School	Sumner	Charles Sumner Math & Science Con	715 S Kildare AVENUE, Chicago IL	2014	Annex		Mechanical Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6B	51447	Active School	Sutherland	Elizabeth H Sutherland Elementary Sc	10015 S Leavitt STREET, Chicago I	2019	Main	69781	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	51447	Active School	Sutherland	Elizabeth H Sutherland Elementary Sc	10015 S Leavitt STREET, Chicago I	2019	Main	69781	Boiler Room	Condensing- Hot Water Boiler
1	QS-6B	51447	Active School	Sutherland	Elizabeth H Sutherland Elementary Sc	10015 S Leavitt STREET, Chicago I	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6B	51447	Active School	Sutherland	Elizabeth H Sutherland Elementary Sc	10015 S Leavitt STREET, Chicago I	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-2A	51075	Active School	Swift	George B Swift Elementary Specialty	5900 N Winthrop AVENUE, Chicagc	2019	Main	66708	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51075	Active School	Swift	George B Swift Elementary Specialty	5900 N Winthrop AVENUE, Chicagc	2019	Main	66708	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51075	Active School	Swift	George B Swift Elementary Specialty	5900 N Winthrop AVENUE, Chicagc	2019	Addition 1	42691	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	51075	Active School	Swift	George B Swift Elementary Specialty	5900 N Winthrop AVENUE, Chicagc	2019	Addition 1	42691	Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-1B	51540	Active School	Taft HS	William Howard Taft High School	6530 W Bryn Mawr AVENUE, Chica	2014	Main	175896	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51540	Active School	Taft HS	William Howard Taft High School	6530 W Bryn Mawr AVENUE, Chica	2014	Main	175896	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3B	51147	Active School	Talcott	Mancel Talcott Elementary School	1840 W Ohio STREET, Chicago IL	2014	Main	91945	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3B	51147	Active School	Talcott	Mancel Talcott Elementary School	1840 W Ohio STREET, Chicago IL	2014	Main	91945	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	52602	Active School	Talman	Talman Elementary School	2644 W 55th STREET, Chicago IL 6	2014	Leased-Annex		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	52602	Active School	Talman	Talman Elementary School	2644 W 55th STREET, Chicago IL 6	2014	Leased-Annex		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6A	52602	Active School	Talman	Talman Elementary School	2644 W 55th STREET, Chicago IL 6	2014	Leased-Annex		Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-6A	52602	Active School	Talman	Talman Elementary School	2644 W 55th STREET, Chicago IL 6	2014	Leased-Annex		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	52602	Active School	Talman	Talman Elementary School	2644 W 55th STREET, Chicago IL 6	2014	Leased-Annex		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	52602	Active School	Talman	Talman Elementary School	2644 W 55th STREET, Chicago IL 6	2014	Leased-Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-7A	51484	Active School	Tanner	Henry O Tanner Elementary School	7350 S Evans AVENUE, Chicago IL	2014	Main	52920	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7A	51484	Active School	Tanner	Henry O Tanner Elementary School	7350 S Evans AVENUE, Chicago IL	2014	Main	52920	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51679	Active School	Tarkington	Tarkington School of Excellence ES	3300 W 71st STREET, Chicago IL 6	2014	Main	136289	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-6B	51679	Active School	Tarkington	Tarkington School of Excellence ES	3300 W 71st STREET, Chicago IL 6	2014	Main	136289	Boiler Room	Condensing- Hot Water Boiler
1	QS-9B	51518	Active School	Taylor	Douglas Taylor Elementary School	9912 S Avenue H AVENUE, Chicag	2014	Main	75318	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51518	Active School	Taylor	Douglas Taylor Elementary School	9912 S Avenue H AVENUE, Chicag	2014	Main	75318	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51518	Active School	Taylor	Douglas Taylor Elementary School	9912 S Avenue H AVENUE, Chicag	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51518	Active School	Taylor	Douglas Taylor Elementary School	9912 S Avenue H AVENUE, Chicag	2014	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5B	51342	Active School	Thomas	Velma F Thomas Early Childhood Cer	3625 S Hoyne AVENUE, Chicago IL	2019	Leased-Main	16056	Adjacent church	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51520	Active School	Thorp J	James N Thorp Elementary School	8914 S Buffalo AVENUE, Chicago IL	2019	Addition 2	47014	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51520	Active School	Thorp J	James N Thorp Elementary School	8914 S Buffalo AVENUE, Chicago IL	2019	Addition 2	47014	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51037	Active School	Thorp O	Ole A Thorp Elementary Scholastic Ac	6024 W Warwick AVENUE, Chicagc	2019	Main	93200	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1B	51037	Active School	Thorp O	Ole A Thorp Elementary Scholastic Ac	6024 W Warwick AVENUE, Chicagc	2019	Main	93200	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5B	51584	Active School	Tilden HS	Edward Tilden Career Community Acc	4747 S Union AVENUE, Chicago IL	2019	Main	328514	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-5B	51584	Active School	Tilden HS	Edward Tilden Career Community Acc	4747 S Union AVENUE, Chicago IL	2019	Main	328514	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-5B	51584	Active School	Tilden HS	Edward Tilden Career Community Acc	4747 S Union AVENUE, Chicago IL	2019	Main	328514	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam High Pressure Boiler
1	QS-8B	51407	Active School	Till	Emmett Louis Till Math and Science A	6543 S Champlain AVENUE, Chicag	2019	Main	47220	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51407	Active School	Till	Emmett Louis Till Math and Science A	6543 S Champlain AVENUE, Chicag	2019	Main	47220	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51407	Active School	Till	Emmett Louis Till Math and Science A	6543 S Champlain AVENUE, Chicag	2019	Annex		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51407	Active School	Till	Emmett Louis Till Math and Science A	6543 S Champlain AVENUE, Chicag	2019	Annex		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-4A	51191	Active School	Tilton	George W Tilton Elementary School	223 N Keeler AVENUE, Chicago IL	2019	Main	77670	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-4A	51191	Active School	Tilton	George W Tilton Elementary School	223 N Keeler AVENUE, Chicago IL	2019	Main	77670	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	51310	Active School	Tonti	Enrico Tonti Elementary School	5815 S Homan AVENUE, Chicago IL	2019	Main	62367	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51310	Active School	Tonti	Enrico Tonti Elementary School	5815 S Homan AVENUE, Chicago IL	2019	Main	62367	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-6A	51310	Active School	Tonti	Enrico Tonti Elementary School	5815 S Homan AVENUE, Chicago IL	2019	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-6A	51310	Active School	Tonti	Enrico Tonti Elementary School	5815 S Homan AVENUE, Chicago IL	2019	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-7B	51465	Active School	Turner-Drew	Turner-Drew Elementary Language Ar	9300 S Princeton AVENUE, Chicag	2019	Main	39077	Entire Building	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-7B	51465	Active School	Turner-Drew	Turner-Drew Elementary Language Ar	9300 S Princeton AVENUE, Chicag	2019	Main	39077	Entire Building	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6A	54221	Active School	Twain Elementary S Mark Twain Elementary School	5134 S Lotus AVENUE, Chicago IL	2019	Main	75820	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler	
1	QS-6A	54221	Active School	Twain Elementary S Mark Twain Elementary School	5134 S Lotus AVENUE, Chicago IL	2019	Main	75820	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler	
1	QS-6A	54221	Active School	Twain Elementary S Mark Twain Elementary School	5134 S Lotus AVENUE, Chicago IL	2019	Main	75820	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler	
1	QS-6A	54221	Active School	Twain Elementary S Mark Twain Elementary School	5134 S Lotus AVENUE, Chicago IL	2019	Main	75820	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler	



1	QS-6A	54221	Active School	Twain Elementary S	Twain Elementary School	5134 S Lotus AVENUE, Chicago IL	2019	Main	75820	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	52495	Active School	Uplift	Uplift Community High School	900 W Wilson AVENUE, Chicago IL	2019	Linked Addition-Athletic Building		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2A	52495	Active School	Uplift	Uplift Community High School	900 W Wilson AVENUE, Chicago IL	2019	Linked Addition-Athletic Building		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-6B	51448	Active School	Vanderpoel	John H Vanderpoel Elementary Magn	9510 S Prospect AVENUE, Chicago	2019	Main	32562	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-6B	51448	Active School	Vanderpoel	John H Vanderpoel Elementary Magn	9510 S Prospect AVENUE, Chicago	2019	Main	32562	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-6B	51448	Active School	Vanderpoel	John H Vanderpoel Elementary Magn	9510 S Prospect AVENUE, Chicago	2019	Main	32562	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51544	Active School	Vaughn Occ HS	Jacqueline B Vaughn Occupational Hi	4355 N Linder AVENUE, Chicago IL	2019	Main	50289	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-1B	51544	Active School	Vaughn Occ HS	Jacqueline B Vaughn Occupational Hi	4355 N Linder AVENUE, Chicago IL	2019	Main	50289	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-6B	51429	Active School	Vick	Barbara Vick Early Childhood & Famil	2554 W 113th STREET, Chicago IL	2019	Main	12479	Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water Boiler
1	QS-6B	51429	Active School	Vick	Barbara Vick Early Childhood & Famil	2554 W 113th STREET, Chicago IL	2019	Main	12479	Mechanical Room	Non Condensing- Cast Iron- Force Draft- Hot Water Boiler
1	QS-6B	51429	Active School	Vick	Barbara Vick Early Childhood & Famil	2554 W 113th STREET, Chicago IL	2019	Leased-Branch		Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-6B	51429	Active School	Vick	Barbara Vick Early Childhood & Famil	2554 W 113th STREET, Chicago IL	2019	Leased-Branch		Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-1A	51038	Active School	Volta	Alessandro Volta Elementary School	4950 N Avers AVENUE, Chicago IL	2014	Main	67204	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-1A	51038	Active School	Volta	Alessandro Volta Elementary School	4950 N Avers AVENUE, Chicago IL	2014	Main	67204	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1A	51038	Active School	Volta	Alessandro Volta Elementary School	4950 N Avers AVENUE, Chicago IL	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-1A	51038	Active School	Volta	Alessandro Volta Elementary School	4950 N Avers AVENUE, Chicago IL	2014	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-1A	51541	Active School	Von Steuben HS	Friedrich W von Steuben Metropolitan	5039 N Kimball AVENUE, Chicago I	2014	Main	248453	Boiler Room	Boiler Auxiliary- Steam Boiler
1	QS-1A	51541	Active School	Von Steuben HS	Friedrich W von Steuben Metropolitan	5039 N Kimball AVENUE, Chicago I	2014	Main	248453	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-7B	51452	Active School	Wacker	Charles H Wacker Elementary School	9746 S Morgan STREET, Chicago I	2014	Main	27552	Entire Building	Boiler Auxiliary- Steam Boiler
1	QS-7B	51452	Active School	Wacker	Charles H Wacker Elementary School	9746 S Morgan STREET, Chicago I	2014	Main	27552	Entire Building	Non Condensing- Water Tube- Flexible Tube- Force Draft- Steam Boiler
1	QS-5A	51251	Active School	Walsh	John A Walsh Elementary School	2015 S Peoria STREET, Chicago IL	2014	Main	50106	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51251	Active School	Walsh	John A Walsh Elementary School	2015 S Peoria STREET, Chicago IL	2014	Main	50106	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	51251	Active School	Walsh	John A Walsh Elementary School	2015 S Peoria STREET, Chicago IL	2014	Addition	23182	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51251	Active School	Walsh	John A Walsh Elementary School	2015 S Peoria STREET, Chicago IL	2014	Addition	23182	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-4B	51252	Active School	Ward J	James Ward Elementary School	2701 S Shields AVENUE, Chicago I	2014	Main	24724	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-4B	51252	Active School	Ward J	James Ward Elementary School	2701 S Shields AVENUE, Chicago I	2014	Main	24724	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	52590	Active School	Warren	Joseph Warren Elementary School	9239 S Jeffery BOULEVARD, Chica	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	52590	Active School	Warren	Joseph Warren Elementary School	9239 S Jeffery BOULEVARD, Chica	2014	Annex		Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-9B	51521	Active School	Washington G	George Washington Elementary Scho	3611 E 114th STREET, Chicago IL	2014	Main	54934	Boiler Room	Boiler Auxiliary- Electric- Hot Water Boiler
1	QS-9B	51521	Active School	Washington G	George Washington Elementary Scho	3611 E 114th STREET, Chicago IL	2014	Main	54934	Boiler Room	Electric- Hot Water Boiler
1	QS-9B	51521	Active School	Washington G	George Washington Elementary Scho	3611 E 114th STREET, Chicago IL	2014	Annex		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-9B	51521	Active School	Washington G	George Washington Elementary Scho	3611 E 114th STREET, Chicago IL	2014	Annex		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-9B	51633	Active School	Washington G HS	George Washington High School	3535 E 114th STREET, Chicago IL	2014	Main	214541	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51633	Active School	Washington G HS	George Washington High School	3535 E 114th STREET, Chicago IL	2014	Main	214541	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-9B	51476	Active School	Washington H	Harold Washington Elementary Schoc	9130 S University AVENUE, Chicag	2014	Main	77300	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-9B	51476	Active School	Washington H	Harold Washington Elementary Schoc	9130 S University AVENUE, Chicag	2014	Main	77300	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51077	Active School	Waters	Thomas J Waters Elementary School	4540 N Campbell AVENUE, Chicag	2014	Main	58148	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2A	51077	Active School	Waters	Thomas J Waters Elementary School	4540 N Campbell AVENUE, Chicag	2014	Main	58148	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2A	51077	Active School	Waters	Thomas J Waters Elementary School	4540 N Campbell AVENUE, Chicag	2014	Linked Addition		Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-4A	51215	Active School	Webster	Daniel Webster Elementary School	4055 W Arthington STREET, Chicag	2014	Main	60295	Boiler Room	Condensing- Hot Water Boiler
1	QS-4A	51215	Active School	Webster	Daniel Webster Elementary School	4055 W Arthington STREET, Chicag	2014	Main	60295	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51555	Active School	Wells HS	Wells Community Academy High Sch	936 N Ashland AVENUE, Chicago II	2014	Main	264101	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51555	Active School	Wells HS	Wells Community Academy High Sch	936 N Ashland AVENUE, Chicago II	2014	Main	264101	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-2B	51555	Active School	Wells HS	Wells Community Academy High Sch	936 N Ashland AVENUE, Chicago II	2014	Main	264101	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51555	Active School	Wells HS	Wells Community Academy High Sch	936 N Ashland AVENUE, Chicago II	2014	Main	264101	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51126	Active School	West Park	West Park Elementary Academy	1425 N Tripp AVENUE, Chicago IL	2014	Main	81350	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-3A	51126	Active School	West Park	West Park Elementary Academy	1425 N Tripp AVENUE, Chicago IL	2014	Main	81350	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-1A	54766	Active School	West Ridge	West Ridge Elementary School	6700 N Whipple STREET, Chicago	2014	Main	100107	Mechanical Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1A	54766	Active School	West Ridge	West Ridge Elementary School	6700 N Whipple STREET, Chicago	2014	Main	100107	Mechanical Room	Condensing- Hot Water Boiler
1	QS-9A	51523	Active School	Whistler	John Whistler Elementary School	11533 S Ada STREET, Chicago IL	2019	Main	42600	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-9A	51523	Active School	Whistler	John Whistler Elementary School	11533 S Ada STREET, Chicago IL	2019	Main	42600	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-9A	51523	Active School	Whistler	John Whistler Elementary School	11533 S Ada STREET, Chicago IL	2019	Addition 2	32950	Boiler Room	Boiler Auxiliary- Scotch Marine- Hot Water Boiler
1	QS-9A	51523	Active School	Whistler	John Whistler Elementary School	11533 S Ada STREET, Chicago IL	2019	Addition 2	32950	Boiler Room	Non Condensing- Scotch Marine- Hot Water Boiler
1	QS-5A	51282	Active School	Whitney	Eli Whitney Elementary School	2815 S Komensky AVENUE, Chicag	2014	Main	73614	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51282	Active School	Whitney	Eli Whitney Elementary School	2815 S Komensky AVENUE, Chicag	2014	Main	73614	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-5A	51282	Active School	Whitney	Eli Whitney Elementary School	2815 S Komensky AVENUE, Chicag	2014	Annex		Mechanical Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51282	Active School	Whitney	Eli Whitney Elementary School	2815 S Komensky AVENUE, Chicag	2014	Annex		Mechanical Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-5A	51253	Active School	Whittier Elementary	John Greenleaf Whittier Elementary S	1900 W 23rd STREET, Chicago IL	2014	Main	49232	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51253	Active School	Whittier Elementary	John Greenleaf Whittier Elementary S	1900 W 23rd STREET, Chicago IL	2014	Main	49232	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-1B	51040	Active School	Wildwood	Wildwood IB World Magnet School	6950 N Hiawatha AVENUE, Chicag	2014	Main	24950	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-1B	51040	Active School	Wildwood	Wildwood IB World Magnet School	6950 N Hiawatha AVENUE, Chicag	2014	Main	24950	Boiler Room	Condensing- Hot Water Boiler
1	QS-8A	51255	Active School	Williams	John B Drake Elementary School	2710 S Dearborn STREET, Chicagc	2014	Main	141400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51255	Active School	Williams	John B Drake Elementary School	2710 S Dearborn STREET, Chicagc	2014	Main	141400	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	51255	Active School	Williams	John B Drake Elementary School	2710 S Dearborn STREET, Chicagc	2014	Main	141400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	51255	Active School	Williams	John B Drake Elementary School	2710 S Dearborn STREET, Chicagc	2014	Main	141400	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51403	Active School	Woodlawn	Woodlawn Community Elementary Sc	6657 S Kimbark AVENUE, Chicago	2014	Main	30193	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8B	51403	Active School	Woodlawn	Woodlawn Community Elementary Sc	6657 S Kimbark AVENUE, Chicago	2014	Main	30193	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8B	51403	Active School	Woodlawn	Woodlawn Community Elementary Sc	6657 S Kimbark AVENUE, Chicago	2014	Main	30193	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-8A	53477	Active School	Woodson	Carter G Woodson South Elementary	4414 S Evans AVENUE, Chicago IL	2014	Linked Addition-Center building Gym		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-8A	53477	Active School	Woodson	Carter G Woodson South Elementary	4414 S Evans AVENUE, Chicago IL	2014	Linked Addition-Center building Gym		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51130	Active School	Yates	Richard Yates Elementary School	1839 N Richmond STREET, Chicag	2019	Addition	58800	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler

1	QS-2B	51130	Active School	Yates	Richard Yates Elementary School	1839 N Richmond STREET, Chicag	2019	Addition	58800	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-2B	51130	Active School	Yates	Richard Yates Elementary School	1839 N Richmond STREET, Chicag	2019	Linked Addition		Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-2B	51130	Active School	Yates	Richard Yates Elementary School	1839 N Richmond STREET, Chicag	2019	Linked Addition		Boiler Room	Non Condensing- Flexible Tube- Atmospheric- Hot Water Boiler
1	QS-3A	51103	Active School	Young Elementary S	Ella Flagg Young Elementary School	1434 N Parkside AVENUE, Chicago	2014	Main	107359	Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-3A	51103	Active School	Young Elementary S	Ella Flagg Young Elementary School	1434 N Parkside AVENUE, Chicago	2014	Main	107359	Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler
1	QS-3A	51103	Active School	Young Elementary S	Ella Flagg Young Elementary School	1434 N Parkside AVENUE, Chicago	2014	Addition	69645	Boiler Room	Boiler Auxiliary- Condensing Hot Water
1	QS-3A	51103	Active School	Young Elementary S	Ella Flagg Young Elementary School	1434 N Parkside AVENUE, Chicago	2014	Addition	69645	Boiler Room	Condensing- Hot Water Boiler
1	QS-5A	51274	Active School	Zapata	Emiliano Zapata Elementary Academy,	2728 S Kostner AVENUE, Chicago I	2014	Main	73845	Boiler Room	Boiler Auxiliary- Non Condensing Hot Water
1	QS-5A	51274	Active School	Zapata	Emiliano Zapata Elementary Academy,	2728 S Kostner AVENUE, Chicago I	2014	Main	73845	Boiler Room	Non Condensing- Water Tube- Flexible Tube- Force Draft- Hot Water Boiler
1	QS-5A	51274	Active School	Zapata	Emiliano Zapata Elementary Academy,	2728 S Kostner AVENUE, Chicago I	2014	Branch		Boiler Room	Boiler Auxiliary- Scotch Marine- Steam Low Pressure Boiler
1	QS-5A	51274	Active School	Zapata	Emiliano Zapata Elementary Academy,	2728 S Kostner AVENUE, Chicago I	2014	Branch		Boiler Room	Non Condensing- Fire Tube- Scotch Marine- Steam- Low Pressure Boiler

CPS Chillers

Biddable	Quality Region	FCID	Property Use	Campus Name	School Name	Address	Assess Year	Building Name	Building	Location	Item Name
1	Q5-4B	51230	Active School	Abbott	Air Force Academy High School	3630 S Wells STREET, Chicago IL 60609	2019	Addition 2	38154	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-9B	51495	Active School	Addams	Jane Addams Elementary School	10810 S Avenue H, Chicago IL 60617	2019	Addition	3959	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-1A	54187	Active School	Albany Park/ Edison	Albany Park Multicultural Academy	4929 N Sawyer AVENUE, Chicago IL 60625	2014	Main	104203	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51109	Active School	Ames	Marine Leadership Academy at Ames	1920 N Hamlin AVENUE, Chicago IL 60647	2014	Main	126540	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-8A	51401	Active School	Ariel Elementary Community Academy	Ariel Elementary Community Academy	1119 E 46th STREET, Chicago IL 60653	2019	Addition 1	59963	Site South	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-1A	51044	Active School	Armstrong G	George Armstrong International Studies ES	2110 W Greenleaf AVENUE, Chicago IL 60645	2019	Addition 2	70296	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-3A	51675	Active School	Austin Community High School	Austin College and Career Academy High School	231 N Pine AVENUE, Chicago IL 60644	2014	Main	397258	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-6B	54768	Active School	Azuela	Mariano Azuela Elementary School	4707 W Marquette ROAD, Chicago IL 60629	2014	Main	94600	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-5B	59215	Active School	Back of the Yards	Back of the Yards IB HS	2111 W 47 STREET, Chicago IL 60609	2014	Main	212285	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-1A	51046	Active School	Bateman	Newton Bateman Elementary School	4220 N Richmond STREET, Chicago IL 60618	2019	Addition	58757	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-1B	52519	Active School	Beard	Daniel C Beard Elementary School	6445 W Strong STREET, Chicago IL 60656	2019	Linked Addition		Courtyard	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-2B	51180	Active School	Beidler	Jacob Beidler Elementary School	3151 W Walnut STREET, Chicago IL 60612	2019	Addition	39450	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3B	51047	Active School	Bell	Alexander Graham Bell Elementary School	3730 N Oakley AVENUE, Chicago IL 60618	2019	Addition	19000	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-9B	51493	Active School	Black	Robert A Black Magnet Elementary School	7133 S Coles AVENUE, Chicago IL 60649	2019	Branch	34329	Basement	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-6A	51304	Active School	Blair	Blair Early Childhood Center	6751 W 63rd PLACE, Chicago IL 60638	2019	Addition	23160	Roof	Chiller-Air Cooled- Recipitating-Roof Mounted
1	Q5-9B	51627	Active School	Bowen Multiplex Facility	Bowen High School	2710 E 89th STREET, Chicago IL 60617	2019	Addition 4	82150	Site North	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-5B	51285	Active School	Brighton Park	Brighton Park Elementary School	3825 S Washtenaw AVENUE, Chicago IL 60632	2014	Addition 2	53000	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-8A	51685	Active School	Bronzeville Classical @ Hartigan	Bronzeville Classical Elementary School	8 W Root STREET, Chicago IL 60609	2019	Main		Grade Mounted outside Me	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-9A	51632	Active School	Brooks	Gwendolyn Brooks College Preparatory Academy	250 E 111th STREET, Chicago IL 60628	2019	Addition 1	50957	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-9A	51512	Active School	Brown R	Ronald Brown Elementary Community Academy	12607 S Union AVENUE, Chicago IL 60628	2019	Main	36229	Enclosure off boiler room	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-3A	51088	Active School	Brunson	Milton Brunson Math & Science Specialty ES	932 N Central AVENUE, Chicago IL 60651	2014	Main	102700	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51088	Active School	Brunson	Milton Brunson Math & Science Specialty ES	932 N Central AVENUE, Chicago IL 60651	2014	Main	102700	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51087	Active School	Burbank	Luther Burbank Elementary School	2035 N Mobile AVENUE, Chicago IL 60639	2019	Main	90517	Parking lot	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-3A	51087	Active School	Burbank	Luther Burbank Elementary School	2035 N Mobile AVENUE, Chicago IL 60639	2019	Addition	74847	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-6A	51289	Active School	Byrne	Michael M Byrne Elementary School	5329 S Oak Park AVENUE, Chicago IL 60638	2019	Addition 1	17326	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-6A	51289	Active School	Byrne	Michael M Byrne Elementary School	5329 S Oak Park AVENUE, Chicago IL 60638	2019	Addition 3	36830	Site - East	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-5B	51286	Active School	Calmea Elementary School	Calmea Academy of Fine Arts and Dual Language	3456 W 38th STREET, Chicago IL 60632	2019	Main	108624	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-1B	51005	Active School	Canty	Arthur E Canty Elementary School	3740 N Panama AVENUE, Chicago IL 60634	2019	Main	41329	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-1B	51005	Active School	Canty	Arthur E Canty Elementary School	3740 N Panama AVENUE, Chicago IL 60634	2019	Addition 3	39475	Entire Building	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-6B	51425	Active School	Carroll	Carroll-Rosenwald Specialty Elementary School	2929 W 83rd STREET, Chicago IL 60652	2019	Main	26642	Site - East	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-6A	52327	Active School	Carson	Rachel Carson Elementary School	2550 W 56th STREET, Chicago IL 60629	2019	Annex	75380	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-4A	51117	Active School	Casals	Pablo Casals Elementary School	3501 W Potomac AVENUE, Chicago IL 60651	2014	Main	66550	Mechanical Room	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-6B	51426	Active School	Cassell	George F Cassell Elementary School	11314 S Spaulding AVENUE, Chicago IL 60655	2019	Addition	14700	Site South	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-2B	51199	Active School	Chalmers	Thomas Chalmers Specialty Elementary School	2745 W Roosevelt ROAD, Chicago IL 60608	2019	Main	56732	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-2B	51199	Active School	Chalmers	Thomas Chalmers Specialty Elementary School	2745 W Roosevelt ROAD, Chicago IL 60608	2019	Main	56732	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-3B	52415	Active School	Chase	Salmon P Chase Elementary School	2021 N Point STREET, Chicago IL 60647	2014	Linked Addition		Boiler Room	Chiller-Water Cooled- Cetrifugal
1	Q5-5B	51330	Active School	Chavez	Cesar E Chavez Multicultural Academic Center ES	4747 S Marshfield AVENUE, Chicago IL 60609	2019	Main	68408	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-1B	51041	Active School	Chicago Academy School @ Wright College	Chicago Academy Elementary School	3400 N Austin AVENUE, Chicago IL 60634	2019	Leased-Main	231712	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-6B	54361	Active School	Chicago Ag HS	Chicago High School for Agricultural Sciences	3807 W 111th STREET, Chicago IL 60655	2019	Linked Addition		Site West	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-8A	51589	Active School	Chicago Military HS	Chicago Military Academy High School	3533 S Giles AVENUE, Chicago IL 60653	2019	Addition	53804	Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-8B	51625	Active School	Chicago Vocational	Chicago Vocational Career Academy High School	2100 E 87th STREET, Chicago IL 60617	2014	Main	521300	Boiler Room	Chiller-Water Cooled- Cetrifugal
1	Q5-6A	51341	Active School	Claremont	Claremont Academy Elementary School	2300 W 64th STREET, Chicago IL 60636	2019	Main	112806	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51086	Active School	Clark Elem	George Rogers Clark Elementary School	1045 S Monitor AVENUE, Chicago IL 60644	2014	Addition	32700	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2B	51556	Active School	Clemente HS	Roberto Clemente Community Academy High Sch	1147 N Western AVENUE, Chicago IL 60622	2019	Main	354518	Penthouse	Chiller-Water Cooled- Cetrifugal
1	Q5-2B	51556	Active School	Clemente HS	Roberto Clemente Community Academy High Sch	1147 N Western AVENUE, Chicago IL 60622	2019	Main	354518	Penthouse	Chiller-Water Cooled- Cetrifugal
1	Q5-2A	51053	Active School	Clinton	DeWitt Clinton Elementary School	6110 N Fairfield AVENUE, Chicago IL 60659	2019	Addition 2	34416	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-9A	51519	Active School	Colemon	Johnnie Colemon Elementary Academy	1441 W 119th STREET, Chicago IL 60643	2019	Main	34600	Site North	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-5B	51279	Active School	Columbia Explorers	Columbia Explorers Elementary Academy	4520 S Kedzie AVENUE, Chicago IL 60632	2019	Main	83500	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2A	51594	Active School	Coonley	John C Coonley Elementary School	4046 N Leavitt STREET, Chicago IL 60618	2019	Annex		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-4B	51564	Active School	Crane HS	Richard T Crane Medical Preparatory HS	2245 W Jackson BOULEVARD, Chicago IL 60612	2019	Main	371560	2nd Floor	Chiller-Water Cooled- Cetrifugal
1	Q5-7B	51436	Active School	Cuffe	Paul Cuffe Math-Science Technology Academy ES	8324 S Racine AVENUE, Chicago IL 60620	2014	Main	82120	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5B	51334	Active School	Daley	Richard J Daley Elementary Academy	5024 S Wolcott AVENUE, Chicago IL 60609	2019	Main	73350	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-7A	54217	Active School	Davis M Magnet	Sir Miles Davis Magnet Elementary Academy	6740 S Paulina STREET, Chicago IL 60636	2014	Main	104200	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5B	53959	Active School	Davis N	Nathan S Davis Elementary School	3050 W 39th PLACE, Chicago IL 60632	2019	Annex	34018	Entire Building	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-7A	51377	Active School	Deneen	Charles S Deneen Elementary School	7240 S Wabash AVENUE, Chicago IL 60619	2019	Addition 3	32350	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51107	Active School	DePriest	Oscar DePriest Elementary School	139 S Parkside AVENUE, Chicago IL 60644	2019	Main	106650	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-1B	51008	Active School	Dever	William E Dever Elementary School	3436 N Osceola AVENUE, Chicago IL 60634	2019	Main	38530	Site North	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-1A	51019	Active School	Disney II (Irving Park)	Disney II Magnet School	3815 N Kedvale AVENUE, Chicago IL 60641	2019	Main	50560	Site - East	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-7B	51464	Active School	Dixon	Arthur Dixon Elementary School	8306 S Saint Lawrence AVENUE, Chicago IL 60619	2014	Main	101627	Courtyard	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 60638	2019	Main		Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6A	58212	Active School	Dore	John C Dore Elementary School	7134 W 65th STREET, Chicago IL 60638	2019	Branch-Old-Main		Site West	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-8B	51418	Active School	Dumas	James Wadsworth Elementary School	6650 S Ellis AVENUE, Chicago IL 60637	2019	Main	64558	Site West	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-4A	51218	Active School	Dvorak	Dvorak Technology Academy	3615 W 16th STREET, Chicago IL 60623	2019	Main	69287	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6A	51293	Active School	Eberhart	John F Eberhart Elementary School	3400 W 65th PLACE, Chicago IL 60629	2014	Addition	81635	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-1B	51010	Active School	Edgebrook	Edgebrook Elementary School	6525 N Hiawatha AVENUE, Chicago IL 60646	2019	Addition 3	35298	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-1B	51001	Active School	Edison Park	Edison Park Elementary School	6220 N Olcott AVENUE, Chicago IL 60631	2019	Main	34423	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-1B	51001	Active School	Edison Park	Edison Park Elementary School	6220 N Olcott AVENUE, Chicago IL 60631	2019	Addition	26052	Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-5B	51294	Active School	Edwards	Richard Edwards Elementary School	4815 S Karlov AVENUE, Chicago IL 60632	2019	Addition 2	50193	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-5B	51294	Active School	Edwards	Richard Edwards Elementary School	4815 S Karlov AVENUE, Chicago IL 60632	2019	Branch		North Courtyard	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-3A	54725	Active School	Ellington Elementary School - 54725	Edward K Ellington Elementary School	243 N Parkside AVENUE, Chicago IL 60644	2014	Main	112380	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5B	51340	Active School	Evergreen	Evergreen Academy Middle School	3537 S Paulina STREET, Chicago IL 60609	2014	Main	50060	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51011	Active School	Falconer	Laughlin Falconer Elementary School	3020 N Lamon AVENUE, Chicago IL 60641	2019	Addition	82797	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-1B	51012	Active School	Farnsworth	James B Farnsworth Elementary School	5414 N Linder AVENUE, Chicago IL 60630	2019	Main	76762	Site West	Chiller-Air Cooled-Scroll Type-Ground Mounted

1	Q5-5A	51581	Active School	Farragut HS	David G Farragut Career Academy High School	2345 S Christiana AVENUE, Chicago IL 60623	2019	Main	136264	Entire Building	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-3B	54119	Active School	Funston	Frederick Funston Elementary School	3616 W Armitage AVENUE, IL 60647	2014	Linked Addition		Main Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-1A	52447	Active School	Gale	Stephen F Gale Elementary Community Academy	7650 N Marshfield AVENUE, Chicago IL 60626	2019	Annex		Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-1B	51013	Active School	Garvy J	John W Garvy Elementary School	5225 N Oak Park AVENUE, Chicago IL 60656	2019	Addition 2	33345	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-4A	54663	Active School	George Westinghouse High School	George Westinghouse College Prep	3223 W Franklin BOULEVARD, Chicago IL 60624	2014	Main	224604	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2A	51059	Active School	Goudy	William C. Goudy Technology Academy	5120 N Winthrop AVENUE, Chicago IL 60640	2019	Addition 2	42116	Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-1B	54101	Active School	Gray	William P Gray Elementary School	3730 N Laramie AVENUE, IL 60641	2019	Annex		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5B	51323	Active School	Greene N	Nathanael Greene Elementary School	3525 S Honore STREET, Chicago IL 60609	2019	Main	82455	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-6A	51296	Active School	Hale	Nathan Hale Elementary School	6140 S Melvina AVENUE, Chicago IL 60638	2019	Addition	35910	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-5B	51324	Active School	Hamline	John H Hamline Elementary School	4747 S Bishop STREET, Chicago IL 60609	2019	Addition	35521	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5B	51324	Active School	Hamline	John H Hamline Elementary School	4747 S Bishop STREET, Chicago IL 60609	2019	Branch	37552	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-5A	51204	Active School	Hammond	Charles G Hammond Elementary School	2819 W 21st PLACE, Chicago IL 60623	2014	Main	38104	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6B	51288	Active School	Hampton	Lionel Hampton Fine & Performing Arts ES	3434 W 77th STREET, Chicago IL 60652	2019	Main	98776	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6A	51605	Active School	Hancock HS	John Hancock College Preparatory High School	4034 W 56th STREET, Chicago IL 60629	2014	Main	169086	Site North	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2A	52465	Active School	Hayt	Stephen K Hayt Elementary School	1518 W Granville AVENUE, Chicago IL 60660	2019	Linked Addition		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-4B	51260	Active School	Healy	Robert Healy Elementary School	3040 S Parnell AVENUE, Chicago IL 60616	2019	Annex		Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-6A	52467	Active School	Hearst	Phoebe Apperson Hearst Elementary School	4640 S Lamont AVENUE, Chicago IL 60638	2014	Main		Lower Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-5B	51325	Active School	Hedges	James Hedges Elementary School	4747 S Winchester AVENUE, Chicago IL 60609	2019	Addition	51015	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-7A	51326	Active School	Henderson	Charles R Henderson Elementary School	5650 S Wolcott AVENUE, Chicago IL 60636	2014	Main	81110	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6A	54697	Active School	Hernandez	Irene C. Hernandez Middle School for the Advanc	3510 W 55th STREET, Chicago IL 60632	2014	Main	127162	Lower Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-1A	51017	Active School	Hibbard	William G Hibbard Elementary School	3244 W Ainslie STREET, Chicago IL 60625	2019	Addition	72800	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-1B	51018	Active School	Hitch	Rufus M Hitch Elementary School	5625 N McVicker AVENUE, Chicago IL 60646	2019	Main	72250	Mechanical Building/Centra	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-4B	52307	Active School	Hope Institue	Hope Institute Learning Academy	1628 W Washington BOULEVARD, Chicago IL 60612	2014	Main	208370	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-9A	54705	Active School	Hughes L	Langston Hughes Elementary School	240 W 104th STREET, Chicago IL 60628	2014	Main	100000	Chiller Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6A	51298	Active School	Hurley	Edward N Hurley Elementary School	3849 W 69th PLACE, Chicago IL 60629	2019	Main	35666	Site South	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-8B	51612	Active School	Hyde Park HS	Hyde Park Academy High School	6220 S Stony Island AVENUE, Chicago IL 60637	2014	Addition 2	22050	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-2B	51211	Active School	Irving Elementary School	Washington Irving Elementary School	749 S Oakley BOULEVARD, Chicago IL 60612	2019	Main	55148	Main Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-4B	51243	Active School	Jackson A	Andrew Jackson Elementary Language Academy	1340 W Harrison STREET, Chicago IL 60607	2019	Main	74135	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2A	51063	Active School	Jamieson	Minnie Mars Jamieson Elementary School	5650 N Mozart STREET, Chicago IL 60659	2019	Addition 2	37761	1st Floor	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-4B	51563	Active School	Jones HS	William Jones College Preparatory High School	606 S State STREET, Chicago IL 60605	2014	Linked Addition-Bldg A (Old Main)		Mechanical Room	Chiller-Water Cooled- Absorber
1	Q5-1A	51054	Active School	Jordan	Jordan Elementary Community School	7414 N Wolcott AVENUE, Chicago IL 60626	2019	Main	66950	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-5A	51570	Active School	Juarez HS	Benito Juarez Community Academy High School	1510 W Cermak ROAD, Chicago IL 60608	2019	Main-Building C	158600	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-6B	51442	Active School	Keller	Annie Keller Regional Gifted Center	3020 W 108th STREET, Chicago IL 60655	2019	Main	36864	Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago IL 60632	2019	Addition	73769	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-5B	51582	Active School	Kelly HS	Thomas Kelly College Preparatory	4136 S California AVENUE, Chicago IL 60632	2019	Addition	73769	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-6A	51299	Active School	Kennedy/Kinzie	John F Kennedy High School	5625 S Mobile AVENUE, Chicago IL 60638	2014	Main (Kinzie)	111615	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-6A	51299	Active School	Kennedy/Kinzie	John F Kennedy High School	5625 S Mobile AVENUE, Chicago IL 60638	2014	Linked Addition (K	233791	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-8A	51586	Active School	Kenwood	Kenwood Academy High School	5015 S Blackstone AVENUE, Chicago IL 60615	2014	Main-Academic U	105996	Boiler Room	Chiller-Water Cooled- Absorber
1	Q5-1A	58049	Active School	Kilmer	Joyce Kilmer Elementary School	6700 N Greenview AVENUE, Chicago IL 60626	2019	Linked Addition		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-8B	51588	Active School	King HS	Dr Martin Luther King Jr. College Prep HS	4445 S Drexel BOULEVARD, Chicago IL 60653	2019	Main	310545	Mechanical Room	Chiller-Water Cooled- Absorber
1	Q5-8B	51588	Active School	King HS	Dr Martin Luther King Jr. College Prep HS	4445 S Drexel BOULEVARD, Chicago IL 60653	2019	Main	310545	Mechanical Room	Chiller-Water Cooled- Absorber
1	Q5-5B	51327	Active School	Lara	Agustin Lara Elementary School	4619 S Wolcott AVENUE, Chicago IL 60609	2019	Main	67964	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-9A	51449	Active School	Lavizzo	Mildred I Lavizzo Elementary School	138 W 109th STREET, Chicago IL 60628	2014	Main	83900	Main Roof	Chiller-Air Cooled- Recipitating-Roof Mounted
1	Q5-6A	51313	Active School	Lee	Richard Henry Lee Elementary School	6448 S Tripp AVENUE, Chicago IL 60629	2014	Main	10687	Site - East	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	Q5-3A	51094	Active School	Lewis	Leslie Lewis Elementary School	1431 N Leamington AVENUE, Chicago IL 60651	2014	Main	63800	Entire Building	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-3A	51094	Active School	Lewis	Leslie Lewis Elementary School	1431 N Leamington AVENUE, Chicago IL 60651	2014	Addition	65153	Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-7A	52292	Active School	Lindblom HS	Robert Lindblom Math & Science Academy HS	6130 S Wolcott AVENUE, Chicago IL 60636	2014	Main	305788	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-7A	52292	Active School	Lindblom HS	Robert Lindblom Math & Science Academy HS	6130 S Wolcott AVENUE, Chicago IL 60636	2014	Main	305788	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3B	52616	Active School	Linne	Carl von Linne Elementary School	3221 N Sacramento AVENUE, Chicago IL 60618	2019	Addition 2	32830	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5A	51264	Active School	Little Village Elem	Little Village Elementary School	2620 S Lawndale AVENUE, Chicago IL 60623	2014	Main	68870	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-5A	51638	Active School	Little Village Multiplex	Greater Lawndale High School For Social Justice	3120 S Kostner AVENUE, Chicago IL 60623	2014	Main	290134	Lower Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	51095	Active School	Locke J	Joyce Kilmer Elementary School	2828 N Oak Park AVENUE, Chicago IL 60634	2014	Linked Addition		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3B	51158	Active School	Logandale	Avondale-Logandale Elementary School	2945 N Sawyer AVENUE, Chicago IL 60618	2019	Annex		Site West	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-2A	54765	Active School	Lorca	Federico Garcia Lorca Elementary School	3231 N Springfield AVENUE, Chicago IL 60618	2014	Main	105599	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2B	51686	Active School	Lozano / Rowe Charter	Rowe Elementary Charter School	1501 N Greenview AVENUE, Chicago IL 60642	2014	Annex (Lozano)			Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3A	52617	Active School	Lyon	Mary Lyon Elementary School	2941 N McVicker AVENUE, Chicago IL 60634	2019	Addition	53326	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-5A	51281	Active School	Madero	Francisco I Madero Middle School	3202 W 28th STREET, Chicago IL 60623	2014	Main	62071	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-3B	51167	Active School	Manierre	George Manierre Elementary School	1420 N Hudson AVENUE, Chicago IL 60610	2014	Addition 3_ Fergus	24110	Mechanical Room	Chiller-Air Cooled- Recipitating-Roof Mounted
1	Q5-9B	54222	Active School	Marsh ES	John L Marsh Elementary School	9822 S Exchange AVENUE, Chicago IL 60617	2014	Addition	83300	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2A	51535	Active School	Mather HS	Stephen T Mather High School	5835 N Lincoln AVENUE, Chicago IL 60659	2014	Main	169809	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-3B	51168	Active School	Mayer	Oscar Mayer Magnet School	2250 N Clifton AVENUE, Chicago IL 60614	2019	Main	73514	Site North	Chiller-Air Cooled-Screw Type-Ground Mounted
1	Q5-2A	51079	Active School	McCutcheon	John T McCutcheon Elementary School	4865 N Sheridan ROAD, Chicago IL 60640	2019	Main	25250	Site North	Chiller-Air Cooled-Recipitating-Ground Mounted
1	Q5-6A	52507	Active School	McKay	Camelot Excel - Southwest HS	6901 S Fairfield AVENUE, Chicago IL 60629	2019	Addition		Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	Q5-3A	51105	Active School	McNair	Ronald E McNair Elementary School	4820 W Walton STREET, Chicago IL 60651	2014	Main	98596	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2A	51067	Active School	McPherson	James B McPherson Elementary School	4728 N Wolcott AVENUE, Chicago IL 60640	2014	Addition 3	69623	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-9A	51503	Active School	Metcalfe	Ralph H Metcalfe Elementary Community Academ	12339 S Normal AVENUE, Chicago IL 60628	2019	Main	76400	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-9A	51503	Active School	Metcalfe	Ralph H Metcalfe Elementary Community Academ	12339 S Normal AVENUE, Chicago IL 60628	2019	Main	76400	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-3B	52514	Active School	Monroe	James Monroe Elementary School	2634 N Monticello AVENUE, Chicago IL 60647	2014	Linked Addition		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-2B	51122	Active School	Moos Elementary School	Bernhard Moos Elementary School	1711 N California AVENUE, Chicago IL 60647	2014	Addition	57687	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-6B	51631	Active School	Morgan Park HS	Morgan Park High School	1744 W Pryor AVENUE, Chicago IL 60643	2014	Addition	101977	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	Q5-3B	52522	Active School	Mozart	Wolfgang A Mozart Elementary School	2230 N Hamlin AVENUE, Chicago IL 60647	2019	Linked Addition		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-8A	51355	Active School	Murray	Phillip Murray Elementary Language Academy	5335 S Kenwood AVENUE, Chicago IL 60615	2014	Main	29338	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-8A	51355	Active School	Murray	Phillip Murray Elementary Language Academy	5335 S Kenwood AVENUE, Chicago IL 60615	2014	Addition 2	27886	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	Q5-4B	51254	Active School	NTA	National Teachers Elementary Academy	55 W Cermak ROAD, Chicago IL 60616	2019	Main	92500	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-4B	51254	Active School	NTA	National Teachers Elementary Academy	55 W Cermak ROAD, Chicago IL 60616	2019	Main	92500	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-4B	51254	Active School	NTA	National Teachers Elementary Academy	55 W Cermak ROAD, Chicago IL 60616	2019	Linked Addition-Athletic		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	Q5-1A	51080	Active School	New Field	New Field Elementary School	1707 W Morse AVENUE, Chicago IL 60626	2019	Main	85500	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted

1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary School	5250 S Rockwell STREET, Chicago IL 60632	2019	Main	71880	Entire Building	Chiller-Water Cooled- Cetrifugal
1	QS-6B	51305	Active School	Nightingale	Florence Nightingale Elementary School	5250 S Rockwell STREET, Chicago IL 60632	2019	Addition	56750	Mechanical Room	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-8B	51467	Active School	Ninos Heroes	Ninos Heroes Elementary Academic Center	8344 S Commercial AVENUE, Chicago IL 60617	2014	Main	73518	Site South	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-3B	54211	Active School	Nixon	William P Nixon Elementary School	2121 N Keeler AVENUE, Chicago IL 60639	2019	Linked Addition		Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-4A	51550	Active School	North-Grand HS	North-Grand High School	4338 W Wabansia AVENUE, Chicago IL 60639	2014	Main	205094	Entire Building	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-1A	51543	Active School	Northside CP HS	Northside College Preparatory High School	5501 N Kedzie AVENUE, Chicago IL 60625	2014	Main	222600	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-1B	51023	Active School	Norwood Park	Norwood Park Elementary School	5900 N Nina AVENUE, Chicago IL 60631	2019	Main	56330	In outside enclosure	Chiller-Air Cooled- Recipitating-Ground Mounted
1	QS-1B	51023	Active School	Norwood Park	Norwood Park Elementary School	5900 N Nina AVENUE, Chicago IL 60631	2019	Main	56330	In outside enclosure	Chiller-Air Cooled-Recipitating-Ground Mounted
1	QS-7A	51329	Active School	O'Toole	Luke O'Toole Elementary School	6550 S Seeley AVENUE, Chicago IL 60636	2014	Main	78700	Site North	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-2B	51171	Active School	Ogden Elem	William B Ogden Elementary School	24 W Walton STREET, Chicago IL 60610	2014	Main	132724	2nd Floor Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-1B	51025	Active School	Oriole Park	Oriole Park Elementary School	5424 N Oketo AVENUE, Chicago IL 60656	2019	Main	38534	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-1B	51025	Active School	Oriole Park	Oriole Park Elementary School	5424 N Oketo AVENUE, Chicago IL 60656	2019	Addition	37942	Site West	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	QS-5A	51256	Active School	Orozco	Orozco Fine Arts & Sciences Elementary School	1940 W 18th STREET, Chicago IL 60608	2014	Main	107722	Main Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago IL 60629	2014	Main	77900	Entire Building	Chiller-Water Cooled- Absorber
1	QS-6A	51306	Active School	Pasteur	Louis Pasteur Elementary School	5825 S Kostner AVENUE, Chicago IL 60629	2014	St Camillus		Entire Building	Chiller-Air Cooled-Recipitating-Ground Mounted
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory High School	1034 N Wells STREET, Chicago IL 60610	2019	Main	167870	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory High School	1034 N Wells STREET, Chicago IL 60610	2019	Main	167870	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-2B	51549	Active School	Payton College HS	Walter Payton College Preparatory High School	1034 N Wells STREET, Chicago IL 60610	2019	Addition	48605	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-6A	51307	Active School	Peck	Ferdinand Peck Elementary School	3826 W 58th STREET, Chicago IL 60629	2014	Main	76131	Mechanical Building/Centra	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	QS-2A	51069	Active School	Peirce	Helen Peirce International Studies ES	1423 W Bryn Mawr AVENUE, Chicago IL 60660	2019	Addition	71850	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-4A	51212	Active School	Penn	William Penn Elementary School	1616 S Avers AVENUE, Chicago IL 60623	2019	Main	158325	Site South	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-5A	52428	Active School	Perez	Manuel Perez Elementary School	1241 W 19th STREET, Chicago IL 60608	2014	Main	65134	1st Floor	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	QS-1A	51027	Active School	Peterson	Mary Gage Peterson Elementary School	5510 N Christiana AVENUE, Chicago IL 60625	2014	Main	65087	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	QS-2B	51185	Active School	Phoenix Military Academy HS	Phoenix Military Academy High School	145 S Campbell AVENUE, Chicago IL 60612	2019	Addition 3	27310	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-5A	51248	Active School	Pickard	Josiah Pickard Elementary School	2301 W 21st PLACE, Chicago IL 60608	2014	Addition	46690	Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-7B	51477	Active School	Pirie	John T Pirie Fine Arts & Academic Center ES	650 E 85th STREET, Chicago IL 60619	2014	Main	43063	Boiler Room and Roof	Chiller-Water Cooled- Cetrifugal
1	QS-1B	51028	Active School	Portage Park	Portage Park Elementary School	5330 W Berceau AVENUE, Chicago IL 60641	2019	Addition	43890	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-8B	54776	Active School	Powell	Adam Clayton Powell Paideia Community Academ	7511 S South Shore DRIVE, Chicago IL 60649	2014	Main	113516	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-3A	54698	Active School	Prieto	Dr Jorge Prieto Math and Science	2231 N Central AVENUE, Chicago IL 60639	2014	Main	106218	Lower Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-2B	51149	Active School	Pritzker	A.N. Pritzker School	2009 W Schiller STREET, Chicago IL 60622	2014	Main	66300	Exterior courtyard	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-4A	51574	Active School	Raby HS	Al Raby High School	3545 W Fulton BOULEVARD, Chicago IL 60624	2014	Main	156248	Site South	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-7B	51322	Active School	Randolph	Asa Philip Randolph Elementary School	7316 S Hoyne AVENUE, Chicago IL 60636	2014	Main	78450	Mechanical Room	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-2A	53001	Active School	Reilly	Frank W Reilly Elementary School	3650 W School STREET, IL 60618	2019	Linked Addition		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-5A	51278	Active School	Ruiz	Irma C Ruiz Elementary School	2410 S Leavitt STREET, Chicago IL 60608	2014	Main	73217	East Courtyard	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-6A	51312	Active School	Sandoval	Socorro Sandoval Elementary School	5534 S Saint Louis AVENUE, Chicago IL 60629	2019	Main	108534	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-1A	51032	Active School	Sauganash	Sauganash Elementary School	6040 N Kilpatrick AVENUE, Chicago IL 60646	2019	Addition 2	41498	Lower Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago IL 60632	2014	Main	79788		Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-6B	51308	Active School	Sawyer	Sidney Sawyer Elementary School	5242 S Sawyer AVENUE, Chicago IL 60632	2014	Annex			Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-2A	51537	Active School	Schurz HS	Carl Schurz High School	3601 N Milwaukee AVENUE, Chicago IL 60641	2014	Main	455800	Roof	Chiller-Water Cooled- Cetrifugal
1	QS-2A	51538	Active School	Senn HS	Nicholas Senn High School	5900 N Glenwood AVENUE, Chicago IL 60660	2014	Addition 1	33906	Roof	Chiller-Water Cooled- Cetrifugal
1	QS-7A	51359	Active School	Sherwood	Jesse Sherwood Elementary School	245 W 57th STREET, Chicago IL 60621	2014	Addition	19885	Site South	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-5B	53894	Active School	Shields	James Shields Elementary School	4231 S Talman STREET, Chicago IL 60632	2014	Annex	36100	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-5B	55216	Active School	Shields Middle School	James Shields Middle School	2611 W 48th STREET, Chicago IL 60632	2019	Main	95265	Lower Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-8A	51413	Active School	Shoesmith	Beulah Shoesmith Elementary School	1330 E 50th STREET, Chicago IL 60615	2019	Main	36887	Site North	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-9A	51516	Active School	Shoop	John D Shoop Math-Science Technical Academy E	11140 S Bishop STREET, Chicago IL 60643	2014	Addition	36007	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-7B	51604	Active School	Simeon HS	Neal F Simeon Career Academy High School	8147 S Vincennes AVENUE, Chicago IL 60620	2014	Main	210316	Roof Chiller	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-4B	54719	Active School	Skinner West	Mark Skinner Elementary School	1260 W Adams STREET, Chicago IL 60607	2014	Main	102055	Entire Building	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-2A	51036	Active School	Solomon	Hannah G Solomon Elementary School	6206 N Hamlin AVENUE, Chicago IL 60659	2014	Main	18083	Site North	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	QS-6A	54767	Active School	Solorio HS	Alcott High School for the Humanities	5400 S St Louis AVENUE, Chicago IL 60632	2014	Main	213710	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-4B	58744	Active School	South Loop	South Loop Elementary School	1601 S Dearborn STREET, Chicago IL 60616	2019	Main (New)		Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-8B	54787	Active School	South Shore International College Prep Hig	Ogden International High School	1955 E 75th STREET, Chicago IL 60649	2014	Main	213710	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-3A	51553	Active School	Steinmetz HS	Charles P Steinmetz College Preparatory HS	3030 N Mobile AVENUE, Chicago IL 60634	2014	Main	384200	Mechanical Room and Roof	Chiller-Water Cooled- Cetrifugal
1	QS-3A	51553	Active School	Steinmetz HS	Charles P Steinmetz College Preparatory HS	3030 N Mobile AVENUE, Chicago IL 60634	2014	Main	384200	Mechanical Room and Roof	Chiller-Water Cooled- Cetrifugal
1	QS-1B	51034	Active School	Stock	Frederick Stock Elementary School	7507 W Birchwood AVENUE, Chicago IL 60631	2019	Main	17355	Courtyard	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	QS-2A	51073	Active School	Stockton	Mary E Courtenay Elementary Language Arts Cen	4420 N Beacon STREET, Chicago IL 60640	2014	Main	92490	Site West	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-8B	51481	Active School	Sullivan	William K New Sullivan Elementary School	8331 S Mackinaw AVENUE, Chicago IL 60617	2014	Main	218126	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-8B	51481	Active School	Sullivan	William K New Sullivan Elementary School	8331 S Mackinaw AVENUE, Chicago IL 60617	2014	Main	218126	Roof	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-6B	51447	Active School	Sutherland	Elizabeth H Sutherland Elementary School	10015 S Leavitt STREET, Chicago IL 60643	2019	Main	69781	Next to boiler house	Chiller-Air Cooled-Screw Type-Ground Mounted
1	QS-2A	51075	Active School	Swift	George B Swift Elementary Specialty School	5900 N Winthrop AVENUE, Chicago IL 60660	2019	Addition 1	42691	Mechanical Room	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-1B	51540	Active School	Taft HS	William Howard Taft High School	6530 W Bryn Mawr AVENUE, Chicago IL 60631	2014	Main	175896	Mechanical Room and Roof	Chiller-Water Cooled- Cetrifugal
1	QS-1B	51540	Active School	Taft HS	William Howard Taft High School	6530 W Bryn Mawr AVENUE, Chicago IL 60631	2014	Main	175896	Mechanical Room and Roof	Chiller-Water Cooled- Cetrifugal
1	QS-6B	51679	Active School	Tarkington	Tarkington School of Excellence ES	3300 W 71st STREET, Chicago IL 60629	2014	Main	136289	Lower Roof, Boiler Room.	Chiller-Air Cooled-Recipitating-Roof Mounted
1	QS-6A	51310	Active School	Tonti	Enrico Tonti Elementary School	5815 S Homan AVENUE, Chicago IL 60629	2019	Main	62367	Mechanical Room	Chiller-Water Cooled- Cetrifugal
1	QS-6A	54221	Active School	Twain Elementary School - 54221	Mark Twain Elementary School	5134 S Lotus AVENUE, Chicago IL 60638	2019	Main	75820	Entire Building	Chiller-Water Cooled- Absorber
1	QS-6A	54221	Active School	Twain Elementary School - 54221	Mark Twain Elementary School	5134 S Lotus AVENUE, Chicago IL 60638	2019	Main	75820	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-3A	51126	Active School	West Park	West Park Elementary Academy	1425 N Tripp AVENUE, Chicago IL 60651	2014	Main	81350	Main Roof	Chiller-Air Cooled-Screw Type-Roof Mounted
1	QS-1A	54766	Active School	West Ridge	West Ridge Elementary School	6700 N Whipple STREET, Chicago IL 60645	2014	Main	100107	Lower Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-5A	59845	Active School	Whitney	Eli Whitney Elementary School	2845 S Komensky AVENUE, Chicago IL 60623	2014	Annex		Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-5A	59845	Active School	Whitney	Eli Whitney Elementary School	2845 S Komensky AVENUE, Chicago IL 60623	2014	Annex		Roof	Chiller-Air Cooled-Scroll Type-Roof Mounted
1	QS-1B	51040	Active School	Wildwood	Wildwood IB World Magnet School	6950 N Hiawatha AVENUE, Chicago IL 60646	2014	Main	24950	Boiler Room	Chiller-Air Cooled-Scroll Type-Ground Mounted
1	QS-3A	51103	Active School	Young Elementary School	Ella Flagg Young Elementary School	1434 N Parkside AVENUE, Chicago IL 60651	2014	Addition	69645	Roof	Chiller-Air Cooled-Screw Type-Roof Mounted

**VIII. BID EXECUTION PAGE**

The undersigned, hereby acknowledges having received Specification No. 21-350020 containing a full set of documents, including, 1) General Invitation, 2) General Terms and Conditions, 3) Specific Terms and Conditions, 4) Scope of Products and Services, 5) Submittal Requirements, 6) Evaluation Criteria and Basis of Award, 7) Bid Tabulation Page, 8) Bid Execution Page, 9) Attachments A, B, C, and D ; and 10) Addenda Nos. N/A (none unless indicated here). Bidder is responsible for reading and understanding all sections of this bid, and affirms that Bidder shall be bound by all of the terms and conditions contained in this bid.

The undersigned understands, by signing this document, that all documents submitted to the Board of Education of the City of Chicago ("Board") are a matter of public record and are subject to the Illinois Freedom of Information Act, 5 ILCS 140/1-11 ("FOIA"). Bidder acknowledges that if the Board receives a FOIA request for your Bid the Board must release those documents to the requester. However, the Board will consider redacting any portion to your bid which is attached under separate cover and designated "Trade secrets and commercial or financial information where the trade secrets or information are proprietary or where disclosure may cause competitive harm". (5 ILCS 140/7(1) (g)). Any portion of this bid designated as trade secrets or proprietary information which does not fall directly within this FOIA exemption will be subject to release by the Board pursuant to FOIA. The Board will not honor Bidder's request to mark the entire bid or substantial parts of the bid as confidential. In such cases, the entire bid will be subject to disclosure under FOIA.

If Bidder is awarded this Contract, Bidder acknowledges that the bid Contract will be posted online on the CPS website. If Bidder designates any portion of the bid proposal as exempt under FOIA, Bidder shall be responsible for submitting a redacted copy of the bid proposal and the redacted version shall be posted online.

Bidder agrees to indemnify, defend and hold the Board harmless from and against any loss, damage, expense, penalty, or cost, including any and all legal fees, sought in every claim or suit of any kind arising out of the Board redacting those portions of the bid, proposal or Addenda designated as trade secrets or proprietary information.

Further, the undersigned, being duly sworn, states on oath that no disclosures of ownership have been withheld from the Board, that the information provided herein is current, and Bidder and its officers and employees have not entered into any agreement with any other bidder or prospective bidder or with any other person, firm or corporation relating to any prices or other terms named in this bid or any other bid, nor has it entered into any agreement or arrangement under which a person, firm or corporation is to refrain from responding to this bid.

BIDDER'S NAME: Global Water Technology, Inc.

ADDRESS: 354 West Armory Drive

By: *Michael A. Byerley*  
(Signature)

CITY: South Holland, IL 60473

TELEPHONE: 708-349-9991

NAME: Michael A. Byerley

TITLE: President & CEO  
(Printed)

ATTEST BY: *Rena Schaver*  
(Signature)



Subscribed and Sworn to before me this  
day of February 22 2021

NAME: Rena Schaver

TITLE: Business Manager

Corporate Seal (requested, not required)

*Jennakah Castaneda*  
Notary Public Signature Seal of Notary



**VIII. BID EXECUTION PAGE**

**AWARD OF CONTRACT**

**Date of Award:** As of July 28, 2021 **Term of Contract:** October 1, 2021 through September 30, 2023

By execution below, the Board accepts the offer of **GLOBAL WATER TECHNOLOGY, INC.** for **WATER TREATMENT PRODUCTS AND SERVICES** in an amount not to exceed **\$1,946,250** for the two-year Term.

**BOARD OF EDUCATION OF THE CITY OF CHICAGO**

DS  
LB

Board Report No.: 21-0728-PR17

By: Miguel del Valle  
Miguel Del Valle, President

Attest: Estela Beltran  
Estela G. Beltran, Secretary

By: José M. Torres  
José M. Torres, PhD, Interim Chief Executive Officer

Approved as to legal form:  
Joseph T. Moriarty  
Joseph T. Moriarty, General Counsel

DS  
BH

DS  
JG

DS  
LB